

ALLEGHENY COUNTY AP, PA, USA

WMO: 725205

Lat: 40.355N

Lon: 79.922W

Elev: 380

StdP: 96.84

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 14762

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-14.9	-12.3	-20.3	0.6	-12.9	-17.9	0.8	-10.6	11.1	2.1	9.9	2.2	4.1	260	0.480

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.6	31.4	22.3	30.1	21.7	28.9	21.0	24.0	29.0	23.1	27.8	22.4	26.9	4.0	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
22.4	17.9	26.5	21.7	17.1	25.6	21.0	16.4	24.9	73.7	29.1	70.3	27.8	67.5	26.7	29.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.1	8.1	7.3	DB	-17.4	33.2	4.2	1.8	-20.4	34.5	-22.9	35.5	-25.2	36.5	-28.3	37.8	(4)
(5)			WB	-17.9	25.4	4.0	1.5	-20.8	26.5	-23.2	27.4	-25.4	28.2	-28.4	29.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	11.4	-1.5	0.1	4.7	11.4	16.6	21.0	23.0	22.3	18.7	12.5	6.4	1.4	(6)	
	DBStd	9.97	6.88	6.36	6.28	5.41	4.51	3.35	2.66	2.66	3.77	4.84	5.29	5.71	(7)	
	HDD10.0	1326	363	284	191	47	4	0	0	0	0	29	134	273	(8)	
	HDD18.3	2992	616	512	426	216	88	14	2	3	40	191	360	526	(9)	
	CDD10.0	1847	6	6	25	89	209	329	403	382	262	106	24	6	(10)	
	CDD18.3	471	0	0	1	7	35	94	146	126	52	9	0	0	(11)	
	CDH23.3	3475	0	1	7	68	289	695	1110	882	367	54	2	0	(12)	
	CDH26.7	934	0	0	1	9	61	191	331	243	91	7	0	0	(13)	
(14) Wind	WSAvg	3.5	4.2	4.1	4.0	4.0	3.3	3.1	2.9	2.6	2.7	3.3	3.7	4.0	(14)	
(15) Precipitation	PrecAvg	1015	85	63	83	86	96	105	101	91	86	68	72	82	(15)	
	PrecMax	1302	181	128	154	133	154	148	203	198	224	140	151	181	(16)	
	PrecMin	843	42	25	37	38	39	35	55	39	34	29	17	48	(17)	
	PrecStd	130	34	23	32	24	29	32	33	39	41	28	32	33	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	18.0	19.5	23.9	28.0	30.3	32.5	33.0	32.8	31.3	27.6	22.1	17.9	(19)	
		MCWB	13.3	12.1	14.9	16.9	20.7	22.5	23.8	23.1	21.1	19.6	15.3	13.5	(20)	
	2%	DB	14.8	15.9	21.0	25.4	28.3	30.4	31.4	31.0	29.1	24.8	19.0	15.2	(21)	
		MCWB	12.1	10.9	13.3	15.3	19.3	21.9	22.7	22.4	20.6	17.6	13.1	12.1	(22)	
	5%	DB	12.0	12.7	17.7	22.9	26.8	28.9	29.9	29.1	27.3	22.6	17.1	12.7	(23)	
		MCWB	9.9	8.6	11.3	14.4	18.7	21.3	21.8	21.5	20.1	16.5	12.2	9.8	(24)	
	10%	DB	8.2	9.4	14.6	20.5	24.7	27.4	28.5	27.7	25.4	20.4	14.8	10.1	(25)	
		MCWB	5.9	5.9	9.8	13.0	17.5	20.4	21.3	20.9	18.9	15.6	11.0	7.4	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	14.5	14.1	15.9	18.5	22.4	24.1	25.5	25.0	23.4	21.4	16.6	14.9	(27)	
		MCDB	17.0	17.8	22.2	25.1	28.3	29.7	31.0	30.1	28.4	25.4	20.3	17.0	(28)	
	2%	WB	12.4	11.9	14.1	16.9	20.8	23.0	24.2	23.7	22.2	19.5	14.7	12.6	(29)	
		MCDB	14.3	14.9	18.9	22.8	26.4	28.4	29.2	28.3	26.5	23.1	17.8	14.7	(30)	
	5%	WB	9.7	8.9	12.5	15.7	19.8	22.2	23.2	22.8	21.2	17.8	13.1	10.3	(31)	
		MCDB	11.9	12.5	16.8	20.7	24.7	27.3	27.8	27.2	24.8	21.0	16.0	12.3	(32)	
	10%	WB	6.1	6.2	10.2	14.4	18.6	21.4	22.4	22.0	20.1	16.0	11.3	7.6	(33)	
		MCDB	8.1	9.2	14.3	19.1	23.1	25.9	26.7	26.1	23.8	19.7	14.4	9.5	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	7.5	8.2	9.5	10.9	10.4	9.7	9.6	9.6	9.8	9.4	8.2	7.0	(35)	
		MCDBR	10.3	12.6	13.2	13.6	12.6	11.4	11.0	11.2	11.7	12.0	11.4	10.5	(36)	
	5% WB	MCWBR	8.3	9.5	8.0	7.2	5.8	5.0	4.3	4.4	4.8	6.2	7.6	8.5	(37)	
		MCWBR	9.9	11.8	11.8	11.7	10.8	10.0	9.5	9.3	9.5	9.9	10.0	10.0	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.303	0.325	0.350	0.380	0.425	0.457	0.467	0.466	0.389	0.363	0.319	0.299	(40)	
		taud	2.458	2.376	2.385	2.330	2.215	2.160	2.149	2.135	2.332	2.406	2.510	2.512	(41)	
	Edn at Noon		862	888	902	893	856	826	813	801	848	833	837	840	(42)	
		Edh at Noon	78	98	109	123	141	149	149	148	113	94	74	69	(43)	
(44) All-Sky Solar Radiation	RadAvg		1.52	2.36	3.33	4.53	5.25	5.71	5.73	5.19	4.24	2.85	1.94	1.29	(44)	
	RadStd		0.15	0.34	0.32	0.44	0.45	0.46	0.37	0.31	0.44	0.29	0.25	0.14	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (37 neighbors)		+0.41	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+122	+58	

Nomenclature: See separate page