

BUFFALO NIAGARA, NY, USA

WMO: 725280

Lat: 42.9411N

Lon: 78.7189W

Elev: 218

StdP: 98.73

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 14733

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-16.4	-14.0	-20.7	0.6	-15.7	-18.4	0.8	-13.2	14.8	-0.2	13.4	0.0	4.6	260	0.580

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.9	30.2	21.8	28.8	21.1	27.6	20.6	23.7	27.6	22.9	26.8	22.0	25.8	5.3	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
22.4	17.6	26.0	21.5	16.6	25.3	20.6	15.7	24.6	71.8	27.6	68.6	27.0	65.5	25.9	27.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.9	10.6	9.2	DB	-19.1	32.5	3.0	1.5	-21.3	33.6	-23.0	34.5	-24.7	35.3	-26.9	36.4	(4)
(5)			WB	-19.5	24.7	2.9	1.1	-21.5	25.5	-23.2	26.1	-24.8	26.7	-26.9	27.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	9.4	-3.8	-3.1	1.1	7.6	14.3	19.5	22.0	21.3	17.7	11.2	5.0	-0.3	(6)
(7)		DBStd	10.31	6.30	5.84	5.82	4.98	4.61	3.61	2.82	2.75	3.87	4.54	4.89	5.15	(7)
(8)		HDD10.0	1718	428	367	282	105	12	0	0	0	1	41	162	321	(8)
(9)		HDD18.3	3583	685	599	533	324	142	29	4	6	58	226	398	578	(9)
(10)		CDD10.0	1512	1	1	7	32	146	284	371	351	230	77	13	1	(10)
(11)		CDD18.3	337	0	0	0	1	17	63	117	98	37	4	0	0	(11)
(12)		CDH23.3	2283	0	0	2	14	132	427	817	621	250	20	0	0	(12)
(13)		CDH26.7	481	0	0	0	2	23	96	183	123	52	1	0	0	(13)
(14)	Wind	WSAvg	4.5	5.4	5.2	4.8	4.8	4.3	4.0	3.9	3.6	4.2	4.7	4.9	(14)	
(15)	Precipitation	PrecAvg	984	76	59	70	76	84	84	80	97	92	78	97	91	(15)
(16)		PrecMax	1360	175	150	152	150	183	212	227	271	228	154	248	221	(16)
(17)		PrecMin	725	28	21	30	23	15	16	18	42	20	8	39	39	(17)
(18)		PrecStd	132	36	28	27	32	35	45	44	46	44	34	37	38	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	15.9	15.4	21.0	25.3	29.1	31.5	31.9	31.5	30.6	25.6	19.8	16.0	(19)
(20)			MCWB	12.8	11.1	14.0	16.5	20.0	22.2	22.4	21.9	21.8	18.7	14.1	12.6	(20)
(21)		2%	DB	11.1	11.0	16.0	21.6	26.8	29.2	30.1	29.4	28.1	23.2	17.3	11.6	(21)
(22)			MCWB	9.3	7.8	11.2	14.2	19.1	21.0	22.2	21.7	21.0	17.4	13.1	9.0	(22)
(23)		5%	DB	7.5	7.3	12.9	18.8	24.5	27.5	28.6	28.0	26.2	20.8	15.2	9.3	(23)
(24)			MCWB	5.6	4.6	9.1	12.3	17.3	20.1	21.3	20.9	19.9	16.3	11.0	7.4	(24)
(25)		10%	DB	4.6	4.5	9.9	16.0	22.3	25.9	27.4	26.7	24.3	18.5	12.7	6.7	(25)
(26)			MCWB	2.9	2.4	6.4	10.7	16.0	19.4	20.9	20.5	18.9	14.5	9.6	4.7	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	12.9	11.9	15.1	17.8	21.4	24.1	25.0	24.5	23.4	20.6	15.4	12.7	(27)
(28)			MADB	15.8	14.7	20.1	23.7	27.5	28.3	29.1	28.2	28.0	23.5	18.4	15.6	(28)
(29)		2%	WB	9.6	7.9	11.9	15.2	20.0	22.6	23.9	23.4	22.2	18.7	13.7	9.8	(29)
(30)			MADB	11.2	10.7	15.0	20.1	25.4	27.2	27.8	27.0	26.3	22.2	16.5	11.2	(30)
(31)		5%	WB	5.9	5.0	9.4	13.4	18.5	21.5	23.0	22.5	21.0	16.6	11.8	7.5	(31)
(32)			MADB	7.3	7.0	12.9	17.7	23.4	25.7	26.7	26.1	24.7	20.0	14.6	9.5	(32)
(33)		10%	WB	3.0	2.4	6.6	11.2	17.0	20.6	22.1	21.6	19.9	15.0	10.0	4.9	(33)
(34)			MADB	4.4	4.3	9.5	15.1	20.9	24.4	25.8	25.2	23.4	18.1	12.5	6.5	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	6.9	7.3	8.1	9.7	9.8	9.0	8.9	9.2	8.1	7.1	6.0	(35)	
(36)			MADB	9.9	11.5	12.8	14.5	12.2	11.1	10.1	10.3	11.1	11.0	10.7	9.1	(36)
(37)			MCWBR	8.9	9.1	8.7	9.0	6.4	5.5	4.8	5.1	5.6	6.4	7.9	7.8	(37)
(38)		5% WB	MADB	9.7	11.0	12.0	13.1	11.1	9.1	8.1	8.0	9.2	9.4	9.8	9.0	(38)
(39)			MCWBR	9.0	9.3	8.8	9.3	6.7	5.3	4.7	5.0	5.3	6.3	7.9	8.2	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.295	0.321	0.331	0.371	0.400	0.433	0.432	0.422	0.375	0.358	0.312	0.295	(40)	
(41)		taud	2.396	2.319	2.406	2.334	2.291	2.230	2.245	2.261	2.374	2.414	2.511	2.466	(41)	
(42)		Ebn at Noon	842	872	912	895	874	843	839	835	852	821	821	812	(42)	
(43)		Edh at Noon	78	99	104	120	129	138	135	128	106	90	70	67	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.29	2.09	3.27	4.40	5.40	5.79	5.85	5.20	4.15	2.50	1.55	1.05	(44)	
(45)		RadStd	0.12	0.21	0.35	0.47	0.56	0.45	0.46	0.28	0.38	0.24	0.22	0.14	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days					
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+88	N/A		
(47) Regional (53 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Nomenclature: See separate page