

NIAGARA FALLS INTL, NY, USA

WMO: 725287

Lat: 43.108N

Lon: 78.938W

Elev: 178

StdP: 99.20

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 04724

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-16.7	-14.1	-20.9	0.6	-15.9	-18.4	0.8	-13.5	14.6	-1.7	13.0	-2.4	4.6	260	0.587

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.1	31.1	22.4	29.6	21.7	28.1	20.9	24.0	28.7	23.0	27.6	22.2	26.5	5.8	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
22.5	17.5	26.5	21.6	16.6	25.7	20.9	15.9	25.0	72.7	28.7	69.2	27.6	66.1	26.4	27.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
11.9	10.7	9.2	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
			-19.9	33.0	3.4	1.5	-22.3	34.1	-24.3	35.0	-26.2	35.9	-28.7	37.0		
			-20.2	25.5	3.3	1.2	-22.6	26.4	-24.6	27.1	-26.4	27.8	-28.8	28.7		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	9.3	-4.1	-3.4	0.9	7.5	14.2	19.6	22.1	21.2	17.3	10.9	4.6	-0.5	(6)
(7)		DBStd	10.39	6.27	5.77	5.60	4.84	4.55	3.69	3.00	2.93	3.94	4.49	4.69	5.11	(7)
(8)		HDD10.0	1760	439	375	287	104	12	0	0	0	1	43	172	326	(8)
(9)		HDD18.3	3651	697	608	541	327	144	28	4	8	66	234	412	583	(9)
(10)		CDD10.0	1489	1	1	5	29	142	288	376	347	219	71	10	1	(10)
(11)		CDD18.3	338	0	0	0	1	16	66	122	97	34	3	0	0	(11)
(12)		CDH23.3	2662	0	0	1	16	166	527	976	703	255	18	0	0	(12)
(13)		CDH26.7	694	0	0	0	2	37	143	281	172	59	1	0	0	(13)
(14)	Wind	WSAvg	4.4	5.5	5.3	4.9	4.8	4.1	3.8	3.7	3.5	3.6	4.3	4.8	5.1	(14)
(15)	Precipitation	PrecAvg	896	68	53	65	75	78	71	86	81	85	77	79	78	(15)
(16)		PrecMax	1091	119	117	121	131	140	157	185	137	178	187	119	167	(16)
(17)		PrecMin	711	36	24	30	34	19	19	25	37	45	22	27	32	(17)
(18)		PrecStd	103	25	22	24	30	35	37	40	30	32	39	22	30	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	14.7	14.5	20.9	25.9	29.8	32.2	33.0	32.4	31.1	25.6	19.1	15.4	(19)
(20)		0.4%	MCWB	12.0	10.4	14.4	17.0	20.5	23.0	23.0	23.1	21.9	18.7	14.0	12.4	(20)
(21)		2%	DB	10.5	10.2	15.7	22.0	27.5	30.1	31.2	30.1	28.3	22.9	17.0	11.3	(21)
(22)		2%	MCWB	8.9	7.2	10.6	14.2	19.2	21.6	22.7	22.2	21.2	17.1	12.7	8.9	(22)
(23)		5%	DB	7.3	7.2	12.5	18.7	25.1	28.1	29.6	28.5	26.3	20.8	14.8	8.9	(23)
(24)		5%	MCWB	5.6	4.6	9.0	12.4	17.6	20.9	21.7	21.2	19.8	16.4	11.2	7.1	(24)
(25)		10%	DB	4.2	4.1	9.5	16.0	22.6	26.4	28.0	27.2	24.1	18.4	12.4	6.4	(25)
(26)		10%	MCWB	2.4	2.1	6.3	10.7	16.0	19.5	20.9	20.7	18.9	14.7	9.4	4.2	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	12.3	11.6	15.1	17.9	21.9	24.6	25.5	25.2	23.5	20.3	15.2	12.2	(27)
(28)		0.4%	MCDWB	14.3	14.0	19.9	24.2	28.5	29.9	30.6	29.3	28.7	23.7	18.1	14.5	(28)
(29)		2%	WB	9.0	7.6	11.7	15.2	20.2	22.9	24.1	23.6	22.2	18.3	13.5	9.2	(29)
(30)		2%	MCDWB	10.2	9.9	14.5	20.3	26.1	28.4	29.0	27.8	26.5	21.7	16.2	10.8	(30)
(31)		5%	WB	5.6	4.7	9.2	13.3	18.7	21.8	23.2	22.8	21.0	16.6	11.6	7.1	(31)
(32)		5%	MCDWB	7.0	6.8	12.4	17.5	23.9	26.5	27.7	26.7	24.5	20.1	14.2	8.9	(32)
(33)		10%	WB	2.8	2.4	6.4	11.1	17.1	20.7	22.2	21.9	19.9	15.0	9.7	4.7	(33)
(34)		10%	MCDWB	4.1	4.2	9.1	15.2	21.1	24.9	26.4	25.7	23.4	18.0	12.4	6.5	(34)
(35)	Mean Daily Temperature Range		MDBR	7.2	7.8	8.6	10.5	11.2	10.4	10.1	10.0	10.3	9.0	7.8	6.4	(35)
(36)		5% DB	MCDDBR	9.5	11.4	13.2	15.2	13.9	12.0	11.3	11.3	12.2	12.2	11.4	9.1	(36)
(37)			MCWBR	8.7	9.4	9.3	9.5	7.5	6.1	5.3	5.4	6.3	7.3	8.5	7.7	(37)
(38)			MCDDBR	9.3	10.9	12.3	13.5	12.7	10.4	9.6	9.5	10.3	10.5	10.3	8.8	(38)
(39)		5% WB	MCWBR	8.7	9.4	9.2	9.7	7.6	6.2	5.4	5.2	6.1	7.2	8.4	7.9	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.296	0.322	0.333	0.374	0.404	0.433	0.432	0.420	0.380	0.361	0.314	0.298	(40)	
(41)		taud	2.417	2.340	2.407	2.332	2.290	2.240	2.260	2.282	2.375	2.410	2.507	2.472	(41)	
(42)		Ebn at Noon	841	871	909	892	870	842	838	836	847	816	817	808	(42)	
(43)		Edh at Noon	76	97	103	120	129	137	132	125	106	91	70	67	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.31	2.10	3.31	4.42	5.42	5.84	5.88	5.22	4.16	2.51	1.56	1.06	(44)	
(45)		RadStd	0.12	0.19	0.35	0.47	0.57	0.44	0.45	0.28	0.37	0.23	0.21	0.13	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(46)
		N/A	N/A	N/A	N/A	N/A	-0.51	N/A	N/A	N/A	N/A	
(47)	Regional (50 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page