

GARRETT COUNTY AP, MD, USA

WMO: 725293

Lat: 39.580N

Lon: 79.339W

Elev: 2933

StdP: 13.20

Time Zone: -5.00 (NAE)

Period: 07-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	0.8	5.1	-8.4	3.9	7.8	-3.7	5.0	10.2	24.4	29.2	22.6	27.8	9.6	280	0.525

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.1	80.8	67.7	78.6	66.4	76.7	65.6	72.1	76.9	70.2	74.2	68.7	72.9	6.6	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
70.5	125.2	73.2	68.5	116.7	71.9	67.7	113.8	71.4	37.7	75.9	36.2	73.0	34.6	74.0	80.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.7	19.2	17.4	-3.5	84.0	5.2	2.8	-7.3	86.0	-10.4	87.6	-13.3	89.2	-17.2	91.2
			-4.1	72.4	5.2	1.8	-7.8	73.7	-10.9	74.8	-13.8	75.8	-17.6	77.2
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	47.7	24.8	29.8	35.9	47.0	57.0	63.5	67.2	66.0	60.8	49.8	39.0	31.0
	DBStd	17.22	12.09	11.25	11.11	10.33	8.68	5.53	4.60	4.74	6.97	9.50	9.24	10.71
	HDD50	3097	785	571	458	176	38	1	0	0	5	123	346	594
	HDD65	6592	1248	986	903	546	269	90	31	46	162	478	779	1054
	CDD50	2272	3	6	20	85	254	406	534	495	330	117	17	5
	CDD65	290	0	0	0	5	20	45	100	76	37	7	0	0
	CDH74	961	0	0	0	28	80	141	334	227	131	20	0	0
	CDH80	64	0	0	0	1	2	9	28	15	9	0	0	0
Wind	WSAvg	8.4	10.2	10.1	9.8	10.0	8.1	7.0	5.9	5.7	6.8	8.6	9.3	9.8
Precipitation	PrecAvg	46.8	3.9	3.2	4.3	3.9	4.7	4.8	4.4	4.0	3.6	3.0	3.1	3.9
	PrecMax	61.3	6.9	5.0	7.1	6.1	7.7	7.1	8.1	8.1	8.3	5.5	6.5	7.4
	PrecMin	36.6	2.1	1.5	1.5	1.9	2.0	2.2	2.7	2.2	0.7	0.9	0.4	1.8
	PrecStd	6.1	1.3	1.0	1.5	1.3	1.7	1.4	1.4	1.5	2.0	1.4	1.3	1.5
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	57.0	62.7	67.7	78.6	79.4	81.2	82.3	81.8	81.4	77.0	66.1	60.7
		MCWB	51.7	52.3	54.5	55.0	63.5	67.3	71.0	69.5	65.5	66.2	54.1	53.2
	2%	DB	52.1	54.7	61.4	72.4	76.8	77.4	80.7	79.2	77.4	72.0	60.8	54.3
		MCWB	49.1	49.6	50.7	54.7	62.6	66.0	69.8	66.8	65.3	62.5	50.4	51.1
	5%	DB	46.1	51.7	56.8	68.1	72.8	74.9	77.4	76.9	73.5	67.9	55.4	51.7
		MCWB	43.1	47.8	48.1	53.4	60.5	65.0	67.7	66.6	63.7	59.1	47.6	49.4
	10%	DB	41.4	46.1	53.6	63.2	70.2	72.4	75.1	73.2	71.9	63.5	53.6	46.4
		MCWB	37.6	42.0	47.7	50.5	59.7	64.3	66.4	65.0	63.4	57.3	47.0	43.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	53.7	55.0	56.5	60.3	68.9	72.0	76.5	75.4	71.6	68.1	57.7	55.0
		MCDB	56.7	59.9	63.2	68.5	72.7	75.9	77.7	78.7	74.9	73.5	63.1	58.5
	2%	WB	49.7	51.9	53.6	57.3	66.1	69.3	72.5	71.2	68.9	65.0	54.0	52.0
		MCDB	51.6	53.9	57.9	65.8	72.5	73.2	78.0	75.3	73.3	70.1	58.2	53.8
	5%	WB	44.2	48.1	51.2	55.4	63.7	67.8	70.6	69.2	67.0	63.0	50.6	49.5
		MCDB	45.7	51.2	56.2	63.7	69.3	73.4	75.3	73.1	72.8	65.3	54.0	51.0
	10%	WB	37.6	43.0	47.2	53.6	62.1	66.3	69.2	67.6	64.5	58.8	47.2	45.2
		MCDB	40.2	46.6	52.9	60.5	67.0	71.9	72.9	72.3	69.2	62.9	52.1	46.2
Mean Daily Temperature Range	5% DB	MDBR	13.0	14.2	14.9	17.6	15.4	13.9	14.1	13.8	14.9	14.2	13.1	11.5
		MCDBR	17.4	19.7	20.5	22.7	18.3	16.1	15.6	15.6	16.4	16.6	17.6	16.0
		MCWBR	15.4	15.9	13.1	11.0	9.0	8.3	7.7	7.5	8.3	9.1	11.8	13.0
	5% WB	MCDBR	17.5	19.9	18.2	20.5	15.8	14.3	14.7	13.3	14.6	14.8	16.8	15.2
		MCWBR	16.5	17.4	13.3	11.5	8.2	8.6	7.9	7.8	7.9	9.3	13.8	13.7
Clear-Sky Solar Irradiance	taub	0.277	0.293	0.317	0.356	0.396	0.432	0.453	0.457	0.377	0.330	0.295	0.278	
	taud	2.499	2.434	2.449	2.371	2.261	2.180	2.144	2.105	2.325	2.472	2.543	2.533	
	Ebn at Noon	287	296	299	292	280	269	262	257	274	278	278	279	
	Edh at Noon	24	30	32	37	43	46	48	49	36	28	23	22	
All-Sky Solar Radiation	RadAvg	523	782	1099	1457	1645	1820	1785	1621	1342	946	654	456	
	RadStd	56	122	87	131	150	140	108	93	161	112	74	47	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (37 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+194	N/A

Nomenclature: See separate page