

ANSON COUNTY AP, NC, USA

WMO: 725294

Lat: 35.017N

Lon: 80.083W

Elev: 299

StdP: 14.54

Time Zone: -5.00 (NAE)

Period: 07-19

WBAN: 00383

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	18.9	23.0	0.3	5.6	30.4	6.5	7.8	34.0	19.1	48.7	16.5	46.7	1.5	220	0.369

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.8	96.5	73.4	93.8	73.3	91.3	73.2	77.8	87.4	77.0	86.6	76.2	85.7	5.7	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
75.3	134.0	80.7	74.5	130.3	80.2	73.3	124.9	79.3	41.3	88.3	40.5	86.1	39.6	85.8	81.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
15.3	12.5	10.8	DB	11.1	99.2	5.0	2.7	7.5	101.1	4.6	102.7	1.8	104.2	-1.8	106.1
			WB	10.6	79.7	4.9	1.2	7.1	80.5	4.2	81.2	1.5	81.9	-2.0	82.7

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	61.9	41.5	46.3	51.9	61.9	70.7	78.1	80.3	79.0	73.5	62.2	50.2	46.6	(6)
	DBStd	15.65	9.95	10.05	9.56	7.78	6.38	4.71	3.74	4.19	5.68	8.22	8.25	9.55	(7)
	HDD50	866	300	178	93	6	0	0	0	0	0	7	97	185	(8)
	HDD65	3037	730	528	417	149	27	0	0	0	8	153	449	576	(9)
	CDD50	5218	36	74	154	363	640	843	941	898	704	384	102	79	(10)
	CDD65	1916	1	5	13	56	203	393	476	434	261	65	4	5	(11)
	CDH74	18753	4	33	142	574	1848	4047	4887	4180	2351	645	28	14	(12)
	CDH80	8121	0	1	17	124	648	1929	2345	1915	975	166	1	0	(13)
(14) Wind	WSAvg	3.4	3.4	4.0	4.5	4.5	3.6	3.2	3.1	2.7	3.0	2.9	3.0	3.0	(14)
(15) Precipitation	PrecAvg	45.1	3.5	3.3	4.2	3.4	3.3	4.2	5.2	4.4	4.0	3.4	3.0	3.2	(15)
	PrecMax	62.8	9.2	5.3	8.2	7.7	7.6	7.8	12.9	7.8	11.2	14.6	7.8	6.2	(16)
	PrecMin	31.0	0.9	1.5	1.4	1.1	1.3	0.4	1.8	0.6	0.4	0.0	0.4	1.3	(17)
	PrecStd	7.4	1.9	1.2	1.7	1.8	1.7	2.0	2.6	1.9	2.9	3.0	2.0	1.3	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	73.1	78.5	82.1	87.1	93.2	98.6	99.1	99.5	95.0	89.8	77.3	75.9	(19)
		MCWB	61.3	63.5	61.5	66.3	71.2	72.7	73.6	73.3	69.8	71.9	62.7	66.2	(20)
	2%	DB	67.7	73.2	78.5	83.6	89.8	95.3	96.2	95.0	91.3	84.1	73.1	71.1	(21)
		MCWB	59.1	60.1	61.0	64.6	69.6	73.1	74.5	73.7	71.1	68.8	61.6	64.9	(22)
	5%	DB	63.7	68.8	73.8	80.9	86.9	92.7	93.4	91.7	89.5	81.0	69.9	67.8	(23)
		MCWB	56.2	57.8	58.3	64.2	69.4	72.9	74.2	74.5	70.7	66.7	60.8	63.1	(24)
	10%	DB	59.0	64.2	69.8	77.1	83.6	90.2	90.8	89.9	86.3	77.2	66.2	63.7	(25)
		MCWB	51.8	55.4	57.6	62.4	68.8	72.4	73.9	74.0	70.4	65.9	58.0	58.4	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	65.1	65.9	65.5	71.5	75.0	77.7	79.2	79.1	77.0	75.2	68.3	69.2	(27)
		MCDB	69.9	74.6	73.4	79.2	85.3	88.5	88.9	88.3	84.8	81.3	71.5	72.0	(28)
	2%	WB	62.0	63.6	63.9	69.2	73.1	76.4	77.9	78.0	75.5	73.5	65.6	66.2	(29)
		MCDB	65.8	70.0	71.6	76.6	81.8	87.5	88.0	86.9	84.5	79.5	70.4	69.5	(30)
	5%	WB	58.1	60.6	62.4	67.3	71.9	75.4	77.0	77.1	74.3	71.4	63.0	63.1	(31)
		MCDB	62.3	67.1	69.7	75.0	80.7	86.6	87.1	85.9	82.3	77.6	67.2	66.9	(32)
	10%	WB	52.9	56.9	60.1	65.5	70.8	74.4	76.1	76.1	73.0	68.7	59.8	59.8	(33)
		MCDB	57.0	63.0	67.8	74.0	79.3	84.7	86.0	84.8	80.3	74.7	65.4	63.4	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	21.8	22.8	24.5	24.4	22.4	21.8	20.8	20.0	21.8	24.5	25.2	21.3	(35)
		MCDBR	27.7	26.6	28.5	27.2	25.4	24.7	23.7	23.2	26.5	27.1	28.4	22.2	(36)
		MCWBR	18.4	15.7	13.9	11.9	9.6	7.4	6.7	7.1	8.9	13.0	17.5	15.6	(37)
	5% WB	MCDBR	22.2	22.4	23.1	21.2	20.6	21.6	19.6	19.4	19.5	19.9	20.1	18.9	(38)
(40) Clear-Sky Solar Irradiance	taub	taub	0.315	0.325	0.362	0.405	0.466	0.491	0.544	0.518	0.433	0.388	0.333	0.312	(40)
		taud	2.506	2.470	2.399	2.270	2.146	2.114	1.991	2.051	2.280	2.376	2.487	2.547	(41)
		Ebn at Noon	283	292	288	279	263	255	241	245	262	265	273	278	(42)
	Edh at Noon		26	30	36	43	49	50	56	52	40	33	27	24	(43)
(44) All-Sky Solar Radiation	RadAvg		844	1050	1392	1744	1924	2036	1918	1744	1482	1217	928	731	(44)
	RadStd		49	121	103	129	156	144	121	82	128	153	75	64	(45)

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (71 neighbors)		+0.88	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+290	+211

Nomenclature: See separate page