

FINDLAY, OH, USA

WMO: 725366

Lat: 41.014N

Lon: 83.669W

Elev: 800

StdP: 14.28

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 14825

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	0.5	5.8	-7.4	3.8	1.0	-1.8	5.1	6.8	29.0	28.9	26.9	29.1	9.0	250	0.542

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.3	90.5	73.7	88.2	72.5	85.7	71.0	76.8	86.7	75.0	83.9	73.4	81.8	10.7	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
73.4	128.0	82.8	72.1	122.5	80.8	70.6	116.2	78.8	40.6	87.1	38.9	83.6	37.5	81.9	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 25.8	(b) 22.5	(c) 19.7	(e) -5.0	(f) 94.3	(g) 7.3	(h) 2.8	(i) -10.3	(j) 96.3	(k) -14.6	(l) 97.9	(m) -18.7	(n) 99.5	(o) -24.0	(p) 101.5		
(4) 25.8	(5) 22.5	(6) 19.7	(7) -5.0	(8) 94.3	(9) 7.3	(10) 2.8	(11) -10.3	(12) 96.3	(13) -14.6	(14) 97.9	(15) -18.7	(16) 99.5	(17) -24.0	(18) 101.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	51.5	26.2	29.3	38.5	50.5	61.5	70.8	73.7	71.9	65.8	54.2	42.0	31.8
	DBStd	19.08	12.35	11.51	10.92	9.32	8.61	6.55	5.31	5.23	7.37	8.98	9.64	10.42
	HDD50	2727	742	584	388	105	8	0	0	0	1	56	275	568
	HDD65	5825	1204	999	824	443	173	23	3	8	78	352	690	1028
	CDD50	3267	3	5	31	120	366	623	736	679	476	187	36	5
	CDD65	889	0	0	2	8	66	196	274	222	103	18	0	0
	CDH74	7636	0	0	13	90	603	1671	2423	1777	903	153	3	0
	CDH80	2449	0	0	2	11	165	575	853	533	279	31	0	0
Wind	WSAvg	9.4	11.5	11.0	10.8	11.0	9.4	8.1	7.0	6.5	7.3	9.1	10.3	10.6
Precipitation	PrecAvg	34.4	1.7	1.6	2.5	3.1	3.9	3.9	4.0	3.5	2.9	2.2	2.7	2.4
	PrecMax	44.2	4.6	4.4	6.2	6.7	9.1	10.9	10.4	7.6	9.1	5.5	7.0	6.8
	PrecMin	23.4	0.5	0.2	0.7	0.8	0.8	0.4	0.3	0.2	0.5	0.5	0.3	0.6
	PrecStd	5.8	1.0	1.0	1.3	1.4	1.6	2.0	2.2	2.0	1.7	1.2	1.5	1.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	60.3	65.0	74.8	81.5	88.3	93.0	93.8	91.7	91.2	84.0	71.7	62.7
		MCWB	55.6	56.3	62.0	64.5	69.2	72.4	76.7	74.8	72.5	68.5	58.2	57.2
	2%	DB	54.9	56.8	67.0	76.3	84.4	89.8	90.5	88.4	87.3	78.3	64.9	56.1
		MCWB	51.6	51.4	56.9	61.0	67.8	72.1	74.9	73.8	70.7	64.1	56.8	52.0
	5%	DB	49.1	50.3	61.4	71.6	81.1	86.5	87.9	85.5	82.9	73.6	61.3	51.3
		MCWB	45.7	45.4	53.9	58.4	66.3	70.6	73.2	72.0	68.5	62.1	54.7	47.9
	10%	DB	42.6	44.7	56.0	66.6	76.7	83.0	84.9	82.7	79.3	69.3	57.0	45.8
		MCWB	39.3	40.6	49.7	55.9	64.6	69.3	71.5	70.8	66.2	60.2	51.4	42.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	56.1	57.5	63.1	67.6	73.1	76.5	79.3	78.3	75.6	71.3	62.7	58.2
		MCDB	59.5	62.3	72.5	76.0	83.5	87.4	90.0	88.3	86.6	81.1	68.0	62.2
	2%	WB	52.2	51.8	58.6	63.3	70.5	74.4	77.4	76.3	73.3	67.4	58.6	52.7
		MCDB	55.0	56.3	65.4	73.6	80.7	84.9	87.7	85.0	82.4	74.6	63.4	55.5
	5%	WB	45.9	45.8	54.8	60.2	68.4	72.8	75.4	74.4	71.0	64.3	55.3	47.8
		MCDB	48.7	49.9	60.8	68.6	77.3	82.9	84.2	82.1	78.8	71.5	60.1	51.0
	10%	WB	39.4	40.6	50.1	57.2	66.3	71.2	73.6	72.8	68.9	61.0	51.4	42.9
		MCDB	42.3	44.6	56.0	65.3	74.5	80.4	81.5	79.9	76.2	68.1	56.5	45.8
Mean Daily Temperature Range	5% DB	MDBR	13.7	14.3	16.9	20.2	19.8	19.0	19.3	19.2	20.9	19.1	15.6	12.5
		MCDBR	17.8	21.1	24.3	26.7	23.9	22.8	21.5	21.4	24.7	24.4	21.4	17.7
		MCWBR	15.8	17.1	16.3	15.4	12.0	10.0	9.3	9.9	11.2	13.0	15.1	15.2
	5% WB	MCDBR	17.6	20.1	22.2	23.1	21.0	19.2	18.8	18.4	20.1	20.5	19.3	17.0
		MCWBR	16.2	17.1	16.1	15.3	11.9	9.8	9.3	9.7	10.2	12.3	15.2	15.5
Clear-Sky Solar Irradiance	taub	0.305	0.330	0.352	0.401	0.437	0.448	0.445	0.441	0.392	0.360	0.326	0.305	
	taud	2.395	2.320	2.334	2.214	2.158	2.177	2.204	2.198	2.314	2.385	2.437	2.429	
	Ebn at Noon	269	278	284	276	268	264	264	261	267	264	259	259	
	Edh at Noon	26	32	36	43	47	46	45	44	36	30	25	23	
All-Sky Solar Radiation	RadAvg	499	792	1107	1478	1732	1920	1917	1707	1388	932	606	416	
	RadStd	49	99	100	127	147	137	110	69	113	78	81	42	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+1.24	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+301	+198
(47) Regional (68 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+180	N/A

Nomenclature: See separate page