

LIVINGSTON COUNTY AP, MI, USA

WMO: 725378

Lat: 42.629N

Lon: 83.984W

Elev: 944

StdP: 14.20

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 04887

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 0.5	(c) 5.2	(d) -7.8	(e) 3.7	(f) 3.3	(g) -2.4	(h) 5.0	(i) 7.8	(j) 24.4	(k) 26.4	(l) 21.0	(m) 29.0	(n) 5.5	(o) 230	(p) 0.506

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	21.0	90.2	72.0	87.6	71.0	84.1	69.5	75.6	84.3	73.9	82.3	72.3	80.3	9.1	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
72.9	126.4	79.8	71.9	121.9	78.7	70.0	114.3	76.8	39.7	84.7	38.1	82.0	36.6	80.1	86.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 20.6	(b) 18.1	(c) 16.2	(e) -5.7	(f) 93.7	(g) 6.3	(h) 2.8	(i) -10.3	(j) 95.7	(k) -14.0	(l) 97.3	(m) -17.5	(n) 98.8	(o) -22.1	(p) 100.9		
(4) 20.6	(5) 18.1	(6) 16.2	(7) -5.7	(8) 93.7	(9) 6.3	(10) 2.8	(11) -10.3	(12) 95.7	(13) -14.0	(14) 97.3	(15) -17.5	(16) 98.8	(17) -22.1	(18) 100.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	49.1	24.7	26.5	35.3	47.4	58.6	68.0	71.8	70.0	63.5	51.6	40.2	29.9
	DBStd	18.94	11.17	10.91	11.16	9.24	8.54	6.87	5.73	5.54	7.71	8.75	9.19	9.60
	HDD50	3130	786	660	476	156	19	0	0	0	3	87	316	627
	HDD65	6470	1250	1079	922	533	237	46	10	18	119	424	743	1089
	CDD50	2792	1	1	21	76	285	541	676	620	408	137	23	3
	CDD65	656	0	0	1	4	39	136	221	172	74	9	0	0
	CDH74	5862	0	0	10	50	396	1254	2054	1375	644	78	1	0
	CDH80	1804	0	0	1	8	93	417	706	378	188	13	0	0
Wind	WSAvg	6.9	8.2	8.1	7.9	8.4	7.0	5.8	5.1	4.9	5.2	6.8	7.7	7.8
Precipitation	PrecAvg	33.3	2.2	1.9	2.1	2.7	3.5	3.7	3.3	3.1	3.1	2.8	2.4	2.2
	PrecMax	41.1	4.0	3.6	3.9	5.7	7.5	6.5	6.5	6.1	9.3	7.3	4.4	3.9
	PrecMin	24.0	0.7	0.8	0.7	0.4	1.1	1.3	1.5	0.7	0.6	0.3	1.1	0.9
	PrecStd	4.4	1.1	0.9	0.9	1.0	1.7	1.4	1.5	1.3	2.0	1.5	1.0	0.8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	55.4	58.9	73.4	80.5	87.8	91.3	93.5	91.1	90.1	81.7	68.4	59.4
		MCWB	52.0	51.4	59.0	61.5	68.3	72.7	73.7	72.1	70.6	68.2	56.6	56.5
	2%	DB	49.9	52.2	65.3	73.2	82.2	88.9	90.4	87.7	85.5	75.3	63.0	53.7
		MCWB	46.7	46.9	56.1	56.9	65.9	71.0	72.9	71.5	69.4	62.9	54.4	49.8
	5%	DB	44.7	45.6	58.5	68.6	78.9	84.9	87.6	83.9	81.3	71.5	58.9	46.9
		MCWB	41.6	40.7	50.8	54.9	64.4	69.1	71.8	70.2	67.3	61.4	52.4	43.6
	10%	DB	38.9	40.5	52.5	63.8	73.9	81.4	83.9	81.4	77.2	66.2	54.6	42.5
		MCWB	36.3	36.5	45.9	52.1	62.1	67.6	69.9	68.5	65.5	58.4	48.7	39.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	53.4	54.4	61.6	65.7	71.9	76.2	78.9	76.9	74.9	70.6	60.6	56.9
		MCDB	55.2	57.1	71.4	76.0	81.1	87.3	87.1	86.7	84.3	79.1	65.5	59.7
	2%	WB	47.1	47.2	56.9	60.7	69.1	73.6	76.4	75.0	72.4	66.6	57.0	50.0
		MCDB	48.7	50.5	63.4	68.8	77.9	83.4	84.9	82.7	79.9	72.1	61.1	52.3
	5%	WB	41.2	41.0	52.2	57.3	66.9	72.0	74.3	73.1	70.1	62.8	53.2	44.0
		MCDB	44.3	45.2	57.8	66.3	75.2	81.3	82.7	79.9	76.7	68.4	58.0	46.5
	10%	WB	36.7	36.8	46.1	53.7	64.0	70.0	72.4	71.2	67.9	59.4	49.1	39.2
		MCDB	39.0	40.5	51.1	62.5	71.6	78.0	80.6	77.7	75.0	64.8	54.4	42.1
Mean Daily Temperature Range	5% DB	MDBR	13.0	14.5	17.1	20.2	20.5	20.2	21.0	19.7	20.7	18.2	14.5	11.7
		MCDBR	16.5	19.3	24.9	26.8	24.3	23.8	23.5	22.2	24.4	24.2	20.3	16.6
		MCWBR	14.3	15.0	16.5	15.1	12.1	10.3	9.9	9.4	10.8	13.5	14.1	13.7
	5% WB	MCDBR	15.9	18.2	22.8	23.3	21.1	20.4	19.7	18.2	20.1	20.5	18.6	15.5
		MCWBR	14.8	15.2	16.4	16.0	12.5	10.8	10.4	9.5	10.7	13.8	15.0	14.0
Clear-Sky Solar Irradiance	taub	0.295	0.333	0.343	0.386	0.413	0.435	0.425	0.418	0.380	0.346	0.315	0.298	
	taud	2.372	2.241	2.357	2.258	2.236	2.205	2.248	2.259	2.353	2.442	2.481	2.412	
	Ebn at Noon	267	272	285	279	274	267	268	266	269	266	260	256	
	Edh at Noon	25	34	35	41	43	45	43	41	35	28	23	23	
All-Sky Solar Radiation	RadAvg	474	753	1131	1453	1694	1912	1935	1662	1339	862	535	373	
	RadStd	42	95	116	116	131	152	119	91	70	124	81	69	33

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
	N/A	N/A	N/A	N/A	N/A	-0.97	N/A	N/A	N/A	N/A
Regional (62 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page