

JACKSON COUNTY AP, MI, USA

WMO: 725395

Lat: 42.267N

Lon: 84.467W

Elev: 304

StdP: 97.72

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 14833

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-18.0	-15.2	-22.2	0.5	-17.1	-19.2	0.7	-14.0	10.7	-3.7	9.3	-3.3	3.0	230	0.532

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.4	31.6	22.9	30.0	22.1	28.6	21.3	24.5	29.3	23.6	28.0	22.7	26.8	4.3	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.0	18.4	27.0	22.2	17.5	26.2	21.2	16.5	25.3	75.5	29.3	71.7	28.0	68.1	26.9	28.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.2	8.3	7.6	DB	-22.3	34.0	3.4	1.4	-24.8	35.0	-26.8	35.9	-28.7	36.7	-31.2	37.7	(4)
(5)			WB	-22.6	26.3	3.4	1.0	-25.0	27.1	-27.0	27.7	-28.9	28.3	-31.3	29.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	9.3	-4.5	-3.2	1.9	8.7	14.7	19.9	21.8	20.9	17.2	10.7	4.3	-1.3	(6)	
	DBStd	10.55	6.49	6.15	6.14	5.14	4.72	3.76	3.15	3.00	4.22	4.84	5.23	5.47	(7)	
	HDD10.0	1770	451	371	263	84	11	0	0	0	2	51	184	353	(8)	
	HDD18.3	3632	708	603	510	292	133	26	6	10	71	242	422	609	(9)	
	CDD10.0	1521	1	1	11	44	157	298	367	338	217	72	12	2	(10)	
	CDD18.3	343	0	0	1	2	21	74	115	91	36	4	0	0	(11)	
	CDH23.3	2989	0	0	6	26	212	667	1048	689	306	36	0	0	(12)	
	CDH26.7	833	0	0	1	2	48	202	331	168	78	4	0	0	(13)	
(14) Wind	WSAvg	3.5	4.2	4.2	4.0	4.2	3.5	2.9	2.7	2.5	2.7	3.4	3.9	4.0	(14)	
(15) Precipitation	PrecAvg	776	35	32	55	71	85	88	85	80	77	56	62	52	(15)	
	PrecMax	985	78	75	133	138	184	174	165	236	208	173	140	109	(16)	
	PrecMin	505	8	2	8	8	29	12	16	6	11	8	16	10	(17)	
	PrecStd	105	21	20	29	29	40	39	42	45	46	37	28	24	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.6	15.3	23.7	26.5	30.2	32.9	33.9	32.4	31.4	27.1	20.5	15.8	(19)	
		MCWB	11.7	11.6	16.6	16.8	20.3	23.4	24.4	23.9	21.9	20.4	14.0	13.6	(20)	
	2%	DB	10.3	11.6	18.8	23.2	27.8	30.9	31.7	30.1	28.9	23.8	17.0	12.0	(21)	
		MCWB	8.9	8.5	13.3	15.0	19.2	22.1	23.6	22.8	20.9	17.3	12.8	9.3	(22)	
	5%	DB	7.1	7.9	15.0	20.7	25.9	29.1	30.0	28.5	26.8	21.2	14.9	8.7	(23)	
		MCWB	5.2	4.9	10.4	13.2	18.3	21.1	22.4	21.7	20.0	16.2	11.6	6.3	(24)	
	10%	DB	3.9	4.9	11.8	18.0	23.4	27.3	28.4	27.1	24.8	19.0	12.5	5.8	(25)	
		MCWB	2.5	2.7	8.0	11.7	17.1	20.4	21.5	20.9	18.8	14.8	9.3	3.9	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	12.2	12.9	16.9	18.6	22.3	24.7	26.2	25.5	24.0	21.5	15.8	13.8	(27)	
		MCDB	13.4	14.5	23.0	24.7	27.7	30.7	31.4	30.3	29.0	26.1	18.5	15.5	(28)	
	2%	WB	9.1	8.8	13.9	16.4	20.7	23.5	24.9	24.1	22.5	19.1	13.9	10.0	(29)	
		MCDB	10.1	10.6	17.7	20.4	25.9	29.0	29.7	28.1	26.6	22.0	16.1	11.4	(30)	
	5%	WB	5.3	5.1	11.3	14.4	19.5	22.4	23.8	23.1	21.2	17.0	11.9	6.5	(31)	
		MCDB	6.7	7.4	14.4	19.3	24.1	27.4	28.2	26.6	24.7	20.1	14.6	8.2	(32)	
	10%	WB	2.5	2.8	7.8	12.5	18.0	21.4	22.7	22.1	20.0	15.2	9.6	3.9	(33)	
		MCDB	3.8	5.0	11.2	17.4	22.3	25.7	26.9	25.5	23.4	18.5	12.2	5.5	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	7.4	8.3	9.8	11.4	11.5	11.2	11.4	10.8	11.4	10.3	8.3	6.6	(35)	
		MCDBR	9.4	11.0	14.0	14.7	13.7	12.8	12.6	11.9	13.0	13.1	11.0	9.8	(36)	
	5% WB	MCWBR	8.3	8.8	9.4	8.4	7.2	6.0	5.9	5.7	6.3	7.7	8.0	8.0	(37)	
		MCWBR	9.4	10.5	12.6	12.7	11.8	10.8	10.8	9.6	10.7	11.3	10.4	8.9	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.297	0.347	0.348	0.392	0.423	0.443	0.432	0.427	0.383	0.347	0.315	0.301	(40)	
		taud	2.375	2.189	2.342	2.240	2.202	2.184	2.223	2.232	2.338	2.435	2.476	2.405	(41)	
	Ebn at Noon		845	839	895	875	854	835	840	832	846	839	821	806	(42)	
		Edh at Noon	80	114	111	133	142	145	138	132	111	89	73	72	(43)	
(44) All-Sky Solar Radiation	RadAvg		1.49	2.39	3.57	4.58	5.34	6.02	6.11	5.26	4.26	2.75	1.73	1.20	(44)	
	RadStd		0.14	0.31	0.35	0.42	0.49	0.38	0.29	0.24	0.39	0.26	0.23	0.12	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (65 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page