

OELWEIN, IA, USA

WMO: 725488

Lat: 42.681N

Lon: 91.974W

Elev: 328

StdP: 97.45

Time Zone: -6.00 (NAC)

Period: 95-19

WBAN: 04955

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-22.4	-19.9	-27.1	0.3	-22.6	-23.9	0.5	-19.9	14.2	-8.4	12.5	-8.0	3.9	320	0.571

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.4	32.4	24.3	31.0	23.6	29.1	22.6	26.4	30.1	25.2	28.8	24.0	27.7	5.4	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.2	21.1	28.7	23.9	19.5	27.6	22.7	18.1	26.5	83.9	29.7	78.8	28.2	73.8	28.0	33.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.1	10.9	9.3	DB	-26.8	33.5	3.0	1.8	-29.0	34.8	-30.7	35.8	-32.4	36.8	-34.6	38.1	(4)
(5)			WB	-26.4	27.8	2.8	2.1	-28.4	29.3	-30.0	30.6	-31.5	31.7	-33.5	33.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	8.9	-6.9	-5.4	1.9	9.2	15.7	21.0	22.3	21.1	18.0	10.1	2.6	-3.9	(6)	
	DBStd	11.74	6.98	6.92	6.62	5.40	4.82	3.52	3.12	3.02	4.40	5.36	5.98	6.51	(7)	
	HDD10.0	2029	524	432	262	77	7	0	0	0	2	66	230	431	(8)	
	HDD18.3	3847	782	664	509	276	110	14	5	9	59	259	471	688	(9)	
	CDD10.0	1626	0	1	11	53	185	329	380	344	242	69	9	1	(10)	
	CDD18.3	402	0	0	1	3	29	93	127	94	49	5	0	0	(11)	
	CDH23.3	3584	0	0	4	52	303	848	1123	740	453	51	1	8	(12)	
	CDH26.7	1099	0	0	0	12	94	289	359	194	135	11	0	6	(13)	
(14) Wind	WSAvg	4.4	4.9	4.9	5.1	5.4	5.0	4.1	3.1	2.7	3.4	4.3	4.8	4.8	(14)	
(15) Precipitation	PrecAvg	955	30	34	53	87	128	149	121	117	72	58	63	34	(15)	
	PrecMax	1186	59	87	135	209	288	231	268	239	146	146	135	88	(16)	
	PrecMin	766	6	5	3	29	34	28	26	7	11	13	10	9	(17)	
	PrecStd	138	14	20	38	41	57	50	64	58	35	36	38	20	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.1	14.0	22.9	28.0	32.7	34.1	33.8	33.0	32.4	27.8	22.0	17.1	(19)	
		MCWB	5.7	10.3	15.1	17.8	21.7	23.0	26.5	26.7	22.7	19.0	14.0	14.6	(20)	
	2%	DB	6.1	9.0	17.8	24.1	29.1	32.0	32.2	30.8	30.1	24.0	17.5	9.1	(21)	
		MCWB	4.0	7.1	12.8	15.2	19.1	22.8	25.9	24.9	22.2	17.0	12.5	7.2	(22)	
	5%	DB	3.0	5.9	14.8	21.3	27.1	30.0	30.1	28.8	27.8	22.0	14.1	7.0	(23)	
		MCWB	1.8	3.9	11.1	13.5	18.0	21.6	24.6	24.0	21.2	16.2	10.5	5.2	(24)	
	10%	DB	2.0	2.9	11.1	18.2	24.1	27.8	28.7	27.4	26.2	18.8	12.0	3.7	(25)	
		MCWB	1.1	1.7	8.1	12.0	17.0	20.7	23.8	22.5	19.7	14.6	8.8	2.2	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.5	10.8	16.4	18.6	23.4	26.7	28.7	28.0	25.3	21.6	15.6	14.5	(27)	
		MCDB	9.9	13.6	22.2	26.2	29.7	31.0	32.5	31.2	29.6	24.7	19.8	16.4	(28)	
	2%	WB	4.0	7.1	13.8	16.4	21.4	24.9	26.8	25.9	23.9	19.1	13.3	7.6	(29)	
		MCDB	5.8	8.9	16.9	22.3	27.0	29.1	30.2	29.6	27.9	22.8	16.2	8.5	(30)	
	5%	WB	2.3	4.0	11.2	14.8	20.0	23.6	25.4	24.6	22.7	17.1	10.9	4.9	(31)	
		MCDB	3.4	5.6	14.3	19.9	24.6	27.8	28.7	27.9	26.4	20.3	14.1	6.8	(32)	
	10%	WB	0.8	2.0	7.9	12.8	18.4	22.2	24.1	23.3	21.2	14.7	8.4	2.5	(33)	
		MCDB	1.6	3.3	10.6	17.8	22.9	26.5	28.0	26.3	24.5	18.1	11.0	3.6	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	8.4	8.6	9.1	11.3	11.2	10.5	10.4	10.4	12.4	11.1	9.4	8.1	(35)	
		MCDBR	9.6	10.2	14.3	16.4	14.1	12.8	11.2	11.6	13.8	14.5	13.9	11.1	(36)	
	5% WB	MCWBR	8.0	8.1	9.2	9.1	6.6	6.3	6.8	7.2	7.5	8.2	9.4	9.2	(37)	
		MCWBR	9.3	9.8	13.4	14.2	12.0	10.8	10.1	10.3	11.3	12.5	12.8	10.6	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.278	0.302	0.329	0.370	0.399	0.415	0.429	0.409	0.379	0.335	0.296	0.276	(40)	
		taud	2.381	2.319	2.373	2.296	2.277	2.272	2.222	2.286	2.339	2.456	2.489	2.421	(41)	
	Ebn at Noon		867	897	915	897	875	859	842	848	849	851	843	837	(42)	
		Edh at Noon	78	99	107	125	131	132	138	125	110	86	71	69	(43)	
(44) All-Sky Solar Radiation	RadAvg		1.82	2.85	3.81	4.64	5.52	6.10	6.19	5.37	4.43	2.88	1.93	1.43	(44)	
	RadStd		0.18	0.27	0.40	0.41	0.39	0.51	0.36	0.35	0.33	0.37	0.15	0.12	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (52 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page