

AURORA, NE, USA

WMO: 725513

Lat: 40.893N

Lon: 97.997W

Elev: 548

StdP: 94.91

Time Zone: -6.00 (NAC)

Period: 98-19

WBAN: 04901

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-18.7	-16.2	-22.9	0.5	-17.8	-20.4	0.7	-15.1	15.7	-1.5	14.5	-3.7	4.3	330	0.602

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.2	34.0	23.2	32.6	22.8	31.2	22.4	25.6	30.8	24.7	29.9	23.8	28.9	5.6	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.0	20.3	28.5	22.9	18.9	27.5	22.3	18.2	26.9	82.5	30.8	77.8	30.2	74.1	28.7	29.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 13.4	11.7	10.4	DB	-23.6	37.1	2.0	1.4	-25.0	38.1	-26.2	39.0	-27.3	39.8	-28.7	40.8	(4)
(5)			WB	-23.9	27.7	1.9	0.9	-25.3	28.3	-26.4	28.9	-27.5	29.4	-28.8	30.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	10.7	-3.3	-2.0	4.7	10.4	16.5	21.8	24.1	22.7	18.7	11.4	4.4	-2.1	(6)	
	DBStd	11.07	6.48	6.79	6.20	5.39	4.88	3.82	3.11	3.06	4.51	5.18	5.76	6.14	(7)	
	HDD10.0	1603	412	338	186	58	7	0	0	0	1	45	182	375	(8)	
	HDD18.3	3338	670	571	423	241	95	12	2	3	49	221	418	633	(9)	
	CDD10.0	1851	0	1	21	72	207	354	437	393	264	88	14	0	(10)	
	CDD18.3	546	0	0	1	5	37	117	181	138	62	6	0	0	(11)	
	CDH23.3	5469	0	0	18	91	430	1193	1778	1214	649	91	5	0	(12)	
	CDH26.7	2086	0	0	3	24	144	462	740	454	234	23	1	0	(13)	
(14) Wind	WSAvg	4.8	5.0	5.2	5.5	6.1	5.5	4.7	3.5	3.3	4.0	4.6	5.0	5.0	(14)	
(15) Precipitation	PrecAvg	704	15	19	36	63	116	113	92	87	59	53	33	20	(15)	
	PrecMax	969	39	44	81	112	217	195	212	206	122	173	100	71	(16)	
	PrecMin	414	2	1	0	8	35	38	31	27	10	1	0	0	(17)	
	PrecStd	127	10	11	23	26	48	46	49	44	34	45	24	16	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	16.2	19.1	25.8	29.8	33.0	35.4	36.2	35.9	33.9	30.0	23.3	15.6	(19)	
		MCWB	7.2	9.8	14.1	16.8	18.6	22.1	24.4	23.0	21.2	18.2	12.8	7.4	(20)	
	2%	DB	11.0	14.1	21.9	26.0	30.2	33.0	34.0	32.8	31.9	25.9	19.8	12.0	(21)	
		MCWB	5.2	7.6	12.5	15.0	18.7	22.1	24.6	23.3	20.9	15.4	11.1	7.0	(22)	
	5%	DB	7.7	11.0	18.3	22.8	27.8	31.3	32.5	31.2	29.6	22.9	16.4	8.8	(23)	
		MCWB	3.5	6.4	11.3	13.7	17.8	21.8	24.2	23.4	20.2	14.3	9.9	4.7	(24)	
	10%	DB	5.0	7.3	15.1	20.1	25.6	29.4	31.0	29.1	27.3	20.5	13.3	6.2	(25)	
		MCWB	2.0	3.8	9.4	12.7	16.8	20.9	23.6	22.6	18.8	13.5	8.0	2.8	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.7	11.5	16.7	18.2	22.0	25.3	27.3	26.5	23.8	20.2	14.9	10.7	(27)	
		MCDB	14.3	15.2	20.9	25.4	28.1	30.9	32.3	30.8	28.9	25.7	19.2	14.2	(28)	
	2%	WB	5.5	8.4	14.8	16.5	20.6	24.0	26.1	25.3	22.6	17.8	12.6	6.8	(29)	
		MCDB	10.3	14.1	19.0	22.0	27.0	30.0	31.5	30.4	28.4	22.0	17.8	11.3	(30)	
	5%	WB	3.8	6.0	12.0	15.1	19.5	23.0	25.1	24.2	21.6	16.0	10.5	4.9	(31)	
		MCDB	7.4	10.6	17.1	21.4	25.5	29.0	30.4	29.3	27.1	20.3	15.6	8.5	(32)	
	10%	WB	2.2	3.9	9.6	13.4	18.2	21.9	24.2	23.3	20.4	14.3	8.4	3.0	(33)	
		MCDB	4.9	7.3	15.2	19.5	23.6	27.8	29.3	27.9	25.4	19.3	13.7	5.9	(34)	
(35) Mean Daily Temperature Range	MDBR		10.6	10.9	12.3	12.9	12.2	11.8	11.2	11.3	13.2	12.9	12.4	10.5	(35)	
	5% DB	MCDBR	14.8	16.3	18.1	17.7	15.6	14.0	13.1	13.5	15.1	16.9	17.1	14.8	(36)	
		MCWBR	9.9	10.3	10.0	9.1	6.6	5.9	6.4	6.2	6.4	8.3	9.9	10.1	(37)	
	5% WB	MCDBR	13.8	15.6	15.9	15.1	13.3	12.4	11.6	11.8	12.9	12.7	15.4	13.6	(38)	
		MCWBR	9.5	10.2	9.6	8.9	6.7	6.2	6.5	6.4	6.4	7.7	9.6	9.8	(39)	
(40) Clear-Sky Solar Irradiance	taub		0.275	0.282	0.310	0.347	0.372	0.385	0.401	0.399	0.364	0.323	0.283	0.273	(40)	
	taud		2.481	2.493	2.445	2.360	2.363	2.378	2.342	2.342	2.396	2.495	2.521	2.492	(41)	
	Ebn at Noon		896	943	945	925	904	889	870	863	873	879	879	870	(42)	
	Edh at Noon		75	86	101	118	121	120	123	120	106	85	71	68	(43)	
(44) All-Sky Solar Radiation	RadAvg		2.19	3.04	4.06	5.14	5.98	6.81	6.71	5.83	4.74	3.39	2.42	1.84	(44)	
	RadStd		0.20	0.21	0.34	0.29	0.38	0.42	0.34	0.34	0.30	0.34	0.17	0.18	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (30 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page