

OFFUTT AFB, NE, USA

WMO: 725540

Lat: 41.117N

Lon: 95.900W

Elev: 321

StdP: 97.53

Time Zone: -6.00 (NAC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-19.1	-16.9	-22.9	0.5	-17.9	-20.6	0.6	-15.7	13.9	-7.2	11.9	-4.5	3.4	320	0.539

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.8	35.0	24.7	33.1	24.4	31.9	23.7	26.7	32.0	25.7	30.9	24.9	29.8	4.9	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.2	21.2	29.8	24.2	19.9	28.8	23.3	18.8	27.9	85.8	32.0	81.4	30.9	77.4	29.9	34.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.1	9.4	8.4	DB	-23.7	37.6	2.4	1.9	-25.5	38.9	-26.9	40.0	-28.3	41.1	-30.0	42.5	(4)
(5)			WB	-23.9	28.6	2.5	1.4	-25.7	29.6	-27.1	30.5	-28.5	31.3	-30.3	32.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	11.1	-4.6	-1.9	4.8	11.0	17.3	22.7	25.2	23.8	19.6	12.3	4.5	-2.2	(6)	
	DBStd	11.60	6.57	6.87	6.47	5.47	4.70	3.61	3.27	3.16	4.53	5.17	5.54	6.13	(7)	
	HDD10.0	1622	453	335	186	51	3	0	0	0	1	35	179	379	(8)	
	HDD18.3	3297	712	566	422	225	78	7	1	2	39	195	416	636	(9)	
	CDD10.0	2028	0	3	24	83	228	382	471	428	288	108	14	1	(10)	
	CDD18.3	660	0	0	1	7	45	138	213	171	76	9	0	0	(11)	
	CDH23.3	6672	0	2	17	104	466	1398	2270	1588	722	100	4	0	(12)	
(13)	CDH26.7	2633	0	1	2	28	154	544	1002	628	249	23	1	0	(13)	
(14)	Wind	WSAvg	3.8	3.9	4.0	4.4	4.6	4.0	3.6	3.1	3.1	3.4	3.7	3.9	3.8	(14)
(15) Precipitation	PrecAvg	845	21	27	47	86	128	135	103	119	71	53	35	25	(15)	
	PrecMax	1230	42	69	122	188	245	278	306	293	172	157	79	128	(16)	
	PrecMin	573	4	6	2	14	41	45	5	37	13	1	0	0	(17)	
	PrecStd	159	11	16	30	36	56	65	69	71	41	39	22	25	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.9	19.7	25.9	30.1	33.9	35.2	37.7	36.6	33.9	29.8	22.9	15.5	(19)	
		MCWB	7.2	11.7	15.5	17.9	21.3	23.9	25.0	24.5	22.8	19.5	14.7	10.7	(20)	
	2%	DB	10.0	14.8	22.1	26.3	30.3	33.1	35.2	34.0	32.0	26.1	19.1	12.1	(21)	
		MCWB	5.8	9.2	13.5	16.4	20.6	23.8	25.7	24.6	22.6	17.6	12.6	8.0	(22)	
	5%	DB	7.0	10.9	18.6	23.3	28.0	31.8	33.6	32.1	29.7	23.3	16.1	9.0	(23)	
		MCWB	3.9	6.6	12.3	14.7	19.4	23.1	25.3	24.5	22.0	16.0	11.0	5.8	(24)	
	10%	DB	4.1	7.6	15.3	20.8	25.9	30.0	31.9	30.1	27.6	21.1	13.3	6.3	(25)	
		MCWB	2.1	4.7	9.8	13.4	18.4	22.2	24.6	23.3	20.5	15.3	9.2	3.6	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.3	13.9	17.9	19.8	23.8	26.8	28.4	27.3	25.2	21.8	16.4	12.8	(27)	
		MCDB	12.5	16.5	22.4	26.1	29.1	32.0	34.0	32.0	30.4	25.9	20.2	14.7	(28)	
	2%	WB	6.1	9.6	15.4	17.8	22.3	25.4	27.2	26.3	24.0	19.7	14.1	8.5	(29)	
		MCDB	9.4	14.2	19.7	23.4	27.8	30.7	32.5	31.6	29.2	23.4	18.1	10.9	(30)	
	5%	WB	4.1	6.8	12.7	16.0	21.0	24.3	26.2	25.3	23.0	17.9	12.0	5.8	(31)	
		MCDB	6.6	10.4	17.8	21.7	26.3	29.7	31.5	30.1	27.9	21.4	15.4	8.7	(32)	
	10%	WB	2.4	4.8	10.2	14.2	19.5	23.4	25.2	24.3	21.9	16.1	9.5	3.9	(33)	
		MCDB	4.2	7.6	15.2	19.6	24.4	28.4	30.2	28.7	26.3	19.8	13.1	6.1	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	10.2	10.5	12.1	12.3	11.5	11.1	10.8	10.8	12.3	12.0	11.1	9.7	(35)	
		MCDBR	14.7	15.3	18.2	17.2	14.7	12.9	12.8	13.0	13.8	15.4	15.5	14.3	(36)	
	5% WB	MCWBR	10.7	10.0	10.6	9.2	6.8	5.8	5.4	5.5	6.3	8.1	9.5	10.2	(37)	
		MCWBR	13.5	14.4	15.5	14.3	12.5	11.2	11.0	10.9	11.6	12.2	13.8	12.9	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.281	0.317	0.330	0.385	0.411	0.415	0.426	0.417	0.376	0.333	0.299	0.285	(40)	
		taud	2.459	2.372	2.400	2.263	2.262	2.303	2.266	2.303	2.371	2.478	2.501	2.457	(41)	
	Ebn at Noon		885	892	921	885	868	861	847	845	859	865	855	847	(42)	
		Edh at Noon	76	97	106	130	134	129	133	124	108	87	73	70	(43)	
(44) All-Sky Solar Radiation	RadAvg		2.03	2.96	3.84	4.89	5.80	6.45	6.49	5.62	4.64	3.25	2.27	1.71	(44)	
	RadStd		0.17	0.18	0.35	0.34	0.45	0.50	0.43	0.35	0.30	0.38	0.16	0.17	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (41 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page