

CONVERSE COUNTY AP, WY, USA

WMO: 725686

Lat: 42.796N

Lon: 105.380W

Elev: 4936

StdP: 12.26

Time Zone: -7.00 (NAM)

Period: 99-19

WBAN: 94057

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 12	(b) -8.5	(c) -1.9	(d) -14.9	(e) 2.9	(f) -8.6	(g) -8.0	(h) 4.3	(i) -1.1	(j) 34.3	(k) 43.8	(l) 31.6	(m) 43.3	(n) 3.3	(o) 310	(p) 0.690

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	32.2	95.3	60.5	92.5	60.5	89.8	60.2	65.2	83.9	63.8	82.4	62.4	81.4	12.4	290

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
60.4	94.4	69.5	58.1	86.7	68.2	56.3	81.3	67.5	32.7	83.5	31.5	81.4	30.5	80.9	71.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 30.7	(b) 26.6	(c) 23.8	(e) -19.8	(f) 99.9	(g) 7.8	(h) 2.2	(i) -25.4	(j) 101.4	(k) -30.0	(l) 102.7	(m) -34.4	(n) 103.9	(o) -40.0	(p) 105.5		
(a) 30.7	(b) 26.6	(c) 23.8	(e) -19.0	(f) 68.3	(g) 7.8	(h) 1.7	(i) -24.6	(j) 69.5	(k) -29.1	(l) 70.5	(m) -33.5	(n) 71.5	(o) -39.1	(p) 72.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	46.7	26.3	26.1	37.0	43.8	52.7	63.9	72.7	70.0	60.2	45.9	35.0	25.5
	DBStd	19.01	11.38	12.24	10.60	8.73	8.47	7.02	5.31	5.75	7.85	9.67	11.21	12.00
	HDD50	3531	734	671	415	218	71	2	0	0	13	187	459	761
	HDD65	7212	1198	1089	869	637	386	102	9	22	181	593	901	1225
	CDD50	2329	0	1	11	31	156	418	705	621	319	58	8	1
	CDD65	538	0	0	0	0	6	68	249	178	37	0	0	0
	CDH74	9070	0	0	4	23	268	1335	3621	2744	1005	70	0	0
	CDH80	4271	0	0	0	1	66	575	1908	1325	386	10	0	0
(14) Wind	WSAvg	9.8	9.7	10.0	10.9	11.6	10.8	9.8	8.9	8.9	8.7	9.6	9.4	9.6
(15) Precipitation	PrecAvg	13.8	0.4	0.6	0.9	1.8	2.5	2.1	1.5	1.0	1.1	1.3	0.6	0.4
	PrecMax	20.7	1.0	1.8	2.7	4.3	7.0	4.5	3.2	2.2	3.0	5.5	1.0	1.0
	PrecMin	9.3	0.1	0.0	0.2	0.4	0.9	0.5	0.3	0.2	0.1	0.1	0.0	0.0
	PrecStd	2.8	0.2	0.4	0.6	1.0	1.7	1.2	0.8	0.6	0.7	1.2	0.3	0.2
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	57.5	60.7	72.6	77.1	86.9	96.7	99.9	97.0	91.9	81.1	70.5	57.3
		MCWB	40.0	43.9	48.3	51.0	57.0	58.9	62.6	61.8	59.1	53.2	47.2	41.4
	2%	DB	52.3	54.7	66.0	72.4	81.2	91.3	96.8	94.0	88.4	75.2	64.2	52.2
		MCWB	38.5	40.7	45.6	49.2	56.5	59.7	61.8	60.2	57.5	51.1	44.8	38.9
	5%	DB	47.9	49.7	61.0	67.9	76.2	86.9	93.3	91.1	84.7	70.4	59.4	47.9
		MCWB	37.0	38.0	43.4	47.6	55.3	59.4	61.2	59.9	56.1	49.5	42.8	36.7
	10%	DB	44.1	45.1	55.6	62.7	71.3	81.9	90.6	88.2	80.3	64.3	54.3	43.8
		MCWB	34.8	35.4	41.4	45.9	53.3	58.6	61.2	59.5	54.7	47.5	40.5	34.6
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	42.2	44.3	49.5	53.2	62.3	66.1	67.9	65.8	62.4	55.3	48.6	42.1
		MCDB	54.5	58.6	69.3	71.9	79.5	82.0	86.1	85.4	83.8	72.9	66.7	55.7
	2%	WB	39.4	41.1	46.6	50.6	58.9	63.4	65.8	64.2	59.9	52.9	45.8	39.5
		MCDB	50.3	53.5	63.3	67.8	73.9	80.3	84.8	83.3	79.9	70.7	63.6	51.0
	5%	WB	37.2	38.6	44.2	48.6	56.7	61.7	64.4	62.7	58.3	50.7	43.4	37.1
		MCDB	47.0	49.1	59.3	65.1	71.4	79.6	83.3	81.9	77.2	67.7	58.2	47.0
	10%	WB	35.0	35.6	41.9	46.6	54.5	60.0	63.2	61.5	56.6	48.4	41.0	34.8
		MCDB	43.6	44.4	55.0	60.7	68.6	77.3	82.0	81.0	74.5	63.1	53.7	43.5
(35) Mean Daily Temperature Range	5% DB	MDBR	24.1	23.5	25.7	25.9	26.3	30.1	32.2	32.0	32.0	28.1	26.7	23.4
		MCDBR	28.4	28.5	34.3	37.7	35.8	38.2	37.1	37.2	39.8	39.0	35.4	27.4
		MCWBR	17.1	16.9	17.5	17.8	15.0	13.5	11.3	11.4	14.8	18.5	19.0	16.6
		MCDBR	26.4	27.1	32.7	33.3	31.4	32.9	30.9	31.2	32.9	34.7	33.8	26.0
	5% WB	MCWBR	16.6	16.6	17.1	16.7	14.6	13.6	10.8	10.3	13.0	16.9	18.5	16.4
(40) Clear-Sky Solar Irradiance	taub		0.240	0.249	0.271	0.295	0.313	0.322	0.348	0.343	0.308	0.275	0.254	0.243
	taud		2.581	2.555	2.532	2.484	2.499	2.482	2.440	2.435	2.524	2.595	2.565	2.557
	Ebn at Noon		298	310	312	310	305	300	291	290	295	295	288	285
	Edh at Noon		20	25	29	33	33	34	35	34	29	23	20	19
(44) All-Sky Solar Radiation	RadAvg		663	935	1335	1658	1936	2309	2278	1973	1591	1071	715	541
	RadStd		33	56	103	106	166	140	88	60	107	88	53	31

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (10 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page