

RIFLE GARFIELD COUNTY AP, CO, USA

WMO: 725717

Lat: 39.528N

Lon: 107.720W

Elev: 1683

StdP: 82.67

Time Zone: -7.00 (NAM)

Period: 97-19

WBAN: 03016

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-17.9	-14.8	-21.7	0.7	-15.5	-18.9	0.9	-11.0	9.4	1.0	8.1	-0.2	1.0	190	0.578

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.7	35.1	14.9	33.7	14.7	32.4	14.4	17.3	27.8	16.7	27.1	16.2	26.5	4.8	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
15.1	13.2	18.5	13.9	12.2	18.6	12.8	11.3	19.0	54.8	27.3	53.0	26.9	51.1	26.5	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.5	8.8	7.6	DB	-22.7	37.6	2.7	0.8	-24.7	38.2	-26.3	38.7	-27.8	39.1	-29.8	39.8	(4)
(5)			WB	-23.0	18.6	2.6	0.6	-24.9	19.0	-26.5	19.4	-28.0	19.7	-29.9	20.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	9.5	-3.6	-0.3	5.0	8.7	13.8	19.7	23.3	21.6	17.1	9.7	2.7	-3.8	(6)	
	DBStd	10.03	4.53	4.36	4.06	3.79	3.93	3.28	2.07	2.01	3.32	4.03	4.44	4.79	(7)	
	HDD10.0	1652	422	288	161	68	13	0	0	0	2	53	219	427	(8)	
	HDD18.3	3556	681	522	414	290	147	24	0	2	58	267	468	685	(9)	
	CDD10.0	1486	0	0	5	28	130	290	413	359	215	44	1	0	(10)	
	CDD18.3	349	0	0	0	0	6	64	155	103	21	0	0	0	(11)	
	CDH23.3	5942	0	0	1	16	311	1445	2132	1440	564	34	0	0	(12)	
	CDH26.7	2774	0	0	0	2	80	698	1147	661	183	3	0	0	(13)	
(14) Wind	WSAvg	2.3	1.4	1.9	2.6	3.2	3.1	3.1	2.6	2.4	2.4	2.2	1.8	1.5	(14)	
(15) Precipitation	PrecAvg	302	22	19	24	24	27	24	24	27	29	33	25	29	(15)	
	PrecMax	553	67	56	77	66	82	94	67	66	84	92	91	82	(16)	
	PrecMin	174	0	1	3	2	0	0	0	2	2	4	0	0	(17)	
	PrecStd	90	15	15	17	16	20	24	20	16	23	25	18	22	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.1	14.2	22.4	25.4	32.1	36.1	37.4	35.3	32.8	27.0	19.0	11.1	(19)	
		MCWB	2.7	5.7	8.4	9.7	13.1	14.7	16.1	15.2	14.7	11.2	7.8	4.2	(20)	
	2%	DB	6.9	11.2	19.0	22.8	28.6	34.1	35.9	33.7	30.6	23.8	16.3	7.4	(21)	
		MCWB	1.8	3.9	7.1	8.7	11.8	13.8	15.4	14.8	13.5	10.3	6.4	1.9	(22)	
	5%	DB	4.2	8.5	17.0	21.2	27.0	32.7	34.1	32.4	28.8	21.5	13.7	5.0	(23)	
		MCWB	0.5	2.8	6.1	7.9	11.1	13.4	15.2	14.6	12.8	9.5	5.4	0.8	(24)	
	10%	DB	2.7	6.5	14.0	18.7	24.6	31.1	32.8	30.9	27.1	18.9	10.9	2.7	(25)	
		MCWB	0.0	1.8	4.9	7.3	10.3	13.1	15.1	14.7	12.5	8.5	4.3	-0.3	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	4.0	6.2	9.0	10.6	14.5	16.2	18.2	17.9	16.3	13.0	8.6	4.9	(27)	
		MCDB	7.5	11.6	20.3	23.0	28.9	29.5	28.2	27.8	27.1	21.2	17.1	9.9	(28)	
	2%	WB	2.6	4.6	7.7	9.5	12.8	15.3	17.5	17.1	15.3	11.7	7.0	2.7	(29)	
		MCDB	5.2	9.8	17.8	20.3	24.7	29.6	28.3	27.0	24.4	19.9	14.5	6.0	(30)	
	5%	WB	1.4	3.3	6.5	8.6	11.8	14.6	17.0	16.6	14.6	10.6	5.9	1.3	(31)	
		MCDB	3.9	7.7	15.4	18.9	23.9	28.9	27.7	26.1	23.4	19.0	12.5	4.3	(32)	
	10%	WB	0.3	2.2	5.4	7.8	11.0	13.8	16.5	16.0	13.8	9.5	4.8	0.1	(33)	
		MCDB	2.6	5.8	13.2	17.3	22.7	27.9	27.2	25.4	22.5	17.6	10.5	2.7	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	11.8	11.8	14.8	15.4	17.3	20.0	18.7	17.8	17.9	16.2	13.8	11.5	(35)	
		MCDBR	12.3	14.3	19.6	20.9	21.7	22.8	21.3	21.1	21.5	20.5	18.4	13.4	(36)	
	5% WB	MCWBR	8.2	8.1	9.5	9.5	8.6	8.7	7.5	7.3	8.3	9.8	10.0	8.7	(37)	
		MCWBR	10.4	12.3	18.0	18.5	19.5	20.1	16.5	15.9	15.7	17.2	16.7	11.6	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.249	0.262	0.287	0.317	0.328	0.321	0.362	0.358	0.308	0.288	0.259	0.253	(40)	
		taud	2.509	2.488	2.476	2.428	2.460	2.481	2.410	2.417	2.561	2.584	2.593	2.508	(41)	
	Ebn at Noon		945	975	977	959	949	951	908	906	941	933	929	913	(42)	
		Edh at Noon	74	87	99	111	110	108	115	112	90	79	68	69	(43)	
(44) All-Sky Solar Radiation	RadAvg		2.42	3.21	4.62	5.66	6.44	7.71	6.96	6.04	5.26	3.79	2.64	2.04	(44)	
	RadStd		0.14	0.25	0.41	0.39	0.47	0.49	0.36	0.29	0.31	0.33	0.25	0.18	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (22 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page