

SALT LAKE CITY INTL, UT, USA

WMO: 725720

Lat: 40.778N

Lon: 111.969W

Elev: 1288

StdP: 86.78

Time Zone: -7.00 (NAM)

Period: 94-19

WBAN: 24127

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-11.5	-9.1	-15.6	1.1	-8.8	-13.4	1.4	-5.5	12.1	6.8	11.0	6.2	2.3	140	0.579

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.8	36.8	17.0	35.5	16.6	34.1	16.3	19.0	30.9	18.4	30.3	17.8	29.9	4.7	340

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
15.7	13.1	22.5	14.3	11.9	23.0	13.0	10.9	23.4	59.2	30.7	57.0	30.0	54.8	29.8	22.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.1	9.4	8.3	DB	-15.0	39.1	3.4	1.2	-17.5	40.0	-19.5	40.7	-21.4	41.4	-23.9	42.3	(4)
(5)			WB	-15.5	20.3	3.3	0.8	-17.8	20.9	-19.8	21.4	-21.7	21.9	-24.1	22.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	12.3	-0.5	2.2	7.1	10.5	15.8	21.8	27.2	25.8	19.9	12.0	5.2	-0.3	(6)	
	DBStd	10.40	4.63	4.62	4.37	4.36	4.72	4.74	2.79	2.87	4.49	4.54	4.80	4.60	(7)	
	HDD10.0	1216	326	221	111	47	7	1	0	0	1	29	154	319	(8)	
	HDD18.3	2961	584	453	348	239	108	22	0	1	36	202	393	576	(9)	
	CDD10.0	2047	0	2	22	61	186	356	532	489	298	92	12	1	(10)	
	CDD18.3	750	0	0	0	2	28	127	273	232	82	6	0	0	(11)	
	CDH23.3	9140	0	0	2	33	353	1621	3510	2688	869	64	0	0	(12)	
	CDH26.7	4546	0	0	0	4	110	778	1949	1366	327	12	0	0	(13)	
(14) Wind	WSAvg	3.7	2.9	3.4	3.9	4.1	3.9	4.0	4.0	4.1	3.8	3.5	3.2	3.1	(14)	
(15) Precipitation	PrecAvg	401	32	32	46	54	45	23	17	19	30	35	34	35	(15)	
	PrecMax	616	82	124	101	116	131	98	65	93	179	99	85	111	(16)	
	PrecMin	221	2	3	4	11	4	0	0	0	0	0	1	1	(17)	
	PrecStd	91	18	19	22	27	30	21	15	18	30	23	18	25	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.8	16.6	22.5	26.7	32.2	37.3	38.9	37.3	34.2	28.3	20.6	14.1	(19)	
		MCWB	6.2	7.5	10.1	12.3	14.2	17.0	17.5	17.5	16.4	13.7	9.2	6.9	(20)	
	2%	DB	9.8	13.8	19.8	23.7	29.6	35.2	37.5	35.7	32.1	25.1	17.4	11.3	(21)	
		MCWB	4.6	6.4	9.0	10.8	13.6	15.5	17.2	16.7	15.4	12.4	8.4	5.5	(22)	
	5%	DB	7.8	11.3	17.3	21.2	27.4	33.3	36.3	34.5	30.4	22.2	15.3	8.6	(23)	
		MCWB	3.8	5.6	8.0	9.9	13.0	15.3	17.0	16.4	14.9	11.4	7.3	4.1	(24)	
	10%	DB	5.8	9.1	15.0	18.8	24.9	31.4	34.8	33.2	28.4	19.9	12.9	6.2	(25)	
		MCWB	2.7	4.3	7.0	9.1	12.5	14.9	16.7	16.2	14.4	10.5	6.4	3.1	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.9	8.4	11.2	13.6	16.0	18.7	20.0	19.7	19.0	14.8	10.5	7.7	(27)	
		MCDB	11.0	14.1	20.0	24.6	28.4	33.9	31.7	31.2	29.5	24.4	17.8	12.7	(28)	
	2%	WB	5.3	6.9	9.8	11.7	14.9	17.3	19.1	18.8	17.5	13.5	9.1	6.0	(29)	
		MCDB	8.9	12.5	18.1	21.2	26.1	31.4	31.0	30.2	27.6	22.3	15.5	10.1	(30)	
	5%	WB	4.0	5.8	8.6	10.6	13.9	16.4	18.6	18.0	16.4	12.2	8.0	4.7	(31)	
		MCDB	7.3	10.6	16.3	19.4	24.4	29.7	30.6	29.8	26.1	20.4	13.9	8.3	(32)	
	10%	WB	2.8	4.7	7.5	9.6	13.0	15.6	18.0	17.5	15.4	11.0	6.9	3.3	(33)	
		MCDB	5.5	8.7	14.2	17.8	23.1	28.5	30.2	29.6	25.5	18.9	12.3	6.0	(34)	
(35) Mean Daily Temperature Range	MDBR		7.7	8.8	10.6	11.0	12.0	13.6	13.8	13.5	13.2	11.9	9.9	7.4	(35)	
	5% DB	MCDBR	10.0	11.3	13.8	14.7	15.2	15.8	15.3	14.8	15.0	14.6	13.0	9.6	(36)	
		MCWBR	6.0	6.0	6.6	6.3	5.4	5.3	4.8	4.8	5.3	6.0	6.3	5.5	(37)	
	5% WB	MCDBR	9.2	10.5	13.2	13.4	14.0	14.6	13.5	13.1	12.7	13.5	12.2	9.0	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.256	0.268	0.283	0.319	0.323	0.321	0.348	0.347	0.311	0.288	0.267	0.253	(40)	
	taud		2.474	2.513	2.546	2.436	2.485	2.527	2.476	2.472	2.554	2.594	2.584	2.509	(41)	
	Ebn at Noon		923	961	979	954	952	951	921	914	934	926	908	901	(42)	
	Edh at Noon		74	84	91	110	107	103	108	105	90	77	67	66	(43)	
(44) All-Sky Solar Radiation	RadAvg		2.07	2.94	4.37	5.55	6.54	7.78	7.47	6.49	5.33	3.70	2.41	1.73	(44)	
	RadStd		0.20	0.31	0.30	0.35	0.54	0.57	0.34	0.32	0.38	0.27	0.24	0.21	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	-0.38	N/A	N/A	N/A	+110	+68	
(47) Regional (9 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page