

OGDEN-HINCKLEY, UT, USA

WMO: 725750

Lat: 41.196N

Lon: 112.011W

Elev: 4470

StdP: 12.47

Time Zone: -7.00 (NAM)

Period: 98-19

WBAN: 24126

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	9.2	12.6	0.3	6.6	13.9	4.0	8.0	16.9	24.7	40.2	20.1	39.8	5.4	170	0.544

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	25.0	95.9	61.4	93.3	60.5	90.9	60.1	65.1	85.8	63.9	85.3	62.6	84.6	7.0	290

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
(p)	(q)	(r)	(s)	(t)	(u)	(v)	(w)	(x)	(y)	(z)	(aa)	(ab)	(ac)	(ad)	
58.4	86.2	71.6	55.5	77.4	72.9	53.8	72.8	72.8	32.3	85.7	31.2	84.8	30.3	84.8	69.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 21.4	18.2	15.6	DB	4.5	100.0	4.9	2.5	1.0	101.8	-1.9	103.3	-4.7	104.7	-8.3	106.5	(4)
(5)			WB	3.0	67.0	4.7	1.1	-0.4	67.8	-3.1	68.4	-5.7	69.1	-9.2	69.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	52.1	28.4	33.5	43.1	49.5	58.4	68.9	78.8	75.8	65.8	52.1	40.3	29.7
	DBStd	18.55	8.27	8.12	7.61	7.70	8.47	8.29	4.40	4.87	7.72	7.95	8.38	8.30
	HDD50	2504	669	463	239	102	21	1	0	0	4	70	305	630
	HDD65	5784	1134	882	678	468	239	56	0	4	82	405	742	1094
	CDD50	3280	0	1	26	86	281	569	894	799	477	134	13	0
	CDD65	1087	0	0	0	2	35	174	429	338	105	4	0	0
	CDH74	12958	0	0	1	33	449	2225	5316	3772	1110	52	0	0
	CDH80	6036	0	0	0	4	125	981	2816	1757	347	6	0	0
Wind	WSAvg	6.9	5.2	6.4	7.5	8.1	7.5	7.5	7.3	7.2	7.1	6.7	6.1	5.8
Precipitation	PrecAvg	17.1	1.3	1.3	1.7	2.1	1.9	1.3	0.6	0.7	1.5	1.6	1.6	1.4
	PrecMax	34.3	3.1	3.2	5.1	5.6	5.5	4.2	1.9	3.2	5.5	4.2	3.5	5.4
	PrecMin	8.3	0.0	0.1	0.1	0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	PrecStd	5.0	0.8	0.9	1.2	1.3	1.5	1.2	0.6	0.8	1.5	1.1	0.9	1.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	50.2	58.8	71.4	78.6	88.4	97.7	99.3	96.1	90.4	79.8	65.3	54.0
		MCWB	40.8	43.9	49.0	52.8	57.3	61.5	63.3	61.5	59.7	54.3	48.2	43.5
	2%	DB	45.9	53.6	65.7	72.5	83.5	93.0	97.1	93.3	87.6	73.8	61.2	48.7
		MCWB	38.9	41.7	47.1	49.9	55.8	58.9	62.1	60.5	58.3	52.4	46.2	40.6
	5%	DB	42.9	49.3	61.3	68.3	79.2	89.8	95.0	91.3	84.2	69.8	57.0	44.7
		MCWB	36.9	39.9	45.0	48.5	54.5	58.7	61.3	60.0	56.8	51.4	44.2	37.9
	10%	DB	39.1	45.4	56.9	64.1	74.8	86.0	92.6	89.5	81.1	65.7	52.8	40.9
		MCWB	34.4	37.9	42.9	47.0	53.1	57.3	60.9	59.8	56.7	49.6	42.5	36.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	42.8	45.3	50.2	54.0	59.5	63.6	67.4	65.9	64.3	57.1	50.5	44.4
		MCDB	47.1	55.0	67.2	75.6	82.3	92.1	88.4	85.1	80.1	71.0	61.4	51.9
	2%	WB	40.0	42.8	48.0	51.2	57.4	61.4	65.7	64.4	61.4	54.9	47.3	41.4
		MCDB	44.9	51.5	64.1	68.5	78.2	86.8	86.4	85.0	79.5	69.3	58.0	47.4
	5%	WB	37.4	40.7	45.7	49.5	55.5	59.9	64.5	63.2	59.7	52.8	45.2	38.8
		MCDB	41.7	48.0	59.9	65.4	75.3	84.7	85.8	84.2	77.8	66.7	55.6	43.5
	10%	WB	34.9	38.4	43.7	47.9	53.9	58.7	63.4	62.1	58.1	50.7	43.3	36.4
		MCDB	38.9	44.7	55.6	62.3	72.5	82.4	85.4	83.3	75.6	64.2	52.0	40.8
Mean Daily Temperature Range	5% DB	MDBR	13.0	14.7	18.3	19.7	21.2	24.6	25.0	24.1	23.3	20.2	16.7	12.9
		MCDBR	15.5	18.6	24.2	26.3	27.0	28.7	27.5	26.5	26.6	24.8	21.3	15.7
		MCWBR	10.2	10.8	12.1	12.2	10.4	10.3	9.7	9.9	10.8	12.0	11.8	10.3
	5% WB	MCDBR	14.6	17.1	22.9	24.1	24.8	26.4	23.4	22.7	22.2	22.1	19.6	14.8
	MCWBR	9.9	10.2	11.8	11.6	10.0	10.1	8.7	9.0	9.5	10.8	11.5	10.0	
Clear-Sky Solar Irradiance	taub	0.253	0.265	0.280	0.316	0.319	0.316	0.344	0.338	0.308	0.284	0.263	0.250	
	taud	2.467	2.503	2.547	2.440	2.483	2.530	2.470	2.480	2.551	2.602	2.590	2.515	
	Ebn at Noon	293	305	311	304	303	303	293	292	297	295	288	286	
	Edh at Noon	23	27	29	35	34	33	34	33	29	24	21	21	
All-Sky Solar Radiation	RadAvg	624	903	1364	1753	2069	2465	2393	2080	1680	1157	745	517	
	RadStd	67	100	92	107	169	169	171	103	96	112	77	74	66

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (9 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page