

HUNT FIELD, WY, USA

WMO: 725760

Lat: 42.815N

Lon: 108.726W

Elev: 5592

StdP: 11.96

Time Zone: -7.00 (NAM)

Period: 94-19

WBAN: 24021

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-6.6	-1.0	-12.3	3.5	-4.1	-7.5	4.5	2.4	29.0	40.1	24.1	38.9	2.5	120	0.598

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	28.9	92.2	58.8	89.5	58.0	86.8	57.4	61.9	83.2	60.5	82.1	59.4	81.3	10.0	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
55.3	80.3	66.4	52.8	73.2	66.6	50.6	67.3	67.2	30.3	82.8	29.3	82.0	28.4	81.2	68.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
25.3	20.2	16.7	-15.0	96.8	6.0	2.1	-19.3	98.3	-22.8	99.5	-26.2	100.7	-30.6	102.2		
			-15.4	64.4	5.8	1.7	-19.6	65.6	-23.0	66.6	-26.2	67.5	-30.4	68.7		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	46.1	22.6	25.9	36.6	43.8	53.1	63.7	72.7	70.7	60.6	46.0	33.4	22.4	(6)
	DBStd	19.81	11.11	11.33	10.02	8.90	8.65	7.60	5.01	5.38	8.56	9.87	11.24	11.44	(7)
	HDD50	3808	850	676	422	223	70	5	0	0	19	187	501	855	(8)
	HDD65	7472	1315	1096	879	637	377	111	7	18	176	589	947	1320	(9)
	CDD50	2372	0	0	7	37	164	416	704	641	336	63	4	0	(10)
	CDD65	563	0	0	0	0	7	72	246	194	43	1	0	0	(11)
	CDH74	7104	0	0	0	9	151	1047	2978	2262	632	25	0	0	(12)
	CDH80	2849	0	0	0	0	22	371	1350	924	180	2	0	0	(13)
(14) Wind	WSAvg	6.3	4.8	5.3	6.8	7.4	7.3	7.6	7.1	6.9	6.4	5.6	5.2	4.8	(14)
(15) Precipitation	PrecAvg	13.0	0.5	0.6	1.2	2.0	2.4	1.3	0.7	0.5	1.0	1.3	0.8	0.6	(15)
	PrecMax	21.3	1.3	1.7	4.6	6.5	6.8	5.3	2.5	2.3	4.7	4.9	3.4	2.0	(16)
	PrecMin	5.4	0.0	0.0	0.0	0.2	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	(17)
	PrecStd	3.2	0.4	0.4	1.0	1.2	1.7	1.3	0.6	0.5	0.9	0.9	0.7	0.5	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	51.3	56.1	67.6	74.9	82.8	92.8	96.5	93.8	89.0	77.5	64.8	53.2	(19)
		MCWB	38.4	40.4	45.2	49.8	54.5	57.9	60.3	58.7	57.5	51.9	44.8	39.7	(20)
	2%	DB	46.6	50.7	61.8	69.4	78.4	88.3	93.5	90.9	85.0	71.7	59.2	47.7	(21)
		MCWB	35.8	38.2	42.8	46.8	53.1	56.7	59.6	58.1	55.3	49.4	42.6	36.6	(22)
	5%	DB	42.3	46.2	57.3	64.8	73.9	84.4	90.6	88.5	81.5	66.8	54.7	43.2	(23)
		MCWB	33.4	35.6	41.3	45.4	51.9	56.2	58.7	57.5	54.2	47.6	40.5	34.0	(24)
	10%	DB	38.2	42.0	52.9	60.5	69.4	80.3	87.7	85.7	77.2	62.4	50.0	38.3	(25)
		MCWB	30.9	32.8	39.1	43.5	50.4	55.4	58.3	57.1	52.8	45.6	38.3	30.9	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	39.2	41.6	46.2	51.0	58.1	62.0	64.4	62.6	60.4	53.2	46.1	40.4	(27)
		MCDB	48.8	53.5	64.8	72.2	76.0	82.7	84.2	84.7	80.8	71.8	61.9	52.3	(28)
	2%	WB	36.3	38.8	43.7	48.1	54.9	59.8	62.5	60.9	57.8	50.7	43.2	37.1	(29)
		MCDB	45.4	50.3	59.8	66.5	72.9	80.9	83.6	82.5	78.0	68.7	57.6	47.1	(30)
	5%	WB	33.7	35.8	41.7	46.0	53.0	58.2	61.3	59.7	56.0	48.5	41.0	34.1	(31)
		MCDB	41.7	45.4	56.6	63.2	70.8	78.5	82.7	81.8	75.5	64.7	53.8	42.7	(32)
	10%	WB	31.2	33.0	39.4	44.0	51.2	56.6	60.1	58.5	54.3	46.4	38.6	31.2	(33)
		MCDB	38.1	41.3	51.9	59.4	67.6	76.4	82.0	80.4	73.4	60.8	49.8	38.1	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	19.1	20.0	22.1	22.8	23.4	27.0	28.9	28.2	26.5	23.4	21.1	18.8	(35)
		MCDBR	23.7	24.4	28.0	29.8	29.7	32.4	32.0	31.3	31.2	29.8	26.7	23.8	(36)
	5% WB	MCWBR	15.5	14.8	14.6	14.5	13.2	13.4	12.0	11.9	13.0	14.1	14.6	15.4	(37)
		MCWBR	23.1	23.7	26.8	28.3	27.4	29.1	28.2	28.5	27.3	27.7	26.1	23.1	(38)
(40) Clear-Sky Solar Irradiance	taub		0.236	0.242	0.261	0.308	0.318	0.315	0.343	0.332	0.300	0.267	0.245	0.236	(40)
	taud		2.521	2.524	2.514	2.404	2.437	2.475	2.426	2.445	2.528	2.596	2.573	2.525	(41)
	Ebn at Noon		298	313	316	305	302	302	292	293	298	298	292	287	(42)
	Edh at Noon		21	25	29	36	35	34	36	34	29	23	20	19	(43)
(44) All-Sky Solar Radiation	RadAvg		679	997	1405	1752	2009	2387	2311	2013	1632	1109	742	551	(44)
	RadStd		44	64	82	102	167	149	97	65	112	73	55	39	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (12 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page