

JACKSON HOLE, WY, USA

WMO: 725776

Lat: 43.600N

Lon: 110.733W

Elev: 1957

StdP: 79.93

Time Zone: -7.00 (NAM)

Period: 94-19

WBAN: 24166

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-26.1	-22.6	-29.2	0.3	-24.6	-26.1	0.4	-22.2	13.0	-5.9	11.4	-4.7	2.8	20	0.719

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.2	28.9	13.1	27.5	12.6	26.1	12.2	14.8	24.9	14.0	24.1	13.2	23.4	4.8	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11.6	10.8	16.5	10.3	9.9	16.2	8.9	9.0	16.1	48.0	24.6	45.5	24.2	43.3	22.9	18.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
10.8	9.2	8.2	-30.8	31.2	2.9	1.7	-32.9	32.4	-34.6	33.4	-36.2	34.3	-38.3	35.5		
			-30.5	16.4	2.2	1.1	-32.1	17.2	-33.3	17.8	-34.5	18.5	-36.1	19.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	3.1	-8.8	-8.2	-3.0	2.6	7.6	11.6	16.2	15.3	10.5	3.9	-2.8	-8.7
	DBStd	9.99	6.34	6.16	4.67	3.63	3.74	3.35	2.59	2.37	3.74	4.11	5.17	6.30
	HDD10.0	3031	583	510	404	222	92	23	1	1	38	193	384	579
	HDD18.3	5580	842	743	662	472	332	203	75	96	234	449	634	837
	CDD10.0	503	0	0	0	0	18	71	192	166	54	3	0	0
	CDD18.3	11	0	0	0	0	0	0	8	3	0	0	0	0
	CDH23.3	1039	0	0	0	0	11	70	513	372	72	0	0	0
	CDH26.7	228	0	0	0	0	1	6	140	76	6	0	0	0
Wind	WSAvg	3.3	3.4	3.5	3.8	3.7	3.5	3.2	3.0	2.9	2.8	3.2	3.0	3.0
Precipitation	PrecAvg	560	67	49	47	42	52	49	27	33	36	43	53	72
	PrecMax	766	117	124	110	64	100	109	81	59	76	80	119	193
	PrecMin	390	14	18	19	12	9	15	6	8	8	5	11	29
	PrecStd	111	31	21	23	14	25	28	20	16	16	20	25	36
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	4.3	5.4	11.1	18.7	24.8	27.4	32.2	30.9	27.4	21.4	12.9	5.4
		MCWB	1.4	1.7	3.9	7.6	11.1	12.7	14.4	13.8	12.0	8.5	5.2	1.2
	2%	DB	2.8	3.5	7.4	16.1	21.4	25.5	29.9	28.6	25.5	17.9	10.0	3.0
		MCWB	0.3	0.6	1.8	5.8	10.1	12.0	13.4	12.7	11.4	7.2	4.0	0.5
	5%	DB	1.7	2.3	5.7	12.7	18.9	23.5	27.9	27.3	23.4	15.4	7.3	2.1
		MCWB	-0.4	-0.2	1.0	4.8	8.9	11.6	13.1	12.2	10.3	6.2	2.4	0.0
	10%	DB	0.3	1.0	3.8	10.1	17.2	21.9	26.4	25.9	21.2	12.6	4.8	0.5
		MCWB	-1.3	-1.0	0.2	3.8	7.9	11.0	12.8	12.0	9.9	5.1	1.3	-1.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	2.3	1.9	3.9	8.0	12.6	14.0	16.2	15.4	13.8	9.3	5.7	2.5
		MCDB	3.9	4.4	9.7	17.3	22.5	24.5	26.4	25.2	23.1	18.2	11.4	4.2
	2%	WB	0.8	0.9	2.4	6.4	10.8	12.9	15.2	14.3	12.5	8.0	4.2	1.0
		MCDB	2.5	3.0	5.9	14.7	19.6	23.0	25.3	24.3	22.1	16.4	8.6	2.9
	5%	WB	-0.1	0.1	1.5	5.1	9.6	12.0	14.5	13.6	11.5	6.8	2.8	0.0
		MCDB	1.4	2.0	5.0	12.0	17.5	22.0	24.6	23.8	21.1	14.1	6.3	1.6
	10%	WB	-1.3	-1.1	0.6	4.0	8.4	11.2	13.7	12.8	10.3	5.6	1.6	-1.2
		MCDB	-0.1	0.5	3.7	9.2	15.5	20.7	23.9	23.0	19.4	12.0	4.6	0.3
Mean Daily Temperature Range	5% DB	MDBR	9.8	11.0	11.1	11.9	14.2	16.1	19.2	19.7	17.9	14.7	11.2	9.9
		MCDBR	8.5	9.2	12.6	18.2	19.2	20.9	22.6	23.0	22.7	20.9	14.8	8.2
		MCWBR	6.7	7.1	8.4	9.8	9.4	9.9	9.9	10.1	10.6	11.6	9.3	6.4
	5% WB	MCDBR	7.0	8.3	11.2	15.9	17.2	19.0	19.0	19.1	19.5	18.4	13.1	7.3
		MCWBR	5.8	6.6	7.7	8.8	8.7	9.2	8.8	8.9	9.3	10.4	8.4	6.0
Clear-Sky Solar Irradiance	taub	0.235	0.246	0.262	0.298	0.305	0.312	0.327	0.333	0.302	0.281	0.251	0.233	
	taud	2.352	2.311	2.331	2.363	2.489	2.515	2.496	2.457	2.549	2.569	2.517	2.403	
	Ebn at Noon	919	964	987	969	966	956	937	921	933	917	900	890	
	Edh at Noon	77	96	109	116	105	103	104	105	88	75	66	67	
All-Sky Solar Radiation	RadAvg	1.85	2.75	4.01	5.19	5.86	6.96	7.27	6.14	4.81	3.04	1.88	1.40	
	RadStd	0.18	0.33	0.34	0.43	0.61	0.62	0.38	0.36	0.43	0.27	0.20	0.16	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (12 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page