

MURPHY 10 W, ID, USAWMO: **725800**Lat: **43.2044N**Lon: **116.7505W**Elev: **3950**StdP: **12.72**Time Zone: **-7.00 (NAM)**Period: **03-19**WBAN: **04127****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	6.3	11.5	-0.8	6.1	6.9	4.0	7.8	14.0	18.1	41.7	16.3	42.3	1.8	N/A	0.510

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	31.1	93.8	59.9	91.1	59.1	88.4	58.6	62.2	85.7	60.9	85.3	59.8	84.3	6.6	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
54.1	72.1	68.4	51.0	64.3	66.9	48.9	59.3	66.8	29.8	84.7	28.9	85.3	28.0	83.7	67.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
14.8	12.5	10.6	-0.8	98.9	4.8	2.4	-4.3	100.6	-7.1	102.0	-9.7	103.3	-13.2	105.1
			-1.9	65.1	4.9	1.7	-5.5	66.3	-8.3	67.3	-11.1	68.2	-14.7	69.5
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	49.1	30.0	34.4	41.2	46.3	54.2	62.4	72.5	70.3	60.8	48.8	37.4	29.8
	DBStd	16.28	8.63	7.47	6.86	6.54	7.42	7.58	5.49	5.62	7.64	8.07	8.59	9.06
	HDD50	2675	620	439	283	148	40	3	0	0	8	120	387	627
	HDD65	6344	1085	857	738	561	342	135	10	21	170	505	829	1091
	CDD50	2339	0	1	9	37	171	375	698	628	331	81	8	0
	CDD65	535	0	0	0	0	7	57	243	184	42	2	0	0
	CDH74	8792	0	0	0	19	235	1138	3767	2771	809	53	0	0
	CDH80	3810	0	0	0	1	48	424	1863	1226	240	8	0	0
Wind	WSAvg	4.3	3.8	4.6	5.0	5.1	4.6	4.3	4.2	4.0	3.9	3.9	4.0	4.1
Precipitation	PrecAvg	13.0	1.6	1.1	1.3	1.5	1.8	0.9	0.4	0.3	0.4	0.8	1.4	1.7
	PrecMax	19.9	3.7	2.1	3.2	2.5	5.7	2.1	1.1	0.9	1.3	2.4	2.2	4.8
	PrecMin	8.0	0.2	0.2	0.2	0.6	0.2	0.3	0.0	0.0	0.0	0.0	0.4	0.6
	PrecStd	3.2	0.9	0.6	0.7	0.5	1.4	0.6	0.3	0.3	0.4	0.6	0.6	1.0
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	53.1	58.0	69.0	77.0	85.6	94.2	98.1	96.1	90.0	80.0	65.5	54.9
		MCWB	42.8	44.1	48.3	53.1	56.3	62.0	62.9	58.9	58.2	55.0	49.7	43.8
	2%	DB	48.5	53.4	63.1	71.0	80.1	89.1	94.9	92.7	86.0	74.0	60.1	51.5
		MCWB	40.4	42.4	46.5	50.3	54.6	59.6	60.1	58.8	56.7	51.6	46.1	42.5
	5%	DB	45.5	50.3	58.9	66.0	76.0	85.0	92.4	89.7	82.6	68.8	56.0	47.8
		MCWB	38.7	41.2	44.9	48.0	53.7	57.9	59.5	58.4	55.6	49.7	43.8	40.8
	10%	DB	42.2	46.9	54.7	61.5	71.2	80.8	89.6	87.0	79.0	64.3	51.2	43.3
		MCWB	36.6	39.4	43.2	46.3	51.8	56.2	59.0	58.0	54.5	47.9	42.4	38.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	45.7	46.4	49.5	55.4	57.9	64.6	64.7	62.3	62.6	56.7	50.5	45.4
		MCDB	51.9	54.5	62.7	74.0	77.2	89.5	88.6	82.8	74.9	73.6	62.6	52.3
	2%	WB	41.4	44.5	47.7	51.6	56.1	61.6	62.4	61.1	59.9	53.8	47.8	43.7
		MCDB	48.1	52.7	60.3	66.9	74.6	87.2	87.7	85.2	77.8	69.3	58.3	50.7
	5%	WB	39.3	42.7	46.0	49.2	54.4	59.5	61.2	60.0	57.8	51.4	45.5	40.7
		MCDB	45.1	51.3	57.6	63.8	72.0	82.1	86.7	85.0	78.5	65.3	54.8	46.7
	10%	WB	37.3	40.5	44.0	47.0	52.8	57.4	60.1	59.0	55.6	49.1	42.9	37.8
		MCDB	42.6	48.1	53.8	60.3	69.3	78.3	85.8	84.5	77.0	62.1	51.3	42.8
Mean Daily Temperature Range	5% DB	MDBR	15.7	16.8	21.3	23.6	25.4	28.3	31.1	30.1	28.9	24.6	19.6	15.9
		MCDBR	18.1	20.5	27.8	31.7	33.0	34.8	33.9	33.7	33.0	29.7	24.6	18.2
		MCWBR	12.5	12.2	14.7	16.1	14.5	14.0	12.7	12.9	14.0	14.4	14.1	11.6
	5% WB	MCDBR	17.8	19.7	24.8	29.0	29.0	32.4	30.3	30.3	28.8	25.3	23.4	16.8
		MCWBR	12.3	12.2	14.0	15.5	13.2	13.6	11.8	12.6	12.5	13.6	13.7	11.1
Clear-Sky Solar Irradiance	taub	0.250	0.256	0.273	0.294	0.309	0.306	0.315	0.316	0.297	0.274	0.256	0.251	
	taud	2.608	2.639	2.598	2.525	2.505	2.555	2.529	2.506	2.560	2.622	2.623	2.596	
	Ebn at Noon	292	307	312	310	305	305	301	298	298	295	287	281	
	Edh at Noon	20	23	27	31	33	31	32	32	28	23	19	18	
All-Sky Solar Radiation	RadAvg	519	837	1248	1730	2097	2400	2442	2117	1661	1102	652	427	
	RadStd	77	109	118	134	156	129	94	95	84	76	53	66	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (11 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+149	+43

Nomenclature: See separate page