

MURPHY 10 W, ID, USA

WMO: 725800

Lat: 43.2044N

Lon: 116.7505W

Elev: 1204

StdP: 87.67

Time Zone: -7.00 (NAM)

Period: 03-19

WBAN: 04127

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-14.3	-11.4	-18.2	0.9	-13.9	-15.6	1.1	-10.0	8.1	5.4	7.3	5.7	0.8	N/A	0.510

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.3	34.3	15.5	32.8	15.1	31.3	14.8	16.8	29.8	16.1	29.6	15.5	29.1	2.9	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12.3	10.3	20.2	10.6	9.2	19.4	9.4	8.5	19.3	51.5	29.3	49.3	29.6	47.3	28.7	19.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6.6	5.6	4.8	-18.2	37.2	2.7	1.3	-20.1	38.1	-21.7	38.9	-23.2	39.6	-25.1	40.6
			-18.8	18.4	2.7	0.9	-20.8	19.0	-22.4	19.6	-23.9	20.1	-25.9	20.8
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	9.5	-1.1	1.3	5.1	8.0	12.3	16.9	22.5	21.3	16.0	9.3	3.0	-1.2	(6)
(7)		DBStd	9.05	4.79	4.15	3.81	3.64	4.12	4.21	3.05	3.12	4.25	4.48	4.77	5.04	(7)
(8)		HDD10.0	1486	344	244	157	82	22	2	0	0	4	67	215	348	(8)
(9)		HDD18.3	3524	603	476	410	312	190	75	6	12	94	281	461	606	(9)
(10)		CDD10.0	1299	0	1	5	21	95	208	388	349	184	45	4	0	(10)
(11)		CDD18.3	297	0	0	0	0	4	32	135	102	23	1	0	0	(11)
(12)		CDH23.3	4884	0	0	0	11	131	632	2093	1539	449	29	0	0	(12)
(13)		CDH26.7	2117	0	0	0	1	27	236	1035	681	133	4	0	0	(13)
(14)	Wind	WSAvg	1.9	1.7	2.1	2.2	2.3	2.0	1.9	1.9	1.8	1.7	1.7	1.8	1.8	(14)
(15)	Precipitation	PrecAvg	329	40	29	32	37	45	22	9	7	10	21	35	43	(15)
(16)		PrecMax	506	94	54	81	63	144	54	27	22	34	60	57	121	(16)
(17)		PrecMin	203	6	6	6	16	5	7	0	0	0	1	10	14	(17)
(18)		PrecStd	82	22	15	19	13	35	15	8	7	10	14	15	26	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.7	14.5	20.6	25.0	29.8	34.6	36.7	35.6	32.2	26.7	18.6	12.7	(19)
(20)			MCWB	6.0	6.7	9.0	11.7	13.5	16.7	17.2	14.9	14.5	12.8	9.8	6.6	(20)
(21)		2%	DB	9.2	11.9	17.3	21.7	26.7	31.7	34.9	33.7	30.0	23.3	15.6	10.8	(21)
(22)			MCWB	4.7	5.8	8.1	10.1	12.6	15.3	15.6	14.9	13.7	10.9	7.8	5.8	(22)
(23)		5%	DB	7.5	10.2	14.9	18.9	24.5	29.5	33.5	32.1	28.1	20.5	13.3	8.8	(23)
(24)			MCWB	3.7	5.1	7.2	8.9	12.0	14.4	15.3	14.7	13.1	9.8	6.6	4.9	(24)
(25)		10%	DB	5.6	8.3	12.6	16.4	21.8	27.1	32.0	30.5	26.1	17.9	10.7	6.3	(25)
(26)			MCWB	2.6	4.1	6.2	7.9	11.0	13.5	15.0	14.5	12.5	8.8	5.8	3.4	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.6	8.0	9.7	13.0	14.4	18.1	18.2	16.9	17.0	13.7	10.3	7.5	(27)
(28)			MCD B	11.1	12.5	17.0	23.3	25.1	31.9	31.5	28.2	23.8	23.1	17.0	11.3	(28)
(29)		2%	WB	5.2	7.0	8.7	10.9	13.4	16.4	16.9	16.2	15.5	12.1	8.8	6.5	(29)
(30)			MCD B	9.0	11.5	15.7	19.4	23.7	30.7	30.9	29.6	25.5	20.7	14.6	10.4	(30)
(31)		5%	WB	4.0	5.9	7.8	9.6	12.4	15.3	16.2	15.6	14.3	10.8	7.5	4.8	(31)
(32)			MCD B	7.3	10.7	14.2	17.7	22.2	27.8	30.4	29.4	25.8	18.5	12.7	8.2	(32)
(33)		10%	WB	2.9	4.7	6.7	8.4	11.6	14.1	15.6	15.0	13.1	9.5	6.1	3.2	(33)
(34)			MCD B	5.9	8.9	12.1	15.7	20.7	25.7	29.9	29.2	25.0	16.7	10.7	6.0	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	8.7	9.4	11.8	13.1	14.1	15.7	17.3	16.7	16.0	13.6	10.9	8.8	(35)
(36)			MCD BR	10.1	11.4	15.4	17.6	18.3	19.3	18.8	18.7	18.3	16.5	13.7	10.1	(36)
(37)			MCWBR	6.9	6.8	8.2	9.0	8.0	7.8	7.0	7.2	7.8	8.0	7.8	6.4	(37)
(38)		5% WB	MCD BR	9.9	11.0	13.8	16.1	16.1	18.0	16.8	16.8	16.0	14.0	13.0	9.3	(38)
(39)			MCWBR	6.8	6.8	7.8	8.6	7.3	7.5	6.6	7.0	6.9	7.6	7.6	6.2	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.250	0.256	0.273	0.294	0.309	0.306	0.315	0.316	0.297	0.274	0.256	0.251	(40)	
(41)		taud	2.608	2.639	2.598	2.525	2.505	2.555	2.529	2.506	2.560	2.622	2.623	2.596	(41)	
(42)		Ebn at Noon	921	969	983	976	962	962	949	940	940	931	905	886	(42)	
(43)		Edh at Noon	62	72	85	99	104	99	101	100	87	72	61	58	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.64	2.64	3.93	5.46	6.61	7.57	7.70	6.67	5.24	3.48	2.05	1.35	(44)	
(45)		RadStd	0.24	0.34	0.37	0.42	0.49	0.41	0.30	0.30	0.27	0.24	0.17	0.21	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days					
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(47) Regional (11 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+83	+24		

Nomenclature: See separate page