

WENDOVER, UT, USA

WMO: 725810

Lat: 40.721N

Lon: 114.036W

Elev: 4237

StdP: 12.58

Time Zone: -7.00 (NAM)

Period: 94-19

WBAN: 24193

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	8.8	12.2	0.2	6.5	15.9	3.0	7.5	20.6	28.8	37.4	25.1	37.5	1.8	50	0.556

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	24.2	97.5	60.9	95.0	60.4	92.2	59.4	63.8	87.4	62.5	87.0	61.4	86.6	11.7	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
55.4	76.6	72.0	54.0	72.6	71.7	51.6	66.5	71.9	31.2	86.0	30.2	87.3	29.4	86.8	69.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 27.3	23.6	19.5	DB	5.0	101.3	4.8	2.2	1.5	102.8	-1.3	104.1	-4.0	105.4	-7.4	107.0	(4)
(5)			WB	3.7	65.9	5.2	1.5	-0.1	67.0	-3.1	67.9	-6.1	68.8	-9.9	69.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	52.7	28.1	34.2	43.5	50.8	60.6	71.4	80.6	77.5	66.3	51.3	37.8	28.5		
	DBStd	19.31	8.50	7.44	6.96	7.36	8.21	8.09	4.97	4.75	7.26	7.37	7.26	7.35		
	HDD50	2540	679	444	222	77	10	1	0	0	1	70	370	666		
	HDD65	5772	1144	863	665	429	187	36	1	1	71	428	816	1131		
	CDD50	3514	0	1	21	101	339	643	949	854	492	110	4	0		
	CDD65	1270	0	0	0	3	51	228	484	390	111	3	0	0		
	CDH74	15332	0	0	2	50	550	2671	6291	4552	1174	42	0	0		
	CDH80	7348	0	0	0	6	159	1190	3395	2211	381	6	0	0		
	WSAvg	6.8	4.3	5.8	7.5	9.0	8.5	8.1	7.4	6.5	5.9	5.2	4.7			
	PrecAvg	5.0	0.3	0.3	0.4	0.5	0.7	0.6	0.3	0.4	0.4	0.5	0.3	0.2		
(15) Precipitation	PrecMax	10.4	1.8	1.3	1.3	2.0	4.2	3.0	1.1	1.5	3.4	2.4	1.6	0.9		
(16) PrecipMin		1.6	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
(17) PrecStd		1.9	0.3	0.3	0.4	0.4	0.7	0.6	0.2	0.4	0.5	0.6	0.3	0.2		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	52.3	58.4	70.4	80.5	90.1	98.7	100.4	99.0	91.4	79.3	63.0	53.8		
		MCWB	41.9	43.9	47.8	52.2	57.4	61.5	62.5	61.6	59.1	53.2	46.9	42.7		
	2%	DB	45.7	53.7	64.1	73.3	84.0	93.3	99.1	95.9	88.3	72.8	57.0	46.4		
		MCWB	37.7	42.1	45.5	49.4	55.1	58.3	61.8	60.4	57.7	51.6	44.2	38.5		
	5%	DB	43.0	48.7	61.1	69.7	80.8	90.6	96.9	93.0	84.1	68.1	53.7	43.2		
		MCWB	35.6	39.8	44.2	48.6	53.9	57.8	61.1	59.4	56.6	50.0	42.2	36.1		
	10%	DB	39.3	45.7	56.7	64.1	75.4	87.8	93.3	90.7	81.2	63.8	49.7	39.1		
		MCWB	33.6	37.7	42.5	46.3	51.8	57.2	60.0	59.1	55.2	47.7	40.5	33.3		
	0.4%	WB	42.1	45.7	49.4	53.7	58.7	62.7	65.8	64.4	63.4	55.6	48.2	43.2		
		MCDB	50.5	56.9	65.8	75.6	84.0	93.0	88.5	85.6	80.2	72.5	60.8	51.7		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	38.8	42.7	47.0	51.0	56.3	60.3	64.3	63.0	60.9	53.3	45.0	39.5		
		MCDB	44.7	51.4	62.6	70.5	79.1	88.4	88.3	85.9	79.4	67.9	56.0	46.0		
	5%	WB	36.4	40.5	45.1	49.2	54.9	59.0	63.3	61.8	59.1	51.2	43.0	36.9		
		MCDB	42.1	48.1	59.7	66.3	76.7	86.4	88.0	85.8	78.2	65.7	52.0	42.6		
	10%	WB	34.3	38.3	43.2	47.4	53.3	57.6	62.2	60.7	57.1	49.1	40.7	34.1		
		MCDB	39.7	45.1	56.1	63.3	73.4	83.9	87.9	85.1	76.5	62.6	48.8	39.0		
(35) Mean Daily Temperature Range	5% DB	MDBR	14.7	16.4	20.0	20.0	20.5	22.9	24.2	24.4	23.5	20.1	17.1	14.7		
		MCDBR	17.6	20.6	25.8	27.4	26.4	27.1	27.0	27.8	28.3	25.3	21.6	17.2		
		MCWBR	12.5	13.2	13.5	12.3	10.2	9.9	9.7	10.0	11.0	11.8	13.1	12.5		
		MCDBR	17.1	19.2	24.5	24.4	24.0	25.8	23.2	23.7	23.0	22.5	19.9	16.5		
	5% WB	MCWBR	12.6	12.8	13.3	11.3	9.3	9.4	7.8	8.8	9.1	10.8	12.8	12.3		
(40) Clear-Sky Solar Irradiance	taub		0.246	0.253	0.265	0.311	0.329	0.326	0.349	0.339	0.305	0.268	0.251	0.245		
	taud		2.594	2.583	2.562	2.379	2.353	2.387	2.353	2.377	2.466	2.588	2.595	2.597		
	Ebn at Noon		300	312	317	305	300	300	292	292	298	302	295	292		
	Edh at Noon		21	25	29	37	39	37	38	36	31	24	21	19		
(44) All-Sky Solar Radiation	RadAvg		666	972	1394	1765	2038	2362	2230	2009	1674	1189	794	560		
	RadStd		92	109	82	100	171	164	111	113	96	69	44	70		

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (8 neighbors)	N/A	N/A	N/A	+0.90	N/A	N/A	N/A	N/A	+189	+99

Nomenclature: See separate page