

WENDOVER, UT, USA

WMO: 725810

Lat: 40.721N

Lon: 114.036W

Elev: 1291

StdP: 86.74

Time Zone: -7.00 (NAM)

Period: 94-19

WBAN: 24193

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-12.9	-11.0	-17.7	0.9	-8.9	-16.1	1.1	-6.3	12.9	3.0	11.2	3.0	0.8	50	0.556

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.4	36.4	16.1	35.0	15.8	33.5	15.2	17.7	30.8	17.0	30.6	16.3	30.3	5.2	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
13.0	10.9	22.2	12.2	10.4	22.1	10.9	9.5	22.2	54.7	30.0	52.4	30.7	50.4	30.5	20.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12.2	10.5	8.7	-15.0	38.5	2.7	1.2	-16.9	39.4	-18.5	40.1	-20.0	40.8	-21.9	41.7
			-15.7	18.8	2.9	0.9	-17.8	19.4	-19.5	19.9	-21.1	20.4	-23.3	21.1
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	11.5	-2.2	1.2	6.4	10.4	15.9	21.9	27.0	25.3	19.1	10.7	3.2	-1.9
	DBStd	10.73	4.72	4.13	3.87	4.09	4.56	4.49	2.76	2.64	4.03	4.10	4.03	4.08
	HDD10.0	1411	377	247	123	43	6	1	0	0	1	39	206	370
	HDD18.3	3207	636	479	369	238	104	20	1	1	39	238	453	628
	CDD10.0	1952	0	1	12	56	188	357	527	474	273	61	2	0
	CDD18.3	706	0	0	0	2	28	127	269	217	62	2	0	0
	CDH23.3	8518	0	0	1	28	306	1484	3495	2529	652	23	0	0
	CDH26.7	4082	0	0	0	3	88	661	1886	1228	212	3	0	0
Wind	WSAvg	3.0	1.9	2.6	3.3	4.0	3.8	3.8	3.6	3.3	2.9	2.7	2.3	2.1
Precipitation	PrecAvg	127	7	7	10	12	19	14	7	9	10	12	8	6
	PrecMax	264	45	33	34	50	106	76	28	38	86	61	40	22
	PrecMin	41	0	0	0	0	0	0	0	0	0	0	0	0
	PrecStd	48	8	7	10	11	19	16	6	11	13	14	8	6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.3	14.6	21.3	27.0	32.3	37.1	38.0	37.2	33.0	26.3	17.2	12.1
		MCWB	5.5	6.6	8.8	11.2	14.1	16.4	16.9	16.4	15.1	11.8	8.3	5.9
	2%	DB	7.6	12.1	17.8	23.0	28.9	34.1	37.3	35.5	31.3	22.7	13.9	8.0
		MCWB	3.2	5.6	7.5	9.6	12.9	14.6	16.6	15.8	14.3	10.9	6.8	3.6
	5%	DB	6.1	9.3	16.2	20.9	27.1	32.5	36.1	33.9	28.9	20.1	12.1	6.2
		MCWB	2.0	4.3	6.8	9.2	12.1	14.3	16.2	15.2	13.7	10.0	5.7	2.3
	10%	DB	4.1	7.6	13.7	17.9	24.1	31.0	34.1	32.6	27.3	17.7	9.8	4.0
		MCWB	0.9	3.2	5.9	7.9	11.0	14.0	15.5	15.1	12.9	8.7	4.7	0.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	5.6	7.6	9.7	12.1	14.9	17.1	18.8	18.0	17.4	13.1	9.0	6.2
		MCDB	10.3	13.8	18.8	24.2	28.9	33.9	31.4	29.8	26.8	22.5	16.0	10.9
	2%	WB	3.8	6.0	8.3	10.6	13.5	15.7	17.9	17.2	16.1	11.8	7.2	4.2
		MCDB	7.1	10.8	17.0	21.4	26.2	31.3	31.3	30.0	26.3	19.9	13.3	7.8
	5%	WB	2.5	4.7	7.3	9.5	12.7	15.0	17.4	16.6	15.1	10.7	6.1	2.7
		MCDB	5.6	9.0	15.4	19.0	24.8	30.2	31.1	29.9	25.7	18.7	11.1	5.9
	10%	WB	1.3	3.5	6.2	8.6	11.8	14.2	16.8	15.9	14.0	9.5	4.8	1.2
		MCDB	4.3	7.3	13.4	17.4	23.0	28.8	31.0	29.5	24.7	17.0	9.3	3.9
Mean Daily Temperature Range	5% DB	MDBR	8.2	9.1	11.1	11.1	11.4	12.7	13.4	13.6	13.0	11.2	9.5	8.2
		MCDBR	9.8	11.5	14.3	15.2	14.7	15.1	15.0	15.4	15.7	14.0	12.0	9.6
		MCWBR	6.9	7.3	7.5	6.8	5.7	5.5	5.4	5.6	6.1	6.6	7.3	6.9
	5% WB	MCDBR	9.5	10.7	13.6	13.6	13.3	14.3	12.9	13.2	12.8	12.5	11.0	9.2
		MCWBR	7.0	7.1	7.4	6.3	5.1	5.2	4.4	4.9	5.0	6.0	7.1	6.9
Clear-Sky Solar Irradiance	taub	0.246	0.253	0.265	0.311	0.329	0.326	0.349	0.339	0.305	0.268	0.251	0.245	
	taud	2.594	2.583	2.562	2.379	2.353	2.387	2.353	2.377	2.466	2.588	2.595	2.597	
	Ebn at Noon	947	984	1000	962	945	945	919	921	938	951	930	921	
	Edh at Noon	66	78	90	116	122	118	121	115	98	77	66	61	
All-Sky Solar Radiation	RadAvg	2.10	3.06	4.39	5.57	6.43	7.45	7.03	6.33	5.28	3.75	2.50	1.76	
	RadStd	0.29	0.34	0.26	0.32	0.54	0.52	0.35	0.36	0.30	0.22	0.14	0.22	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (8 neighbors)	N/A	N/A	N/A	+0.50	N/A	N/A	N/A	N/A	+105	+55

Nomenclature: See separate page