

EUREKA, NV, USA

WMO: 725824

Lat: 39.517N

Lon: 115.967W

Elev: 1993

StdP: 79.56

Time Zone: -8.00 (NAP)

Period: 90-05

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-17.7	-14.0	-22.1	0.7	-12.4	-19.6	0.8	-6.8	14.5	2.8	12.4	-0.1	1.9	220	0.618

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.2	32.7	12.9	31.2	12.5	29.3	12.0	15.1	26.1	14.0	26.3	13.1	26.2	4.9	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
11.3	10.7	17.5	9.0	9.1	17.7	7.4	8.2	18.3	48.5	25.5	45.2	26.0	42.9	26.3	19.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.1	9.2	8.1	-19.1	33.9	4.3	2.2	-22.1	35.5	-24.6	36.8	-27.0	38.1	-30.1	39.7		
(5)			-19.6	15.9	4.0	1.9	-22.5	17.3	-24.9	18.4	-27.2	19.4	-30.1	20.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	8.1	-2.5	-0.7	3.5	6.3	10.7	15.4	21.0	20.0	15.2	9.3	0.7	-2.7	(6)
(7)		DBStd	9.35	4.66	5.25	4.21	4.30	4.59	4.40	2.79	2.96	3.87	4.94	5.43	5.28	(7)
(8)		HDD10.0	1826	388	298	204	123	49	10	0	0	7	71	281	394	(8)
(9)		HDD18.3	3936	647	532	460	360	237	104	11	18	104	281	530	653	(9)
(10)		CDD10.0	1125	0	0	2	13	71	172	342	311	164	49	1	0	(10)
(11)		CDD18.3	193	0	0	0	0	2	16	93	71	12	0	0	0	(11)
(12)		CDH23.3	3382	0	0	1	1	85	487	1472	1023	288	24	0	0	(12)
(13)		CDH26.7	1214	0	0	0	0	25	134	627	367	59	2	0	0	(13)
(14)	Wind	WSAvg	3.4	3.1	3.2	3.7	3.7	3.5	3.4	3.4	3.6	3.3	3.2	3.1	3.0	(14)
(15)	Precipitation	PrecAvg	231	20	22	25	26	26	16	13	15	16	18	15	19	(15)
(16)		PrecMax	327	46	49	76	67	76	56	42	46	43	71	45	38	(16)
(17)		PrecMin	112	1	0	2	0	0	0	0	0	0	0	0	0	(17)
(18)		PrecStd	54	15	12	18	18	22	16	10	13	11	17	11	12	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.8	13.9	21.2	22.4	29.2	31.8	36.3	33.7	30.1	26.3	16.7	11.2	(19)
(20)			MCWB	3.3	5.3	7.0	8.1	11.8	12.3	13.6	12.9	11.5	9.6	5.5	2.9	(20)
(21)		2%	DB	8.2	11.4	17.2	20.0	25.8	29.9	33.9	32.2	28.2	23.0	13.8	8.1	(21)
(22)			MCWB	2.3	3.7	5.6	7.2	10.3	11.8	13.5	12.6	10.8	8.6	4.5	1.8	(22)
(23)		5%	DB	5.7	8.7	13.9	17.5	22.6	28.0	32.3	30.5	27.0	21.3	12.0	6.3	(23)
(24)			MCWB	0.7	2.6	4.5	6.0	9.1	11.1	13.1	12.4	10.5	8.1	4.1	0.6	(24)
(25)		10%	DB	3.8	6.5	11.4	15.2	20.6	26.6	30.2	28.8	24.9	18.8	9.1	4.1	(25)
(26)			MCWB	0.0	1.6	3.7	5.3	8.4	10.6	12.3	12.1	9.9	7.1	2.6	-0.6	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	4.6	5.7	7.6	8.7	12.7	13.0	16.4	16.0	13.6	10.4	7.5	4.3	(27)
(28)			MCDWB	9.2	12.6	19.7	20.4	27.7	28.4	27.8	24.1	22.7	23.0	14.0	8.2	(28)
(29)		2%	WB	2.9	4.3	6.0	7.7	11.1	12.1	15.5	14.7	12.3	9.2	5.7	2.6	(29)
(30)			MCDWB	6.1	10.0	15.5	18.5	23.0	27.6	27.1	24.8	24.2	22.0	11.1	7.2	(30)
(31)		5%	WB	1.7	3.0	5.1	6.7	10.0	11.5	14.5	13.8	11.3	8.3	4.5	1.1	(31)
(32)			MCDWB	4.9	7.6	13.4	16.1	20.6	26.7	27.3	25.5	23.6	20.3	10.4	5.3	(32)
(33)		10%	WB	0.5	2.0	4.0	5.6	9.0	10.8	13.5	13.1	10.5	7.4	3.1	0.0	(33)
(34)			MCDWB	3.4	6.1	10.3	14.0	19.1	25.4	27.1	25.4	22.6	18.1	9.0	3.4	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	9.0	9.9	11.8	12.6	14.0	16.6	17.2	15.9	15.8	13.8	11.2	9.4	(35)
(36)			MCDBR	11.1	12.4	16.7	17.1	18.8	20.2	22.0	19.2	19.8	18.6	15.6	11.7	(36)
(37)			MCWBR	7.4	7.3	8.8	8.3	8.4	8.6	8.4	8.0	8.8	9.3	8.9	7.7	(37)
(38)		5% WB	MCDWR	9.6	10.9	15.5	15.2	16.9	18.9	18.3	15.7	15.9	17.3	13.2	10.9	(38)
(39)			MCWBR	6.7	6.8	8.4	7.7	7.6	8.1	6.5	6.2	7.2	8.6	7.9	7.4	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.230	0.238	0.250	0.275	0.285	0.286	0.305	0.299	0.271	0.254	0.236	0.230	(40)	
(41)		taud	2.635	2.627	2.619	2.527	2.546	2.572	2.542	2.536	2.624	2.652	2.663	2.634	(41)	
(42)		Ebn at Noon	981	1011	1023	1004	993	987	964	966	984	978	966	956	(42)	
(43)		Edh at Noon	65	76	86	101	101	99	101	99	84	73	63	60	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2.34	3.26	4.64	5.84	6.74	7.92	7.19	6.71	5.70	4.10	2.76	2.00	(44)	
(45)		RadStd	0.28	0.36	0.30	0.38	0.70	0.59	0.47	0.47	0.29	0.29	0.14	0.27	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (5 neighbors)		+0.40	N/A	N/A	+0.52	N/A	N/A	N/A	N/A	+125	+61

Nomenclature: See separate page