

WINNEMUCCA, NV, USA

WMO: 725830

Lat: 40.902N

Lon: 117.808W

Elev: 1309

StdP: 86.55

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 24128

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-16.0	-12.6	-20.0	0.7	-10.0	-17.0	1.0	-5.9	11.8	6.9	10.3	6.2	1.5	160	0.605

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	21.8	36.9	16.5	35.5	15.8	34.1	15.3	18.1	33.6	17.0	32.1	16.1	31.0	4.2	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12.7	10.7	21.7	10.9	9.5	21.2	9.5	8.6	21.0	56.0	33.7	52.2	32.1	49.2	30.8	25.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.1	8.5	7.6	DB	-20.6	39.6	4.0	1.8	-23.5	40.9	-25.8	41.9	-28.1	42.9	-31.0	44.2	(4)
(5)			WB	-21.0	19.3	4.0	2.3	-23.9	20.9	-26.2	22.2	-28.4	23.5	-31.3	25.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	9.9	-0.2	2.0	5.2	8.0	12.8	18.3	23.3	21.5	16.3	9.0	3.4	-1.1	(6)	
	DBStd	9.14	4.92	4.22	3.96	4.07	4.29	4.24	2.93	2.84	4.10	4.19	4.63	5.24	(7)	
	HDD10.0	1419	317	224	153	85	21	2	0	0	5	67	201	344	(8)	
	HDD18.3	3409	575	457	406	310	178	51	2	7	85	288	448	602	(9)	
	CDD10.0	1392	0	1	6	25	107	251	414	357	193	37	2	0	(10)	
	CDD18.3	341	0	0	0	0	6	49	158	106	22	1	0	0	(11)	
	CDH23.3	8018	0	0	1	34	315	1307	3026	2350	904	81	0	0	(12)	
	CDH26.7	4233	0	0	0	4	98	628	1791	1307	388	17	0	0	(13)	
(14) Wind	WSAvg	3.3	3.0	3.4	3.6	3.7	3.5	3.6	3.3	3.1	3.0	2.9	2.9	3.0	(14)	
(15) Precipitation	PrecAvg	208	22	17	20	21	24	19	6	8	11	15	23	23	(15)	
	PrecMax	396	51	55	41	74	91	66	44	44	71	44	64	93	(16)	
	PrecMin	105	1	2	1	2	0	0	0	0	0	0	2	1	(17)	
	PrecStd	59	14	11	11	14	21	18	8	11	13	13	15	19	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	14.1	17.2	22.3	26.8	32.3	36.8	39.4	37.7	34.9	28.9	20.8	13.8	(19)	
		MCWB	7.3	7.8	9.1	11.6	15.4	16.2	18.2	17.0	15.8	12.9	9.2	6.5	(20)	
	2%	DB	11.5	14.4	19.5	23.9	29.3	34.3	37.6	36.0	32.5	25.6	18.2	11.1	(21)	
		MCWB	5.5	6.7	8.1	10.5	13.3	15.2	16.7	16.2	14.3	11.3	8.2	6.0	(22)	
	5%	DB	9.3	11.9	17.2	21.2	27.1	32.4	36.3	34.7	30.9	23.1	15.4	9.1	(23)	
		MCWB	4.5	5.5	7.2	9.2	12.3	14.4	16.2	15.6	13.6	10.0	7.0	4.6	(24)	
	10%	DB	7.1	9.7	14.8	18.4	24.3	30.6	34.8	33.3	29.0	20.6	12.5	7.2	(25)	
		MCWB	3.5	4.5	6.2	8.1	11.4	13.6	15.5	14.8	12.9	9.0	5.8	3.4	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.5	8.9	10.1	12.5	16.5	18.1	21.4	19.4	17.5	13.6	10.4	8.0	(27)	
		MCDB	12.4	15.2	19.5	25.1	30.9	34.5	37.7	35.7	30.5	26.4	18.4	11.8	(28)	
	2%	WB	6.4	7.3	8.8	10.9	14.2	16.4	18.6	17.7	15.8	12.0	8.9	6.5	(29)	
		MCDB	10.3	13.2	17.9	22.0	26.3	32.1	34.3	33.3	28.8	23.4	16.7	10.0	(30)	
	5%	WB	5.1	6.1	7.8	9.8	13.0	15.1	17.3	16.5	14.8	10.8	7.6	5.1	(31)	
		MCDB	8.4	11.2	16.0	19.6	24.4	29.7	32.5	31.6	27.7	20.8	14.5	8.7	(32)	
	10%	WB	3.7	4.8	6.7	8.6	11.8	14.1	16.4	15.5	13.5	9.6	6.3	3.6	(33)	
		MCDB	6.9	9.3	14.0	17.4	22.6	28.5	31.6	30.4	26.9	19.2	12.1	6.8	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	11.8	12.6	15.3	16.1	17.5	19.9	21.8	22.5	22.0	19.8	15.6	12.2	(35)	
		MCDBR	14.9	16.1	20.2	22.5	22.8	23.5	23.8	24.7	25.4	24.7	20.4	13.7	(36)	
	5% WB	MCWBR	9.5	9.6	10.7	11.3	10.1	9.8	10.0	11.0	11.8	13.2	12.1	9.2	(37)	
		MCWBR	12.3	14.8	18.0	20.2	20.4	21.9	21.6	22.7	22.5	22.2	18.4	11.8	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.248	0.256	0.270	0.296	0.312	0.308	0.318	0.312	0.292	0.268	0.253	0.247	(40)	
		taud	2.620	2.626	2.586	2.488	2.469	2.514	2.495	2.497	2.553	2.628	2.630	2.622	(41)	
	Ebn at Noon		944	982	994	979	962	963	949	949	954	952	929	919	(42)	
		Edh at Noon	65	75	88	104	109	104	105	102	90	74	63	60	(43)	
(44) All-Sky Solar Radiation	RadAvg		2.06	3.06	4.37	5.72	6.85	7.99	7.88	6.98	5.67	3.93	2.49	1.70	(44)	
	RadStd		0.33	0.36	0.35	0.41	0.58	0.41	0.34	0.34	0.20	0.25	0.17	0.28	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (5 neighbors)	N/A	N/A	N/A	+0.70	N/A	N/A	N/A	N/A	+94	+62

Nomenclature: See separate page