

BLUE CANYON, CA, USA

WMO: 725845

Lat: 39.277N

Lon: 120.710W

Elev: 1608

StdP: 83.44

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 23225

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-6.1	-4.7	-21.6	0.7	6.0	-18.7	0.9	5.9	11.5	1.4	9.8	2.1	2.6	60	0.447

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.2	28.8	14.8	27.4	14.3	26.2	13.5	16.9	25.7	15.8	24.9	15.0	24.1	2.9	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
13.4	11.7	21.6	12.0	10.6	21.1	10.7	9.8	20.6	53.6	25.7	50.0	24.9	47.1	24.0	26.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.4	7.2	5.9	-8.3	30.9	1.8	1.3	-9.6	31.8	-10.7	32.6	-11.7	33.3	-13.0	34.2		
(5)			-9.7	18.6	1.8	2.0	-10.9	20.1	-12.0	21.2	-13.0	22.4	-14.2	23.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	11.1	4.7	3.7	5.3	6.9	11.6	16.7	21.2	20.8	17.9	12.5	7.1	3.9	
	DBStd	7.98	4.95	4.99	4.96	5.40	5.46	4.96	3.20	3.14	4.74	5.08	5.21	4.61	
	HDD10.0	1059	175	186	162	124	49	9	0	0	5	35	117	197	
	HDD18.3	2945	422	410	405	342	217	86	12	13	63	188	337	449	
	CDD10.0	1448	11	9	16	32	98	208	348	335	242	112	31	7	
	CDD18.3	290	0	0	0	0	7	36	101	89	51	7	0	0	
	CDH23.3	1312	0	0	0	0	20	163	506	411	196	16	0	0	
CDH26.7	192	0	0	0	0	1	24	82	61	24	1	0	0		
Wind	WSAvg	2.5	2.5	2.8	2.8	2.7	2.4	2.3	2.0	2.1	2.3	2.4	2.4	2.8	
Precipitation	PrecAvg	1787	311	261	240	133	53	21	3	15	33	108	272	293	
	PrecMax	3092	860	958	565	361	134	69	26	94	179	567	720	1056	
	PrecMin	596	19	21	42	17	2	0	0	0	0	0	26	9	
	PrecStd	526	208	208	141	96	38	21	7	26	47	116	177	230	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	17.1	17.1	18.6	21.4	25.9	29.6	30.5	30.1	29.5	25.6	20.4	16.5	
		MCWB	5.7	6.7	7.8	10.2	13.3	16.2	15.6	14.7	12.6	11.2	9.1	5.7	
	2%	DB	14.7	14.8	16.3	19.1	23.1	26.9	28.8	28.4	26.9	22.7	18.2	13.9	
		MCWB	4.8	5.8	7.2	9.2	12.3	14.5	15.5	14.3	12.7	10.2	8.1	4.6	
	5%	DB	13.1	12.9	14.4	17.2	21.3	25.1	27.4	27.1	25.6	21.0	16.1	12.1	
		MCWB	4.3	4.8	6.4	8.3	11.3	13.7	15.0	13.7	12.2	9.5	6.9	3.5	
	10%	DB	11.5	11.1	12.4	15.1	19.4	23.6	26.1	25.8	24.2	19.2	14.4	10.4	
		MCWB	3.6	3.9	5.3	7.2	10.2	12.8	14.2	13.1	11.9	8.7	6.1	3.0	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.2	8.4	9.7	11.8	15.2	17.7	18.4	17.1	20.3	12.8	10.5	7.9
			MCDB	11.5	13.8	16.0	18.2	22.4	26.7	27.6	27.0	21.6	21.1	18.0	11.0
2%		WB	6.7	7.0	8.3	10.3	13.5	16.0	17.0	15.7	15.5	11.6	9.1	6.6	
		MCDB	10.7	12.1	14.2	17.2	21.0	24.9	26.3	25.4	22.2	19.9	16.0	9.5	
5%		WB	5.7	5.8	7.2	9.1	12.3	14.8	16.0	14.9	13.9	10.7	7.9	5.6	
		MCDB	10.2	10.8	12.7	15.6	19.7	23.4	25.4	24.7	22.5	18.9	14.2	8.7	
10%		WB	4.9	4.8	6.1	7.9	11.1	13.6	15.2	14.0	12.8	9.8	7.0	4.6	
		MCDB	9.7	9.6	11.0	13.8	18.5	22.2	24.5	23.8	22.2	17.6	12.5	8.4	
Mean Daily Temperature Range		5% DB	MDBR	5.6	5.5	6.2	7.0	7.2	7.5	7.2	7.4	7.6	7.0	5.8	5.4
			MCDBR	7.0	7.0	7.8	8.7	8.4	7.9	7.3	7.5	7.8	7.6	6.7	7.0
	MCWBR		4.8	5.0	5.8	6.1	5.9	5.9	5.0	4.5	4.6	4.7	4.7	4.8	
	5% WB	MCDBR	6.1	6.2	7.2	8.2	8.2	7.6	7.0	7.1	7.6	7.1	6.4	5.6	
		MCWBR	4.7	5.0	5.6	6.1	6.0	6.1	5.1	4.7	5.2	4.8	4.8	4.7	
Clear-Sky Solar Irradiance	taub	0.276	0.275	0.296	0.306	0.312	0.305	0.307	0.294	0.299	0.285	0.268	0.282		
	taud	2.528	2.557	2.500	2.486	2.497	2.538	2.541	2.566	2.563	2.602	2.612	2.506		
	Ebn at Noon	912	963	968	971	965	968	963	972	952	938	920	874		
	Edh at Noon	74	82	97	105	106	102	101	96	90	78	67	70		
All-Sky Solar Radiation	RadAvg	2.27	3.13	4.41	5.83	7.11	8.27	8.25	7.42	5.96	4.17	2.65	1.94		
	RadStd	0.35	0.45	0.54	0.59	0.60	0.44	0.35	0.29	0.25	0.32	0.22	0.33		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.82	N/A	N/A	N/A	N/A	N/A	-118	-180	+110	+54
(47) Regional (26 neighbors)		+0.44	N/A	-1.10	N/A	N/A	N/A	-32	-97	+131	+53

Nomenclature: See separate page