

BURLEY, ID, USAWMO: **725867**Lat: **42.542N**Lon: **113.766W**Elev: **4154**StdP: **12.62**Time Zone: **-7.00 (NAM)**Period: **94-19**WBAN: **24133****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	4.6	10.2	-1.9	5.8	7.8	3.1	7.5	13.7	27.2	34.2	25.0	34.7	5.2	60	0.592

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	30.9	93.3	63.3	90.6	62.3	87.7	61.5	66.2	86.5	64.5	84.4	63.2	82.8	6.1	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
59.8	89.7	72.1	57.4	82.1	71.6	55.3	76.0	71.2	33.1	86.6	31.7	84.3	30.6	83.0	80.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 24.8	21.3	18.9	DB	-2.7	99.6	7.4	3.1	-8.0	101.8	-12.3	103.6	-16.5	105.3	-21.8	107.6	(4)
(5)			WB	-3.5	69.4	7.1	3.1	-8.6	71.7	-12.8	73.5	-16.8	75.3	-22.0	77.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	49.2	29.2	33.2	41.4	46.9	55.4	63.6	72.1	69.8	60.9	49.2	38.3	29.2	(6)	
	DBStd	16.42	9.09	8.38	6.99	6.87	7.47	6.76	4.70	5.10	6.99	7.74	8.62	8.88	(7)	
	HDD50	2685	644	471	279	138	32	3	0	0	7	108	357	646	(8)	
	HDD65	6271	1109	891	733	543	307	104	6	18	157	492	800	1111	(9)	
	CDD50	2384	0	0	11	46	199	409	684	612	333	83	7	0	(10)	
	CDD65	497	0	0	0	0	10	61	225	165	34	2	0	0	(11)	
	CDH74	7612	0	0	1	29	278	1066	3019	2375	779	65	0	0	(12)	
	CDH80	3199	0	0	0	4	65	375	1428	1064	253	10	0	0	(13)	
(14) Wind	WSAvg	8.1	8.6	9.3	9.7	10.1	8.4	7.7	6.4	6.2	6.4	7.5	8.1	8.8	(14)	
(15) Precipitation	PrecAvg	9.9	1.1	0.7	0.9	1.0	1.1	0.9	0.4	0.5	0.6	0.6	1.0	0.9	(15)	
	PrecMax	15.7	3.1	3.8	2.8	2.8	4.3	2.4	1.2	4.1	2.3	1.6	2.8	4.1	(16)	
	PrecMin	5.7	0.1	0.0	0.0	0.1	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.0	(17)	
	PrecStd	2.6	0.8	0.7	0.6	0.7	0.9	0.7	0.3	0.7	0.5	0.4	0.6	0.9	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	52.3	58.4	71.1	78.2	85.8	92.7	98.8	96.9	91.4	80.6	66.9	53.8	(19)	
		MCWB	42.6	44.7	48.9	53.2	58.7	63.3	66.8	65.1	61.9	56.1	49.3	43.8	(20)	
	2%	DB	47.5	53.1	65.2	72.1	81.2	88.3	94.3	92.9	86.4	74.7	60.8	49.1	(21)	
		MCWB	39.8	42.7	47.1	50.7	57.0	61.2	63.9	62.8	59.4	53.5	47.1	41.4	(22)	
	5%	DB	43.9	48.9	60.3	67.0	76.3	84.4	91.2	90.1	82.4	69.5	56.4	45.1	(23)	
		MCWB	37.8	40.6	44.9	49.0	55.3	60.1	62.9	61.9	57.9	51.5	44.5	39.2	(24)	
	10%	DB	40.7	45.1	55.3	62.1	71.9	80.6	88.1	86.5	78.6	64.5	51.8	41.4	(25)	
		MCWB	35.9	38.8	42.5	46.9	53.8	58.6	62.3	61.1	56.8	49.0	42.6	36.4	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	44.3	46.3	50.5	54.7	61.4	65.5	69.0	70.8	65.0	57.7	51.2	44.9	(27)	
		MCDB	50.1	55.8	65.8	75.0	80.3	88.0	90.7	90.1	83.5	77.6	62.0	51.8	(28)	
	2%	WB	40.7	43.7	48.1	51.8	58.4	63.1	66.8	65.4	62.3	55.0	48.0	42.0	(29)	
		MCDB	46.2	51.2	62.8	68.2	76.3	84.0	87.3	85.7	79.4	71.1	58.9	47.8	(30)	
	5%	WB	38.2	41.5	45.9	49.8	56.6	61.3	65.3	63.8	60.1	52.7	45.7	39.7	(31)	
		MCDB	43.1	47.8	58.3	64.8	73.4	81.2	85.1	84.0	76.8	66.2	54.6	44.6	(32)	
	10%	WB	36.2	39.2	43.7	47.7	54.5	59.4	63.9	62.2	58.1	50.2	43.3	37.0	(33)	
		MCDB	40.3	44.7	54.1	60.9	69.8	78.0	83.5	82.0	75.2	62.8	51.3	41.0	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	14.5	16.6	21.4	22.9	24.4	27.2	30.9	31.5	29.5	25.1	20.0	14.4	(35)	
		MCDBR	17.8	21.1	30.3	33.0	33.0	35.5	36.2	37.2	37.3	34.1	27.0	17.0	(36)	
		MCWBR	11.9	12.9	15.9	15.8	13.9	13.8	13.4	13.8	14.7	16.4	15.3	11.2	(37)	
	5% WB	MCDBR	16.1	19.3	27.7	29.6	29.7	33.4	32.1	32.4	31.3	29.7	24.7	15.9	(38)	
		MCWBR	11.2	12.3	15.1	14.7	12.8	13.3	12.5	12.8	12.7	14.8	14.4	10.9	(39)	
(40) Clear-Sky Solar Irradiance	taub		0.250	0.259	0.273	0.297	0.316	0.313	0.328	0.323	0.300	0.276	0.259	0.249	(40)	
	taud		2.535	2.580	2.572	2.498	2.476	2.525	2.493	2.487	2.549	2.598	2.593	2.557	(41)	
	Ebn at Noon		292	307	312	309	303	303	298	296	298	295	287	283	(42)	
	Edh at Noon		21	24	28	32	34	33	33	32	28	23	20	19	(43)	
(44) All-Sky Solar Radiation	RadAvg		567	847	1270	1715	2075	2414	2374	2067	1661	1118	686	450	(44)	
	RadStd		71	109	108	115	189	178	125	101	99	75	60	66	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	-1.26	-2.14	N/A	N/A	N/A	N/A
(47) Regional (8 neighbors)		N/A	N/A	N/A	N/A	-0.68	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page