

WOODLEY ISLAND, CA, USA

WMO: 725940

Lat: 40.8097N

Lon: 124.1600W

Elev: 20

StdP: 14.69

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 24213

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	33.1	35.4	26.9	20.9	41.8	30.0	24.0	40.5	26.1	57.3	22.4	53.9	3.2	90	0.539

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	8.6	68.9	59.1	66.4	58.9	64.5	58.2	61.6	66.2	60.3	64.5	59.3	63.2	9.4	340

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
59.6	76.3	63.2	58.4	73.1	62.0	57.4	70.3	61.0	27.4	66.5	26.6	64.8	25.9	63.3	67.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation	n=5 years		n=10 years		n=20 years		n=50 years			
Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(4) 20.4	18.2	16.3	DB	29.4	78.5	1.6	4.9	28.3	82.0	27.3	84.8	26.4	87.5	25.3	91.1	
(5)			WB	28.5	63.8	1.6	1.8	27.3	65.1	26.4	66.2	25.4	67.2	24.2	68.5	(4)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	51.8	47.8	47.7	48.5	49.7	52.1	54.9	56.7	57.3	55.9	53.5	49.9	47.4
	DBStd	5.43	5.11	4.76	4.13	3.80	3.38	2.70	2.60	2.90	3.88	4.25	4.75	5.42
	HDD50	534	103	94	78	49	16	1	0	0	1	14	59	119
	HDD65	4818	533	485	511	458	400	303	258	240	275	356	452	547
	CDD50	1193	35	29	32	41	81	148	207	226	177	123	57	37
	CDD65	1	0	0	0	0	0	0	0	0	1	0	0	0
	CDH74	23	0	0	0	1	1	2	1	2	11	5	0	0
	CDH80	3	0	0	0	0	0	0	0	0	3	0	0	0
Wind	WSAvg	6.0	5.6	6.1	6.9	7.1	6.9	6.8	5.8	5.2	4.9	4.9	5.1	6.1
Precipitation	PrecAvg	39.1	6.4	5.2	5.4	3.2	1.7	0.6	0.2	0.4	0.7	2.4	6.1	7.1
	PrecMax	67.2	13.9	13.9	11.2	11.3	6.1	3.1	1.1	3.4	3.3	6.8	16.6	23.3
	PrecMin	21.7	0.7	0.6	1.2	0.4	0.1	0.0	0.0	0.0	0.0	0.0	1.3	0.5
	PrecStd	10.1	3.3	2.8	2.7	2.3	1.2	0.6	0.2	0.7	0.8	1.8	3.8	4.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	64.0	65.2	64.4	67.2	69.0	67.6	68.0	69.8	73.7	72.4	66.5	63.1
		MCWB	54.2	54.9	53.5	55.1	59.2	58.6	60.2	61.1	61.1	57.8	55.7	54.9
	2%	DB	60.5	60.8	60.0	61.3	62.7	63.4	65.0	66.9	67.9	66.8	62.2	60.4
		MCWB	53.5	54.0	53.1	54.5	57.0	57.2	59.3	60.4	60.2	57.6	55.8	54.4
	5%	DB	58.2	58.0	57.5	58.0	59.7	61.6	63.2	65.0	65.3	63.5	59.8	58.2
		MCWB	53.0	52.4	52.0	52.9	55.1	56.5	58.3	59.6	59.0	57.2	55.1	53.6
	10%	DB	56.1	55.5	55.5	56.1	58.0	60.2	61.8	63.0	63.1	61.3	58.0	56.3
		MCWB	52.1	51.0	51.2	51.6	53.9	55.6	57.6	58.5	58.0	56.0	54.0	52.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	57.6	58.0	56.6	58.2	61.2	60.7	62.0	62.8	63.3	62.2	59.4	58.2
		MCDB	59.9	61.5	60.3	63.6	66.5	65.5	65.9	67.1	70.1	66.2	62.1	60.4
	2%	WB	55.7	55.7	54.7	55.3	57.8	58.8	60.1	61.3	61.3	59.9	57.8	56.5
		MCDB	58.5	59.4	57.8	59.3	61.6	62.0	63.8	65.8	66.0	64.1	60.4	58.7
	5%	WB	54.2	53.5	53.2	53.7	55.8	57.3	58.9	60.0	59.9	58.5	56.3	54.9
		MCDB	57.0	56.3	56.2	56.9	59.1	60.5	62.4	64.1	64.1	62.2	58.8	57.4
	10%	WB	52.6	51.8	51.8	52.4	54.4	56.2	57.8	58.9	58.7	56.8	54.7	53.0
		MCDB	55.4	54.7	54.7	55.6	57.3	59.3	61.1	62.5	62.4	60.3	57.2	55.5
Mean Daily Temperature Range	5% DB	MDBR	10.9	11.2	10.9	10.6	9.4	9.7	8.3	8.6	11.4	12.2	11.3	11.1
		MCDBR	13.1	14.5	13.6	14.2	12.6	12.5	11.1	12.8	16.9	16.9	13.5	11.6
		MCWBR	8.3	8.8	8.3	8.7	7.9	7.6	6.4	7.4	9.3	9.6	8.4	7.6
	5% WB	MCDBR	9.3	10.6	10.9	12.0	11.0	10.7	10.2	11.5	14.0	13.0	9.9	7.8
		MCWBR	7.3	7.6	7.7	8.1	7.5	7.0	6.1	7.0	8.3	8.8	7.3	6.7
Clear-Sky Solar Irradiance	taub	0.327	0.334	0.337	0.360	0.365	0.355	0.368	0.355	0.346	0.340	0.321	0.331	
	taud	2.535	2.521	2.531	2.428	2.453	2.492	2.461	2.501	2.503	2.550	2.582	2.521	
	Ebn at Noon	265	280	291	290	289	291	286	287	284	274	265	252	
	Edh at Noon	23	27	30	35	35	34	35	32	30	26	22	22	
All-Sky Solar Radiation	RadAvg	597	857	1241	1701	2077	2313	2271	1963	1621	1107	683	493	
	RadStd	93	121	126	152	133	133	112	99	84	93	74	91	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (12 neighbors)	N/A	N/A	N/A	+0.92	N/A	N/A	N/A	N/A	+212	+9

Nomenclature: See separate page