

CALIFORNIA REDWOOD COAST, CA, USA

WMO: 725945

Lat: 40.978N

Lon: 124.109W

Elev: 200

StdP: 14.59

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 24283

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	31.4	33.6	26.0	20.1	41.5	29.1	23.3	38.9	24.6	54.4	21.2	53.3	3.5	90	0.555

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	11.4	70.9	59.4	67.9	59.3	65.7	58.4	62.4	67.1	61.1	65.6	60.0	63.9	9.7	340

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
60.7	80.0	63.7	59.2	75.6	62.3	58.1	72.7	61.3	28.1	67.6	27.1	65.5	26.4	64.0	68.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 20.2	18.3	16.4	DB	27.9	81.9	2.1	5.0	26.4	85.5	25.2	88.5	24.0	91.3	22.5	95.0	(4)
(5)			WB	27.2	65.1	2.2	1.8	25.6	66.4	24.3	67.4	23.0	68.4	21.4	69.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	52.1	48.2	48.0	48.6	49.7	52.4	55.1	57.0	57.4	56.3	53.7	50.5	47.7		
	DBStd	5.53	5.29	5.00	4.20	3.93	3.64	2.89	2.65	2.73	3.83	4.52	5.06	5.46		
	HDD50	515	98	90	78	51	15	1	0	0	1	14	55	112		
	HDD65	4725	521	477	510	460	390	298	249	235	261	351	436	537		
	CDD50	1268	42	33	33	41	90	153	216	231	191	129	69	40		
	CDD65	3	0	0	0	0	1	0	0	0	1	1	0	0		
	CDH74	62	0	0	0	3	10	4	3	3	19	19	1	0		
	CDH80	13	0	0	0	0	3	0	0	1	4	5	0	0		
(14) Wind	WSAvg	6.1	6.1	6.5	6.9	6.9	6.8	6.8	5.8	5.2	4.9	5.0	5.5	6.4		
(15) Precipitation	PrecAvg	46.4	7.9	5.7	6.5	4.0	1.9	0.9	0.2	0.2	0.7	2.7	5.7	10.2		
	PrecMax	74.1	16.3	15.1	14.1	12.4	5.1	3.5	0.9	0.7	3.9	11.5	16.0	24.2		
	PrecMin	21.7	1.9	0.7	2.1	1.3	0.0	0.0	0.0	0.0	0.0	0.0	1.2	1.1		
	PrecStd	11.9	4.2	3.3	3.5	2.5	1.5	0.9	0.2	0.2	0.9	2.5	3.3	5.6		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	66.1	66.4	65.6	69.7	72.8	70.4	70.2	71.3	76.5	75.1	69.0	65.0		
		MCWB	54.0	55.1	54.5	56.4	60.3	60.2	60.7	61.2	61.8	58.0	56.8	54.1		
	2%	DB	61.6	61.7	61.1	62.2	63.8	64.9	66.1	67.8	69.5	68.4	63.6	61.4		
		MCWB	53.6	53.3	53.4	55.3	58.4	57.9	59.9	61.0	60.4	57.7	56.2	54.1		
	5%	DB	58.8	58.5	58.2	58.6	60.8	62.9	63.9	65.5	66.3	64.4	61.0	58.8		
		MCWB	53.2	52.9	52.9	53.4	55.9	57.4	58.8	60.0	59.4	56.8	55.1	53.6		
	10%	DB	56.6	55.9	56.0	56.5	58.7	61.0	62.4	63.3	63.9	61.8	58.5	56.6		
		MCWB	52.4	51.4	51.6	52.2	54.5	56.3	58.1	59.0	58.4	56.2	54.4	52.6		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	58.4	58.6	57.8	59.1	63.8	61.5	62.8	63.8	64.1	62.5	60.4	58.5		
		MCDB	60.8	62.8	61.1	64.7	67.6	67.5	66.4	67.6	71.2	67.9	63.9	60.9		
	2%	WB	56.3	56.1	55.3	56.1	58.9	59.5	60.9	62.0	62.0	60.3	58.5	56.8		
		MCDB	59.1	59.3	58.9	60.4	63.3	63.4	64.8	66.1	67.4	64.9	61.4	59.2		
	5%	WB	54.6	54.0	53.7	54.4	56.7	58.2	59.5	60.5	60.4	58.7	56.8	54.9		
		MCDB	57.4	56.9	56.7	57.5	60.1	61.7	63.0	64.2	64.9	62.9	59.5	57.5		
	10%	WB	53.1	52.1	52.3	53.0	55.0	57.0	58.4	59.3	59.1	57.0	55.0	53.3		
		MCDB	55.7	55.0	55.2	55.8	58.0	60.2	61.7	62.7	63.0	60.8	57.6	55.8		
(35) Mean Daily Temperature Range	5% DB	MDBR	14.3	14.2	13.9	13.4	12.2	12.5	10.5	11.4	14.6	16.3	14.6	14.4		
		MCDBR	16.9	17.6	16.8	16.7	16.3	15.9	13.4	16.0	19.6	21.2	16.5	16.4		
		MCWBR	10.7	10.9	11.0	10.9	10.5	10.0	8.1	9.7	11.3	12.2	10.3	10.9		
	5% WB	MCDBR	13.0	14.2	14.4	14.7	14.4	13.8	12.3	13.9	16.9	17.8	13.3	11.8		
		MCWBR	9.4	9.8	10.4	10.2	9.8	9.1	7.7	8.8	10.4	11.4	9.3	9.3		
(40) Clear-Sky Solar Irradiance	taub		0.323	0.328	0.333	0.355	0.361	0.352	0.364	0.353	0.342	0.336	0.317	0.325		
	taud		2.544	2.535	2.544	2.442	2.467	2.502	2.473	2.510	2.514	2.562	2.590	2.536		
	Ebn at Noon		266	282	292	291	290	292	287	288	285	275	266	254		
	Edh at Noon		23	27	29	35	35	34	34	32	30	26	22	22		
(44) All-Sky Solar Radiation	RadAvg		591	852	1234	1693	2079	2318	2290	1978	1624	1104	676	489		
	RadStd		93	122	128	155	133	135	111	102	86	96	75	91		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (15 neighbors)	N/A	N/A	N/A	+0.95	N/A	N/A	N/A	N/A	+202	+25

Nomenclature: See separate page