

CRESCENT CITY DEL NORTE, CA, USA

WMO: 725946

Lat: 41.780N

Lon: 124.237W

Elev: 17

StdP: 101.12

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 24286

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	1.7	2.6	-4.6	2.6	6.3	-2.3	3.1	6.5	15.3	11.4	14.0	11.5	2.0	90	0.596

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	5.2	19.9	15.1	18.6	14.9	17.6	14.3	16.3	18.5	15.6	17.7	15.0	17.0	3.8	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
15.2	10.8	17.0	14.6	10.4	16.3	14.0	10.0	15.8	45.4	18.5	43.6	17.7	41.9	17.0	20.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12.3	11.0	9.3	-0.3	25.3	1.2	2.3	-1.2	27.0	-1.9	28.3	-2.6	29.6	-3.5	31.3
			-1.5	17.7	1.3	1.1	-2.5	18.5	-3.3	19.1	-4.1	19.8	-5.0	20.6
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	11.2	9.2	9.0	9.3	9.9	11.4	12.6	13.7	14.2	13.6	12.2	10.5	8.9
	DBStd	2.76	2.46	2.41	2.01	1.83	1.67	1.44	1.34	1.46	1.80	2.20	2.27	2.52
	HDD10.0	229	44	43	38	22	4	1	0	0	0	4	21	52
	HDD18.3	2597	283	261	281	252	215	172	142	128	143	192	235	293
	CDD10.0	674	19	16	15	19	48	78	116	131	108	72	36	17
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH23.3	7	0	0	0	1	1	1	0	0	2	3	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
(14) Wind	WSAvg	3.7	4.1	4.2	4.4	4.2	3.8	3.9	3.1	2.8	3.1	3.4	3.7	4.3
(15) Precipitation	PrecAvg	1905	300	238	235	176	97	44	9	15	28	119	261	382
	PrecMax	2937	598	543	485	404	213	146	42	53	137	250	641	888
	PrecMin	1149	93	68	96	43	0	2	0	0	0	9	79	114
	PrecStd	456	146	128	108	97	57	38	11	15	32	70	132	190
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	17.5	17.7	16.9	18.9	20.1	18.8	19.5	20.3	21.3	22.8	18.1	16.7
		MCWB	10.7	11.3	11.3	12.9	14.4	15.4	15.8	16.4	15.8	14.0	12.8	11.4
	2%	DB	15.0	15.0	14.6	15.0	16.4	17.2	18.0	19.0	19.0	18.7	16.2	14.8
		MCWB	10.8	11.1	11.2	11.7	13.4	14.0	15.0	15.9	15.4	13.4	12.3	11.7
	5%	DB	13.7	13.6	13.4	13.8	15.1	16.2	17.3	17.9	17.9	17.0	15.0	13.7
		MCWB	10.9	10.8	10.8	11.1	12.7	13.5	14.6	15.2	14.7	13.2	12.1	11.3
	10%	DB	12.8	12.6	12.6	12.9	14.1	15.4	16.4	17.2	17.1	15.8	14.0	12.7
		MCWB	10.7	10.3	10.4	10.6	11.9	13.0	14.0	14.7	14.2	13.0	11.7	10.8
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	13.3	13.4	13.0	13.9	15.5	15.8	16.8	17.0	17.0	15.9	14.8	14.0
		MCDB	14.8	15.5	14.8	17.4	18.3	18.0	18.6	19.1	19.4	18.5	16.1	14.7
	2%	WB	12.3	12.3	12.1	12.4	14.0	14.7	15.6	16.3	16.0	15.0	13.8	13.0
		MCDB	13.5	13.8	13.3	14.0	16.1	16.4	17.5	18.4	18.1	17.1	15.0	14.0
	5%	WB	11.8	11.5	11.5	11.7	13.0	14.0	14.9	15.5	15.3	14.2	13.0	12.1
		MCDB	12.9	12.9	12.7	13.1	14.9	15.7	16.8	17.6	17.2	16.1	14.1	12.9
	10%	WB	11.1	10.7	10.8	11.1	12.3	13.4	14.3	14.9	14.7	13.5	12.3	11.3
		MCDB	12.5	12.0	12.2	12.5	13.8	15.1	16.1	16.8	16.5	15.3	13.4	12.4
(35) Mean Daily Temperature Range	5% DB	MDBR	6.2	6.1	6.0	5.8	5.4	5.6	5.0	5.2	6.2	6.7	6.3	6.1
		MCDBR	7.3	7.4	6.8	6.8	6.6	6.4	6.0	6.7	7.8	8.9	7.5	6.7
	5% WB	MCWBR	4.8	4.7	4.8	4.7	4.4	4.3	3.8	4.2	4.9	5.4	4.9	4.4
		MCWBR	5.3	5.7	5.6	5.8	5.9	5.8	5.6	6.4	7.1	7.4	5.5	4.5
(40) Clear-Sky Solar Irradiance	taub	taub	0.321	0.321	0.327	0.352	0.357	0.348	0.353	0.349	0.341	0.330	0.315	0.319
		taud	2.560	2.571	2.576	2.462	2.491	2.524	2.516	2.540	2.534	2.589	2.604	2.569
	Ebn at Noon	Ebn at Noon	835	894	927	919	917	923	915	911	897	871	837	804
		Edh at Noon	70	80	89	107	106	103	103	98	92	77	66	65
(44) All-Sky Solar Radiation	RadAvg	RadAvg	1.75	2.56	3.74	5.19	6.46	7.15	7.18	6.11	4.95	3.28	1.98	1.44
	RadStd	RadStd	0.27	0.36	0.39	0.47	0.39	0.43	0.35	0.36	0.29	0.30	0.23	0.26

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (16 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+2

Nomenclature: See separate page