

SEXTON SUMMIT, OR, USA

WMO: 725975

Lat: 42.600N

Lon: 123.366W

Elev: 3832

StdP: 12.77

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 24235

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	22.3	24.6	7.0	9.1	41.1	11.2	11.2	40.7	27.0	39.8	25.3	39.0	6.9	110	0.587

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	21.4	84.7	61.5	81.4	60.4	78.4	59.3	64.0	80.3	62.2	78.0	60.6	75.5	4.3	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
57.4	81.0	71.6	55.6	75.9	68.9	54.3	72.3	66.7	31.1	80.2	29.7	77.9	28.6	75.6	70.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 22.5	19.9	18.2	18.6	90.5	3.8	3.5	15.8	92.9	13.6	95.0	11.5	96.9	8.7	99.4		
(5)			17.5	67.3	4.1	1.6	14.5	68.4	12.1	69.3	9.9	70.2	6.9	71.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	48.6	38.2	37.6	39.4	42.9	50.4	56.3	65.0	65.1	60.0	50.0	41.3	36.7	(6)
(7)		DBStd	13.02	7.47	7.40	7.57	8.56	9.03	8.20	6.98	7.13	9.06	8.44	7.86	6.91	(7)
(8)		HDD50	2277	373	354	341	252	108	29	1	1	16	108	281	413	(8)
(9)		HDD65	6235	831	768	794	665	461	281	86	89	203	471	710	876	(9)
(10)		CDD50	1783	7	5	12	38	121	219	467	468	315	107	22	2	(10)
(11)		CDD65	266	0	0	0	1	9	21	87	91	52	5	0	0	(11)
(12)		CDH74	1843	0	0	0	3	72	174	647	629	302	16	0	0	(12)
(13)		CDH80	436	0	0	0	0	13	40	162	158	62	1	0	0	(13)
(14)	Wind	WSAvg	8.7	11.2	9.9	9.0	7.7	7.1	7.3	7.7	7.2	7.3	8.5	10.2	11.2	(14)
(15)	Precipitation	PrecAvg	36.9	5.6	4.3	4.1	2.2	1.7	0.9	0.3	0.7	1.2	2.9	6.8	6.1	(15)
(16)		PrecMax	58.5	19.0	10.4	9.0	7.6	7.2	2.8	1.8	4.2	4.3	9.8	24.1	20.0	(16)
(17)		PrecMin	14.8	0.2	0.3	0.3	0.7	0.1	0.0	0.0	0.0	0.0	0.0	0.7	0.5	(17)
(18)		PrecStd	11.4	4.6	2.6	2.3	1.5	1.7	0.6	0.4	1.1	1.2	2.3	4.8	4.0	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	59.8	59.8	63.7	73.4	81.3	85.3	89.5	89.8	85.8	76.0	64.1	56.4	(19)
(20)			MCWB	42.7	46.4	49.5	54.1	58.5	62.9	64.2	62.2	58.7	54.2	48.7	41.2	(20)
(21)		2%	DB	55.1	55.1	58.7	66.8	74.7	79.0	84.4	84.1	81.3	70.4	60.0	52.1	(21)
(22)			MCWB	41.3	43.9	46.8	51.1	56.8	60.2	63.1	61.1	57.4	52.0	46.7	39.4	(22)
(23)		5%	DB	51.5	51.5	54.7	61.6	69.7	74.5	80.7	80.5	77.5	66.6	56.3	48.8	(23)
(24)			MCWB	39.7	42.2	44.4	48.9	54.6	57.9	61.6	60.3	56.4	50.4	45.4	39.6	(24)
(25)		10%	DB	48.6	48.3	51.0	56.5	64.8	70.4	77.4	77.1	73.4	62.8	52.9	46.4	(25)
(26)			MCWB	39.7	40.8	43.0	46.2	52.2	56.1	60.3	59.1	55.3	49.0	44.0	39.9	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	48.2	48.5	51.0	55.3	60.6	65.2	67.0	65.7	62.2	56.9	52.9	47.8	(27)
(28)			MCD B	50.3	54.1	61.1	68.8	77.3	80.8	84.2	82.5	78.8	69.8	57.5	48.3	(28)
(29)		2%	WB	45.6	46.4	48.2	52.2	58.1	61.4	64.5	63.3	59.9	54.7	49.9	45.7	(29)
(30)			MCD B	48.7	51.6	56.0	64.4	72.3	76.6	81.0	80.0	75.1	65.0	54.4	46.6	(30)
(31)		5%	WB	43.3	44.3	46.1	49.7	55.5	59.1	62.8	61.6	58.4	52.7	47.9	43.5	(31)
(32)			MCD B	47.6	49.2	52.4	60.2	67.4	72.6	78.3	77.8	73.1	62.2	52.8	45.5	(32)
(33)		10%	WB	41.5	42.2	44.0	47.2	53.0	56.8	61.2	60.0	56.7	50.8	46.0	41.5	(33)
(34)			MCD B	46.0	46.9	49.4	55.3	63.2	69.0	75.8	74.9	70.8	59.6	50.9	44.6	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	8.2	9.3	11.6	14.8	17.9	19.9	21.4	20.4	16.8	12.7	8.9	7.9	(35)
(36)			MCDBR	11.5	13.5	16.8	21.2	22.3	23.1	22.2	21.5	19.1	16.1	12.7	10.8	(36)
(37)			MCWBR	6.4	8.0	10.6	12.1	11.9	11.9	11.0	9.9	9.0	8.8	6.9	6.5	(37)
(38)		5% WB	MCDBR	9.0	10.9	15.0	20.0	21.5	22.4	21.6	20.9	18.1	14.8	10.7	8.9	(38)
(39)			MCWBR	7.2	7.4	10.0	11.9	11.8	12.0	11.0	10.1	8.9	9.0	7.3	7.8	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.269	0.270	0.273	0.289	0.295	0.294	0.297	0.295	0.283	0.279	0.266	0.273	(40)	
(41)		taud	2.650	2.662	2.679	2.599	2.614	2.635	2.633	2.639	2.658	2.668	2.671	2.629	(41)	
(42)		Ebn at Noon	287	303	313	312	311	309	307	306	305	295	285	274	(42)	
(43)		Edh at Noon	20	23	25	29	30	29	29	28	25	22	19	18	(43)	
(44)	All-Sky Solar Radiation	RadAvg	525	789	1139	1578	2026	2313	2484	2160	1662	1051	581	419	(44)	
(45)		RadStd	73	110	122	147	164	148	96	106	108	104	71	75	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.56	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+169	N/A
(47) Regional (14 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+7

Nomenclature: See separate page