

LAKE COUNTY AP, OR, USA

WMO: 725976

Lat: 42.167N

Lon: 120.400W

Elev: 4728

StdP: 12.35

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 94285

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 12	(b) 2.5	(c) 8.9	(d) -7.7	(e) 4.3	(f) 9.9	(g) 0.7	(h) 6.8	(i) 10.2	(j) 27.6	(k) 38.3	(l) 24.9	(m) 35.2	(n) 4.0	(o) 350	(p) 0.647

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 36.0	(c) 90.5	(d) 59.1	(e) 88.1	(f) 58.2	(g) 84.3	(h) 56.8	(i) 61.3	(j) 85.1	(k) 59.8	(l) 82.6	(m) 58.4	(n) 80.7	(o) 7.9	(p) 190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
53.4	72.4	68.2	50.2	64.2	66.6	47.8	58.6	65.9	29.5	84.8	28.3	82.4	27.3	81.6	68.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.5	20.1	18.1	-6.2	95.2	5.4	3.5	-10.1	97.7	-13.3	99.8	-16.3	101.8	-20.3	104.3
			-6.9	64.1	7.3	1.9	-12.1	65.5	-16.4	66.6	-20.5	67.6	-25.8	69.0
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	45.5	29.2	31.9	37.4	42.2	50.4	58.2	66.7	64.0	56.8	45.1	35.4	27.9		
	DBStd	14.92	8.16	7.46	6.89	6.95	7.36	7.36	5.78	5.45	6.89	6.74	7.97	8.51		
	HDD50	3220	643	508	391	248	87	17	0	1	22	178	440	685		
	HDD65	7291	1108	928	855	684	453	223	47	83	255	616	889	1150		
	CDD50	1585	0	0	1	14	100	263	518	435	225	28	1	0		
	CDD65	181	0	0	0	0	1	19	101	52	8	0	0	0		
	CDH74	5466	0	0	0	3	113	607	2295	1730	676	42	0	0		
	CDH80	1998	0	0	0	0	14	168	987	643	178	8	0	0		
(14) Wind	WSAvg	8.0	7.3	8.0	8.8	9.1	8.5	8.3	7.5	7.6	7.5	7.7	7.6	7.8		
(15) Precipitation	PrecAvg	15.7	2.0	1.5	1.5	1.3	1.5	1.1	0.4	0.4	0.6	1.1	2.0	2.2		
	PrecMax	24.1	5.8	4.7	3.9	3.4	4.4	4.2	1.4	3.0	2.7	6.6	4.6	9.0		
	PrecMin	9.8	0.2	0.1	0.3	0.2	0.2	0.0	0.0	0.0	0.0	0.0	0.2	0.0		
	PrecStd	3.7	1.4	1.0	0.8	0.7	1.0	1.0	0.4	0.6	0.7	1.1	1.3	1.7		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	52.1	58.2	65.8	73.1	81.7	90.3	95.6	92.6	88.4	80.9	64.5	48.5		
		MCWB	41.9	44.2	46.6	50.8	55.9	60.1	61.7	59.3	56.5	53.2	47.2	41.0		
	2%	DB	46.3	52.4	60.9	69.7	77.1	84.1	91.3	89.8	84.2	72.5	60.5	45.7		
		MCWB	39.5	41.2	44.9	50.1	54.3	57.5	59.8	58.2	55.0	50.4	45.7	39.4		
	5%	DB	43.3	46.4	55.4	63.7	72.9	81.1	89.6	87.3	81.5	68.4	54.0	43.0		
		MCWB	37.4	38.6	43.1	46.9	52.7	56.1	59.1	57.3	54.1	48.8	43.1	37.8		
	10%	DB	39.2	43.2	51.7	57.7	68.3	77.0	85.9	83.6	78.7	63.4	48.2	39.2		
		MCWB	35.1	36.6	42.1	44.1	50.8	54.7	58.0	56.3	53.3	46.4	40.8	35.3		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	44.3	45.7	48.6	53.1	58.7	62.1	64.4	61.8	59.4	54.2	49.6	43.6		
		MCDB	48.5	56.1	62.3	68.5	76.7	84.6	87.5	86.4	77.8	75.7	62.8	46.8		
	2%	WB	40.6	42.8	46.2	50.2	56.1	59.5	62.0	59.8	57.0	51.8	46.3	40.5		
		MCDB	45.9	50.9	57.9	66.8	73.9	80.2	86.2	83.7	79.1	70.7	56.9	44.5		
	5%	WB	38.1	39.9	44.1	47.9	53.9	57.4	60.5	58.4	55.3	49.7	44.1	38.4		
		MCDB	42.0	45.9	54.1	62.2	70.2	77.3	84.2	82.1	78.2	65.9	52.8	41.9		
	10%	WB	35.9	37.4	42.1	45.4	51.6	55.6	59.2	57.2	53.8	47.5	41.6	36.3		
		MCDB	39.4	42.1	50.8	57.4	66.3	74.6	82.3	80.6	76.8	61.9	48.1	39.3		
(35) Mean Daily Temperature Range	5% DB	MDBR	17.2	18.9	21.0	23.7	26.8	30.5	36.0	37.3	36.1	31.2	22.4	18.1		
		MCDBR	22.1	25.5	31.2	35.3	35.7	36.5	39.0	41.0	42.7	42.0	34.2	21.5		
	5% WB	MCWBR	15.7	16.9	18.7	19.6	18.0	16.5	15.9	17.4	20.2	22.9	21.5	15.7		
		MCWBR	19.3	22.9	28.2	33.6	33.1	34.4	36.5	37.3	39.9	38.1	30.0	16.4		
(40) Clear-Sky Solar Irradiance	taub		0.264	0.274	0.274	0.302	0.305	0.296	0.306	0.303	0.292	0.289	0.267	0.264		
		taud	2.546	2.558	2.597	2.508	2.541	2.596	2.567	2.557	2.574	2.574	2.602	2.547		
	Ebn at Noon		287	301	313	308	307	309	305	304	301	291	285	277		
		Edh at Noon	22	25	27	32	32	30	31	30	28	24	20	20		
(44) All-Sky Solar Radiation	RadAvg		599	886	1269	1714	2097	2456	2516	2200	1740	1154	681	479		
	RadStd		84	108	117	151	184	130	105	110	89	90	69	86		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (7 neighbors)		N/A	N/A	-2.18	+1.12	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page