

WATERVILLE LAFLEUR, ME, USA

WMO: 726073

Lat: 44.533N

Lon: 69.667W

Elev: 95

StdP: 100.19

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 14615

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-21.0	-17.7	-29.0	0.3	-17.9	-26.2	0.3	-15.9	11.0	-5.8	9.6	-4.8	2.2	290	0.520

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.6	30.0	21.9	28.0	20.8	27.0	19.9	23.2	28.2	22.1	26.7	21.0	24.9	3.2	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.6	16.5	26.0	20.9	15.7	24.9	19.2	14.1	23.3	69.2	28.4	65.0	26.5	61.2	25.3	28.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4)	8.9	7.8	6.8	DB	-24.1	32.8	3.4	1.0	-26.5	33.5	-28.5	34.1	-30.4	34.7	-32.9	35.4
(5)				WB	-24.4	25.2	3.0	1.2	-26.6	26.1	-28.3	26.8	-30.0	27.5	-32.1	28.4

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	7.3	-7.1	-5.4	-0.3	6.2	12.6	17.1	20.4	19.6	15.5	9.0	2.7	-3.4	(6)
(7)		DBStd	10.50	6.32	5.74	5.20	4.12	3.65	3.49	2.75	2.75	3.91	4.12	4.76	5.30	(7)
(8)		HDD10.0	2137	531	431	322	127	14	1	0	0	3	69	223	417	(8)
(9)		HDD18.3	4203	789	664	578	363	183	63	11	17	102	291	468	674	(9)
(10)		CDD10.0	1156	0	0	2	14	94	215	323	298	168	38	4	0	(10)
(11)		CDD18.3	182	0	0	0	0	4	27	76	58	17	1	0	0	(11)
(12)		CDH23.3	1458	0	0	3	7	77	246	574	416	130	5	0	0	(12)
(13)		CDH26.7	352	0	0	1	1	21	58	141	97	33	0	0	0	(13)
(14)	Wind	WSAvg	2.6	2.9	3.0	3.4	3.3	2.6	2.2	2.0	1.9	2.1	2.6	2.8	2.8	(14)
(15)	Precipitation	PrecAvg	1093	78	63	92	93	85	98	88	98	114	106	99	(15)	
(16)		PrecMax	1567	149	140	160	217	192	202	165	193	254	335	171	175	(16)
(17)		PrecMin	671	12	13	30	11	10	36	42	11	26	21	40	29	(17)
(18)		PrecStd	204	37	28	30	52	43	47	37	46	53	75	36	38	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.1	10.1	17.8	23.1	29.1	31.4	32.3	32.0	30.9	23.8	17.5	12.1	(19)
(20)		MCWB	10.3	6.8	11.3	13.8	18.7	22.1	24.1	22.7	22.2	17.3	13.8	10.1	(20)	
(21)		2%	DB	7.2	7.4	12.2	18.8	25.8	28.0	29.8	29.0	27.1	20.6	14.8	8.8	(21)
(22)		MCWB	5.4	4.5	7.2	11.2	16.1	20.3	22.4	21.5	20.3	15.2	12.1	7.1	(22)	
(23)		5%	DB	3.9	4.7	8.9	16.1	22.5	26.3	27.9	27.4	24.1	17.7	12.5	6.3	(23)
(24)		MCWB	2.0	2.1	4.7	9.4	14.6	18.4	21.1	20.5	18.5	13.9	10.1	3.8	(24)	
(25)		10%	DB	2.0	2.7	7.0	13.0	20.0	24.0	27.0	25.9	22.3	16.0	9.9	3.7	(25)
(26)		MCWB	0.0	0.5	3.3	7.6	13.0	17.5	20.2	19.3	17.4	12.4	7.4	1.5	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.4	7.8	12.4	15.7	20.3	23.6	25.1	24.1	23.2	19.0	15.2	10.8	(27)
(28)		MCDWB	11.1	8.9	16.5	20.5	26.8	29.4	30.3	29.4	29.1	21.4	16.9	11.4	(28)	
(29)		2%	WB	5.8	5.1	8.0	13.0	17.8	21.7	23.4	22.7	21.3	16.8	12.6	7.6	(29)
(30)		MCDWB	6.9	7.1	10.2	16.7	23.1	26.7	28.1	27.3	25.2	19.2	13.9	8.1	(30)	
(31)		5%	WB	2.3	2.7	5.2	10.5	16.0	20.3	22.3	21.5	19.8	14.9	10.3	4.1	(31)
(32)		MCDWB	4.0	4.4	8.3	14.2	20.8	24.3	26.8	25.7	22.9	17.5	12.2	5.8	(32)	
(33)		10%	WB	0.0	0.5	3.4	8.4	14.3	18.8	21.2	20.5	18.4	12.6	7.8	1.8	(33)
(34)		MCDWB	1.6	2.5	6.1	12.8	18.6	22.5	25.0	24.2	21.2	15.0	9.3	3.4	(34)	
(35)	Mean Daily Temperature Range	MDBR	9.2	9.6	9.3	10.1	11.2	10.7	10.6	10.8	10.7	9.7	8.0	8.3	(35)	
(36)		5% DB	MCDBR	10.1	10.5	12.3	15.1	16.0	14.0	12.6	12.8	13.0	12.3	10.4	10.4	(36)
(37)		MCWBR	9.6	8.7	8.3	8.9	8.8	7.8	6.6	6.7	7.6	8.2	8.6	9.3	(37)	
(38)		5% WB	MCDBR	10.4	10.1	11.2	13.2	13.7	11.8	11.0	11.1	11.2	11.2	9.7	10.2	(38)
(39)		MCWBR	10.2	8.8	8.4	9.1	8.5	7.5	6.4	6.6	7.3	8.6	8.9	9.7	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.272	0.287	0.320	0.349	0.372	0.415	0.429	0.402	0.363	0.328	0.311	0.282	(40)	
(41)		taud	2.419	2.354	2.398	2.407	2.387	2.270	2.242	2.317	2.413	2.515	2.521	2.476	(41)	
(42)		Ebn at Noon	860	905	917	914	898	856	838	849	859	850	806	812	(42)	
(43)		Edh at Noon	72	92	102	111	117	132	134	120	101	79	67	63	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.64	2.52	3.72	4.51	5.07	5.48	5.68	5.15	4.17	2.62	1.67	1.25	(44)	
(45)		RadStd	0.13	0.21	0.21	0.50	0.67	0.46	0.46	0.30	0.26	0.24	0.15	0.11	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (37 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page