

BERLIN, NH, USA

WMO: 726160

Lat: 44.576N

Lon: 71.179W

Elev: 353

StdP: 97.16

Time Zone: -5.00 (NAE)

Period: 95-19

WBAN: 94700

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-27.0	-23.2	-30.9	0.2	-25.8	-27.7	0.3	-22.2	8.8	-5.6	7.9	-7.6	0.6	290	0.553

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.9	29.9	20.7	28.2	19.6	27.0	19.0	22.2	27.5	21.2	26.2	20.2	24.8	2.7	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.6	15.9	24.6	19.3	14.7	23.6	18.5	14.0	22.8	66.4	27.3	63.0	26.3	59.6	24.9	25.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.5	6.5	5.5	DB	-31.9	32.5	3.4	1.4	-34.4	33.5	-36.3	34.4	-38.2	35.2	-40.7	36.2	(4)
(5)			WB	-31.6	23.7	2.8	0.9	-33.6	24.3	-35.3	24.8	-36.8	25.3	-38.9	25.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	5.2	-9.6	-8.1	-3.2	4.2	11.0	15.9	18.5	17.7	13.8	7.0	0.7	-5.8	(6)	
	DBStd	11.07	7.13	6.48	6.16	4.52	4.26	3.64	3.00	3.00	4.16	4.49	5.16	6.21	(7)	
	HDD10.0	2647	608	508	411	183	38	2	0	0	11	117	279	489	(8)	
	HDD18.3	4877	867	741	668	423	231	92	35	48	144	352	528	748	(9)	
	CDD10.0	912	0	0	1	9	69	178	264	239	126	23	2	0	(10)	
	CDD18.3	100	0	0	0	0	3	18	41	29	9	0	0	0	(11)	
	CDH23.3	1469	0	0	2	13	103	283	539	376	146	8	0	0	(12)	
	CDH26.7	348	0	0	0	2	24	72	138	79	33	0	0	0	(13)	
(14) Wind	WSAvg	1.8	1.9	2.0	2.2	2.3	2.0	1.6	1.3	1.2	1.3	1.7	1.8	1.8	(14)	
(15) Precipitation	PrecAvg	951	60	56	62	77	84	95	86	101	79	87	96	77	(15)	
	PrecMax	1366	178	166	131	141	215	167	136	198	179	157	239	224	(16)	
	PrecMin	785	4	5	11	32	24	37	36	25	19	32	32	22	(17)	
	PrecStd	132	43	33	26	36	44	38	28	44	41	39	46	44	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.0	10.1	17.4	25.1	29.5	31.6	31.8	31.1	30.3	24.3	17.8	10.9	(19)	
		MCWB	7.8	5.8	11.4	14.5	18.3	21.2	22.6	21.6	21.2	16.3	13.2	8.0	(20)	
	2%	DB	5.9	6.4	11.7	20.9	26.4	28.8	29.8	28.7	27.2	21.1	14.8	7.2	(21)	
		MCWB	3.7	3.1	6.3	11.7	15.7	19.4	21.2	20.3	19.2	14.4	10.7	5.3	(22)	
	5%	DB	2.6	3.4	8.1	17.0	23.3	26.9	28.1	27.2	24.8	17.8	11.9	4.3	(23)	
		MCWB	1.1	1.1	4.1	9.7	14.3	18.5	20.0	19.5	18.1	13.1	8.7	2.8	(24)	
	10%	DB	0.9	1.6	5.8	13.3	20.9	24.5	26.6	25.6	22.3	15.2	8.6	2.5	(25)	
		MCWB	-0.3	0.0	2.4	7.3	13.3	17.0	19.2	18.6	16.7	11.8	6.1	1.1	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.0	7.3	11.8	16.0	19.6	22.5	23.9	22.9	21.8	18.4	14.8	8.7	(27)	
		MCDB	9.6	9.6	16.8	22.5	26.5	28.4	29.4	27.7	27.8	22.0	17.0	9.8	(28)	
	2%	WB	3.8	3.7	7.3	13.2	17.8	21.3	22.5	21.7	20.4	15.7	11.8	5.4	(29)	
		MCDB	5.4	5.9	9.8	19.5	23.4	26.9	27.7	26.5	25.5	19.2	14.1	6.8	(30)	
	5%	WB	1.3	1.6	4.5	10.5	16.0	19.9	21.4	20.7	19.1	13.9	8.6	3.1	(31)	
		MCDB	2.5	3.1	7.7	15.3	21.1	24.4	26.3	25.0	23.2	17.2	11.0	4.2	(32)	
	10%	WB	-0.5	0.1	2.7	8.1	14.4	18.4	20.2	19.7	17.7	12.0	6.5	1.2	(33)	
		MCDB	0.9	1.6	5.4	12.6	19.0	22.5	24.7	23.8	21.1	14.8	8.4	2.2	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	12.0	13.1	12.3	12.8	14.5	13.8	13.9	14.1	14.1	12.2	10.1	10.1	(35)	
		MCDBR	12.8	13.9	15.3	20.9	20.4	17.5	16.2	16.0	17.1	17.4	15.1	11.1	(36)	
	5% WB	MCWBR	11.2	11.3	10.7	12.2	10.9	9.0	8.3	8.4	9.8	11.4	11.3	9.8	(37)	
		MCWBR	12.5	12.2	13.3	18.0	16.1	13.7	14.0	13.7	14.6	14.7	12.9	10.5	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.253	0.274	0.308	0.341	0.363	0.407	0.415	0.390	0.355	0.319	0.301	0.266	(40)	
		taud	2.421	2.332	2.352	2.406	2.406	2.276	2.261	2.329	2.423	2.531	2.517	2.453	(41)	
	Edn at Noon	Edn at Noon	887	921	930	922	906	863	851	861	868	861	819	832	(42)	
		Edh at Noon	71	94	107	111	114	131	131	118	99	78	66	63	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	1.48	2.35	3.53	4.35	4.91	5.37	5.44	4.94	4.03	2.43	1.53	1.12	(44)	
	RadStd	RadStd	0.17	0.25	0.22	0.51	0.62	0.46	0.46	0.29	0.28	0.24	0.18	0.09	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.52	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+116	N/A
(47) Regional (49 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+64	N/A

Nomenclature: See separate page