

AUGUSTA, ME, USA

WMO: 726185

Lat: 44.316N

Lon: 69.797W

Elev: 351

StdP: 14.51

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 14605

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-3.1	1.7	-17.2	2.2	-0.6	-12.6	2.8	3.9	26.0	22.3	22.8	20.0	8.5	300	0.548

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.8	86.8	70.9	83.6	69.1	80.9	67.4	73.5	82.4	71.7	79.7	70.0	77.0	8.0	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
70.8	115.0	77.3	69.2	108.7	75.5	67.7	102.9	73.9	37.3	82.7	35.7	79.6	34.2	76.8	80.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 20.7	18.5	16.6	DB	-9.1	92.2	4.9	2.5	-12.6	94.0	-15.5	95.5	-18.2	96.9	-21.8	98.7	(4)
(5)			WB	-9.9	76.5	4.6	1.7	-13.3	77.7	-16.0	78.7	-18.6	79.6	-22.0	80.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	46.2	20.3	23.3	31.9	43.9	55.0	64.1	70.1	68.7	61.2	49.5	38.0	27.3
	DBStd	18.91	11.00	10.00	9.20	7.45	6.89	6.67	4.96	4.82	6.70	7.28	8.42	9.40
	HDD50	3643	920	747	565	210	26	1	0	0	2	99	369	704
	HDD65	7268	1385	1167	1026	632	319	96	12	19	151	482	810	1169
	CDD50	2271	0	0	3	28	181	423	623	581	339	84	9	0
	CDD65	422	0	0	0	0	10	68	170	135	37	2	0	0
	CDH74	3073	0	0	6	12	151	550	1198	883	260	13	0	0
	CDH80	783	0	0	1	1	41	141	312	219	67	1	0	0
Wind	WSAvg	7.4	8.0	8.2	8.8	8.5	7.5	6.7	6.1	5.9	6.3	7.3	7.6	7.7
Precipitation	PrecAvg	41.3	2.9	2.7	3.5	3.6	3.6	3.5	3.1	3.2	3.4	3.9	4.2	3.6
	PrecMax	55.2	9.0	6.0	6.7	9.0	10.8	10.3	6.9	9.1	11.3	8.1	10.5	12.6
	PrecMin	25.8	0.3	0.3	0.6	0.3	0.6	0.5	0.4	0.2	0.9	1.1	1.3	0.9
	PrecStd	7.4	1.9	1.2	1.5	1.7	2.1	1.8	1.5	1.6	1.9	1.9	1.9	2.5
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	51.5	50.0	64.8	74.8	85.5	89.3	90.6	89.7	87.7	75.5	63.2	53.9
		MCWB	50.7	44.5	52.7	56.7	64.6	71.2	73.7	71.7	71.6	62.1	57.0	50.5
	2%	DB	45.3	45.2	54.1	66.0	77.9	84.0	86.4	85.5	80.6	69.0	58.4	49.0
		MCWB	42.6	40.7	44.8	51.0	61.2	69.4	71.4	70.2	67.9	59.0	53.5	45.7
	5%	DB	39.8	41.0	48.5	60.6	72.8	80.1	83.4	82.0	76.2	64.4	54.7	44.6
		MCWB	36.5	36.5	40.9	48.0	58.5	66.2	69.5	68.3	65.4	57.4	50.6	41.0
	10%	DB	35.2	37.3	44.3	56.3	68.1	76.6	80.7	79.0	72.4	61.1	50.6	40.0
		MCWB	31.7	33.6	38.2	46.0	55.7	64.0	67.8	66.7	63.2	55.2	46.3	36.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	51.0	46.5	54.3	59.7	68.2	74.8	76.4	75.1	73.3	65.9	59.4	52.1
		MCDB	51.4	48.2	62.5	68.2	80.1	85.5	86.2	84.6	83.1	69.1	61.7	53.0
	2%	WB	43.3	41.3	46.9	55.1	63.9	71.8	73.7	72.8	70.5	62.1	55.4	46.5
		MCDB	44.4	44.1	50.9	62.3	73.3	80.8	82.5	80.8	77.3	66.0	57.0	47.7
	5%	WB	36.9	37.3	42.1	50.8	60.8	69.1	71.8	70.9	68.0	59.2	51.1	41.4
		MCDB	39.4	39.9	47.1	57.0	69.5	76.6	79.9	78.0	73.2	63.4	53.4	44.2
	10%	WB	32.4	34.0	38.8	47.5	57.8	66.6	70.1	69.2	65.5	56.0	46.8	37.0
		MCDB	34.6	37.0	43.0	55.0	65.3	73.4	77.0	75.5	70.2	60.1	50.2	39.7
Mean Daily Temperature Range	5% DB	MDBR	14.7	15.9	15.5	17.4	18.8	18.1	17.8	18.2	17.9	15.8	13.5	13.3
		MCDBR	17.9	17.6	20.5	25.7	27.2	23.9	21.6	21.9	22.2	20.9	17.5	17.7
		MCWBR	17.3	14.4	13.5	14.4	13.5	11.8	9.4	9.4	11.4	12.9	14.3	16.0
	5% WB	MCDBR	18.3	16.2	19.0	22.6	24.0	21.0	18.8	18.7	18.7	18.2	15.5	17.7
		MCWBR	18.2	14.5	14.0	15.1	13.4	11.7	9.6	9.6	11.1	13.7	14.9	17.3
Clear-Sky Solar Irradiance	taub	0.275	0.291	0.322	0.348	0.372	0.418	0.431	0.402	0.364	0.329	0.313	0.283	
	taud	2.426	2.370	2.410	2.414	2.391	2.266	2.245	2.322	2.414	2.516	2.519	2.485	
	Ebn at Noon	272	286	291	291	285	271	266	270	272	270	256	258	
	Edh at Noon	23	29	32	35	37	42	43	38	32	25	21	20	
All-Sky Solar Radiation	RadAvg	517	797	1176	1440	1617	1745	1814	1646	1333	840	538	401	
	RadStd	40	65	69	158	208	147	142	92	81	76	49	38	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (38 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+117	N/A

Nomenclature: See separate page