

AUGUSTA, ME, USA

WMO: 726185

Lat: 44.316N

Lon: 69.797W

Elev: 107

StdP: 100.05

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 14605

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-19.5	-16.9	-27.4	0.3	-18.1	-24.8	0.4	-15.6	11.6	-5.4	10.2	-6.7	3.8	300	0.548

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.9	30.4	21.6	28.7	20.6	27.2	19.7	23.0	28.0	22.1	26.5	21.1	25.0	3.6	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.6	16.4	25.2	20.7	15.5	24.2	19.8	14.7	23.3	68.9	28.2	65.1	26.5	61.7	24.9	26.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.3	8.3	7.4	-22.8	33.5	2.7	1.4	-24.8	34.5	-26.4	35.3	-27.9	36.0	-29.9	37.0		
(5)			-23.3	24.7	2.6	0.9	-25.2	25.4	-26.7	25.9	-28.1	26.5	-30.0	27.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	7.9	-6.5	-4.8	-0.1	6.6	12.8	17.8	21.2	20.4	16.2	9.7	3.3	-2.6		
	DBStd	10.51	6.11	5.55	5.11	4.14	3.83	3.71	2.75	2.68	3.72	4.05	4.68	5.22		
	HDD10.0	2024	511	415	314	117	14	1	0	0	1	55	205	391		
	HDD18.3	4038	769	648	570	351	177	53	7	11	84	268	450	649		
	CDD10.0	1262	0	0	2	16	101	235	346	323	188	47	5	0		
	CDD18.3	234	0	0	0	0	6	38	94	75	21	1	0	0		
	CDH23.3	1707	0	0	3	7	84	306	666	491	144	7	0	0		
	CDH26.7	435	0	0	1	1	23	78	173	122	37	1	0	0		
(14) Wind	WSAvg	3.3	3.6	3.7	3.9	3.8	3.4	3.0	2.7	2.7	2.8	3.3	3.4	3.4		
(15) Precipitation	PrecAvg	1050	74	69	89	91	92	88	79	82	86	99	107	91		
	PrecMax	1401	229	153	169	229	275	262	175	231	287	205	267	320		
	PrecMin	655	8	8	15	8	14	12	11	5	23	28	34	23		
	PrecStd	187	48	30	38	42	54	46	38	40	49	49	48	63		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.8	10.0	18.2	23.8	29.7	31.8	32.6	32.1	31.0	24.2	17.3	12.2		
		MCWB	10.4	6.9	11.5	13.7	18.1	21.8	23.2	22.0	22.0	16.7	13.9	10.3		
	2%	DB	7.4	7.3	12.3	18.9	25.5	28.9	30.2	29.7	27.0	20.6	14.7	9.5		
		MCWB	5.9	4.8	7.1	10.5	16.2	20.8	21.9	21.2	19.9	15.0	12.0	7.6		
	5%	DB	4.3	5.0	9.2	15.9	22.6	26.7	28.6	27.8	24.6	18.0	12.6	7.0		
		MCWB	2.5	2.5	4.9	8.9	14.7	19.0	20.8	20.2	18.6	14.1	10.3	5.0		
	10%	DB	1.8	2.9	6.9	13.5	20.0	24.8	27.1	26.1	22.4	16.1	10.3	4.5		
		MCWB	-0.2	0.9	3.5	7.8	13.2	17.8	19.9	19.3	17.4	12.9	7.9	2.5		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.5	8.1	12.4	15.4	20.1	23.8	24.7	23.9	22.9	18.8	15.2	11.1		
		MCDB	10.8	9.0	16.9	20.1	26.7	29.7	30.1	29.2	28.4	20.6	16.5	11.7		
	2%	WB	6.3	5.2	8.3	12.9	17.7	22.1	23.2	22.6	21.4	16.7	13.0	8.0		
		MCDB	6.9	6.7	10.5	16.8	22.9	27.1	28.1	27.1	25.2	18.9	13.9	8.7		
	5%	WB	2.7	3.0	5.6	10.5	16.0	20.6	22.1	21.6	20.0	15.1	10.6	5.2		
		MCDB	4.1	4.4	8.4	13.9	20.8	24.8	26.6	25.6	22.9	17.4	11.9	6.8		
	10%	WB	0.2	1.1	3.8	8.6	14.3	19.2	21.2	20.7	18.6	13.3	8.2	2.8		
		MCDB	1.5	2.8	6.1	12.8	18.5	23.0	25.0	24.2	21.2	15.6	10.1	4.3		
(35) Mean Daily Temperature Range	5% DB	MDBR	8.2	8.8	8.6	9.7	10.5	10.1	9.9	10.1	9.9	8.8	7.5	7.4		
		MCDBR	9.9	9.8	11.4	14.3	15.1	13.3	12.0	12.1	12.3	11.6	9.7	9.8		
	5% WB	MCWBR	9.6	8.0	7.5	8.0	7.5	6.5	5.2	5.2	6.3	7.1	7.9	8.9		
		MCWBR	10.2	9.0	10.6	12.6	13.3	11.6	10.4	10.4	10.4	10.1	8.6	9.8		
(40) Clear-Sky Solar Irradiance	taub	taub	0.275	0.291	0.322	0.348	0.372	0.418	0.431	0.402	0.364	0.329	0.313	0.283		
		taud	2.426	2.370	2.410	2.414	2.391	2.266	2.245	2.322	2.414	2.516	2.519	2.485		
	Ebn at Noon	Ebn at Noon	858	903	917	916	898	854	837	850	859	851	806	814		
		Edh at Noon	72	92	101	110	116	132	134	120	101	80	67	63		
(44) All-Sky Solar Radiation	RadAvg	RadAvg	1.63	2.51	3.71	4.54	5.10	5.50	5.72	5.19	4.20	2.65	1.70	1.26		
	RadStd	RadStd	0.12	0.21	0.22	0.50	0.66	0.46	0.45	0.29	0.26	0.24	0.15	0.12		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (38 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+65	N/A

Nomenclature: See separate page