

GREENVILLE, ME, USA

WMO: 726190

Lat: 45.462N

Lon: 69.595W

Elev: 1401

StdP: 13.97

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 94626

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-10.8	-6.0	-23.4	1.6	0.8	-18.2	2.1	-0.9	26.2	9.3	23.5	9.9	11.1	330	0.550

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.4	82.7	67.8	80.0	66.1	77.0	64.5	70.7	78.6	68.9	76.1	67.4	73.6	5.5	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
68.2	109.1	73.5	66.4	102.3	72.1	64.8	96.8	70.8	35.4	78.7	33.9	76.7	32.6	73.2	77.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 22.1	18.8	16.5	-17.0	88.5	6.5	2.0	-21.6	90.0	-25.4	91.2	-29.1	92.3	-33.8	93.8		
(5)			-17.5	73.8	6.3	1.5	-22.1	74.9	-25.8	75.8	-29.3	76.7	-33.9	77.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	41.7	15.7	17.1	25.7	38.5	51.0	60.5	66.7	64.9	57.3	45.6	33.5	22.4		
	DBStd	19.95	13.16	11.09	9.87	8.21	7.59	6.63	5.14	5.15	7.03	7.76	8.91	11.31		
	HDD50	4738	1067	922	756	357	79	4	0	0	14	182	498	859		
	HDD65	8720	1530	1342	1220	797	440	167	40	65	248	603	946	1322		
	CDD50	1701	2	0	2	10	109	319	518	461	232	44	2	2		
	CDD65	211	1	0	0	0	5	31	94	62	17	1	0	0		
	CDH74	1348	7	3	0	6	77	250	545	349	108	3	0	0		
	CDH80	243	0	0	0	1	15	52	97	57	21	0	0	0		
	WSAvg	6.4	7.7	7.9	8.0	7.3	6.1	5.2	4.2	4.3	5.0	6.3	6.9	7.7		
	PrecAvg	45.3	3.0	2.8	3.3	3.5	3.4	4.5	4.0	3.7	3.9	5.0	4.4	4.0		
(15) Precipitation	PrecMax	64.9	5.3	5.5	6.3	7.5	5.2	8.6	7.2	8.3	9.5	11.3	8.6	8.5		
	PrecMin	26.9	0.5	1.3	1.3	0.5	1.2	1.6	1.1	0.6	1.5	1.1	1.9	1.7		
	PrecStd	8.0	1.3	1.0	1.3	2.0	1.1	2.0	1.6	1.9	1.8	2.7	1.5	1.9		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	72.9	70.0	58.5	70.9	81.9	85.6	86.3	84.9	82.8	72.5	59.3	57.1		
		MCWB	45.0	43.5	50.2	54.1	62.9	69.3	70.9	68.6	69.5	59.3	54.2	37.9		
	2%	DB	52.4	45.1	46.8	62.3	74.7	80.8	82.7	81.3	76.8	65.7	53.9	48.5		
		MCWB	38.8	38.8	38.6	48.6	58.6	66.3	68.4	67.1	65.6	57.0	48.6	38.3		
	5%	DB	41.6	36.9	42.2	56.1	69.3	76.3	79.7	78.2	72.5	61.2	49.6	42.4		
		MCWB	38.5	33.1	35.6	45.6	56.1	63.1	67.0	65.7	63.1	55.7	45.3	37.8		
	10%	DB	33.5	33.1	38.6	51.6	64.6	72.6	76.8	74.8	68.7	57.2	45.8	36.6		
		MCWB	30.9	30.0	33.5	43.8	52.9	61.4	65.3	64.1	61.7	52.3	41.0	33.9		
	0.4%	WB	46.9	45.0	51.2	57.1	66.1	71.7	74.0	71.7	70.8	63.1	56.3	45.7		
		MCDB	62.5	62.9	57.4	65.8	75.7	81.4	81.9	79.7	79.5	66.8	58.0	47.9		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	41.0	38.4	40.8	51.5	61.7	68.7	71.1	69.7	67.9	59.7	51.0	40.0		
		MCDB	49.3	46.4	44.1	56.8	71.2	76.9	78.5	76.8	73.8	63.7	52.3	43.9		
	5%	WB	35.7	33.8	36.7	47.6	58.4	66.2	69.2	68.0	65.4	56.5	46.1	36.6		
		MCDB	42.5	37.1	41.1	54.2	65.7	73.2	76.4	74.4	70.4	60.7	48.2	43.5		
	10%	WB	31.3	30.4	33.7	43.8	55.1	63.6	67.6	66.4	62.9	53.0	42.0	33.5		
		MCDB	33.7	33.1	37.6	50.7	62.0	69.5	73.8	72.3	67.1	56.6	44.8	37.7		
(35) Mean Daily Temperature Range	5% DB	MDBR	17.2	17.4	15.7	16.2	17.8	17.1	16.4	16.5	16.5	13.3	12.0	12.8		
		MCDBR	36.0	27.6	19.2	24.5	26.0	23.5	20.3	20.8	20.9	20.0	17.0	19.1		
		MCWBR	26.5	20.7	13.5	14.7	13.9	12.2	9.8	10.1	11.5	13.5	13.9	14.8		
		MCDBR	32.7	28.0	17.0	22.4	22.3	20.0	17.2	16.6	17.7	17.8	15.8	16.8		
	5% WB	MCWBR	25.4	21.4	13.0	16.0	13.9	11.9	9.7	9.5	11.2	13.9	15.3	14.3		
(40) Clear-Sky Solar Irradiance	taub		0.246	0.264	0.302	0.326	0.348	0.385	0.396	0.377	0.344	0.314	0.289	0.259		
	taud		2.417	2.344	2.350	2.440	2.445	2.326	2.310	2.368	2.455	2.544	2.550	2.454		
	Ebn at Noon		281	295	296	297	292	280	275	276	278	273	263	264		
	Edh at Noon		22	29	34	34	35	39	40	36	30	24	20	19		
(44) All-Sky Solar Radiation	RadAvg		469	750	1143	1428	1574	1708	1735	1552	1268	768	465	352		
	RadStd		55	82	88	145	193	124	148	94	84	71	48	31		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (30 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+97	N/A

Nomenclature: See separate page