

ADIRONDACK, NY, USA

WMO: 726228

Lat: 44.385N

Lon: 74.207W

Elev: 1663

StdP: 13.83

Time Zone: -5.00 (NAE)

Period: 98-19

WBAN: 94740

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-18.7	-12.6	-24.4	1.5	-17.4	-18.1	2.2	-11.1	22.3	34.9	19.7	27.8	1.6	230	0.593

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	23.7	83.5	67.2	81.0	66.2	78.5	64.9	70.9	78.5	69.2	76.5	67.7	74.6	9.9	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
68.4	111.2	74.0	66.4	103.5	72.4	65.0	98.4	71.1	35.8	78.3	34.3	76.8	33.0	74.5	78.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.0	16.7	14.7	-28.1	88.2	5.2	2.0	-31.9	89.6	-35.0	90.8	-37.9	91.9	-41.7	93.4
			-27.6	74.1	4.4	1.9	-30.8	75.5	-33.3	76.6	-35.8	77.6	-39.0	79.0

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	40.3	14.1	16.1	24.5	38.6	51.0	59.2	63.7	62.1	55.4	43.9	32.6	21.1	(6)
	DBStd	20.06	14.03	12.40	12.26	9.10	8.23	6.86	5.58	6.00	7.84	8.58	10.13	12.05	(7)
	HDD50	4997	1114	950	792	360	88	7	0	1	35	229	526	895	(8)
	HDD65	9144	1579	1370	1256	793	438	198	91	130	301	655	973	1360	(9)
	CDD50	1463	0	0	1	18	120	284	426	375	196	40	3	0	(10)
	CDD65	133	0	0	0	0	5	25	52	39	12	0	0	0	(11)
	CDH74	1732	0	0	0	24	149	347	606	399	201	6	0	0	(12)
	CDH80	311	0	0	0	3	24	74	110	61	39	0	0	0	(13)
	WSAvg	5.7	6.3	6.3	6.3	6.5	5.8	5.3	4.8	4.4	4.8	5.6	5.8	6.1	(14)
	PrecAvg	40.7	2.7	2.3	2.7	3.3	3.6	4.1	4.3	3.9	3.7	3.8	3.3	3.3	(15)
(16) Precipitation	PrecMax	49.4	6.5	4.2	4.5	7.0	6.6	8.6	6.7	6.4	7.0	6.9	7.0	5.5	(16)
	PrecMin	35.2	1.5	1.1	1.2	0.8	1.6	1.3	2.6	1.3	2.0	0.9	1.6	1.8	(17)
	PrecStd	3.9	1.1	0.9	0.9	1.5	1.3	2.0	1.2	1.2	1.3	1.7	1.1	1.1	(18)
	PrecStd	3.9	1.1	0.9	0.9	1.5	1.3	2.0	1.2	1.2	1.3	1.7	1.1	1.1	(18)
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	50.3	51.7	61.2	77.4	83.3	86.8	86.9	85.2	84.5	74.2	63.4	54.3	(19)
		MCWB	48.0	47.2	47.7	58.4	63.7	68.3	71.3	69.0	67.5	60.4	54.4	50.2	(20)
	2%	DB	44.7	44.4	52.7	69.3	78.6	81.9	82.8	81.4	79.5	69.0	57.7	46.9	(21)
		MCWB	42.3	39.8	44.0	53.6	60.9	66.0	67.9	66.8	65.8	58.3	50.7	44.3	(22)
	5%	DB	37.9	38.9	47.4	62.1	73.4	78.5	80.5	78.8	75.2	63.9	54.0	42.9	(23)
		MCWB	36.0	35.7	41.1	49.8	57.9	64.0	66.9	66.1	63.8	56.5	48.6	40.5	(24)
	10%	DB	33.6	34.5	42.9	55.8	69.2	74.4	77.4	75.3	71.4	59.5	48.8	37.2	(25)
		MCWB	31.8	32.0	37.2	46.1	56.2	61.9	65.3	64.5	62.0	53.6	44.7	35.2	(26)
(28) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	48.2	47.8	52.4	60.6	67.6	71.4	74.1	72.3	70.8	64.8	56.1	50.5	(27)
		MCDB	50.0	50.2	57.8	71.8	77.9	80.3	82.2	79.2	78.6	68.7	61.0	53.2	(28)
	2%	WB	42.4	40.8	46.1	55.7	64.7	69.0	71.3	70.0	68.1	61.1	52.9	45.5	(29)
		MCDB	44.1	43.5	50.0	66.5	73.7	77.8	79.1	77.0	75.6	66.1	56.7	46.5	(30)
	5%	WB	36.4	36.4	41.9	51.4	61.9	67.0	69.4	68.3	65.8	57.4	49.3	40.4	(31)
		MCDB	38.0	39.0	47.0	59.3	68.8	74.1	76.0	74.9	72.7	63.1	53.0	42.7	(32)
	10%	WB	31.8	32.3	37.6	47.6	59.1	64.8	67.7	66.9	63.5	53.9	45.1	35.7	(33)
		MCDB	33.2	34.6	41.9	54.2	66.0	71.3	74.6	72.9	69.0	58.3	48.5	37.3	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	20.3	22.2	22.6	22.6	25.7	23.6	23.7	23.9	25.2	19.9	18.1	17.3	(35)
		MCDBR	20.8	23.7	27.6	36.1	35.2	29.8	27.8	26.9	30.9	29.1	26.8	20.0	(36)
		MCWBR	19.3	20.3	19.6	21.1	19.4	15.5	14.5	14.3	17.8	18.8	19.9	18.1	(37)
	5% WB	MCDBR	19.9	22.5	24.0	30.4	27.3	23.1	22.8	22.2	24.5	24.6	23.1	18.8	(38)
		MCWBR	18.8	20.1	19.1	19.9	16.6	13.3	13.1	12.9	15.0	17.7	19.1	17.8	(39)
(40) Clear-Sky Solar Irradiance	taub		0.264	0.278	0.313	0.335	0.360	0.405	0.410	0.390	0.346	0.324	0.304	0.276	(40)
	taud		2.398	2.355	2.382	2.432	2.413	2.282	2.267	2.321	2.447	2.515	2.494	2.420	(41)
	Ebn at Noon		276	291	293	295	288	274	272	273	279	272	259	259	(42)
	Edh at Noon		23	29	33	34	36	41	42	38	31	25	22	21	(43)
(44) All-Sky Solar Radiation	RadAvg		440	708	1072	1362	1597	1721	1761	1574	1273	743	471	325	(44)
	RadStd		54	76	94	173	180	145	151	77	108	82	54	33	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (46 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+119	N/A

Nomenclature: See separate page