

OAKLAND COUNTY INTL, MI, USA

WMO: 726375

Lat: 42.665N

Lon: 83.418W

Elev: 298

StdP: 97.80

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 94817

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-17.6	-15.1	-22.1	0.5	-16.8	-19.2	0.7	-14.0	11.7	-4.0	10.7	-4.3	3.1	290	0.547

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.3	32.1	22.7	30.3	21.7	28.8	20.9	24.1	29.1	23.1	27.9	22.3	26.9	4.8	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
22.5	17.8	26.8	21.7	17.0	25.8	20.9	16.1	25.1	73.9	29.5	70.0	27.8	66.7	26.7	29.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.6	9.1	8.2	DB	-21.2	33.9	3.3	1.4	-23.5	34.9	-25.4	35.7	-27.3	36.5	-29.6	37.5	(4)
(5)			WB	-21.5	25.8	3.2	0.9	-23.8	26.5	-25.7	27.0	-27.5	27.5	-29.8	28.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	9.3	-4.6	-3.5	1.4	8.4	14.6	20.1	22.4	21.5	17.5	10.8	4.1	-1.6	(6)	
	DBStd	10.74	6.27	5.98	6.02	4.98	4.78	3.74	3.16	2.98	4.12	4.66	4.96	5.29	(7)	
	HDD10.0	1803	454	378	277	87	11	0	0	0	1	47	187	361	(8)	
	HDD18.3	3667	712	611	526	300	136	23	4	8	63	238	427	618	(9)	
	CDD10.0	1559	1	1	9	39	155	304	385	356	228	72	9	1	(10)	
	CDD18.3	381	0	0	1	2	21	78	131	105	39	4	0	0	(11)	
	CDH23.3	3136	0	0	4	23	209	669	1129	766	306	30	0	0	(12)	
	CDH26.7	916	0	0	1	2	51	210	368	198	81	5	0	0	(13)	
(14) Wind	WSAvg	3.8	4.4	4.3	4.3	4.5	3.9	3.5	3.2	3.0	3.1	3.7	4.1	4.2	(14)	
(15) Precipitation	PrecAvg	855	56	47	56	70	97	87	85	78	80	75	66	56	(15)	
	PrecMax	1081	99	99	100	152	214	136	172	145	186	200	115	93	(16)	
	PrecMin	602	17	18	18	8	41	35	31	13	17	10	21	21	(17)	
	PrecStd	123	24	23	24	31	39	31	38	31	44	38	27	20	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.6	14.8	22.7	26.4	30.4	33.0	34.1	33.0	31.7	26.9	19.8	14.2	(19)	
		MCWB	11.3	10.8	15.8	16.9	20.8	23.2	23.6	23.2	21.8	20.1	14.0	12.3	(20)	
	2%	DB	9.7	10.7	17.8	22.8	28.0	31.3	32.1	30.8	28.9	23.3	16.4	11.1	(21)	
		MCWB	8.3	8.2	12.4	14.7	19.1	22.0	23.0	22.0	20.8	17.2	12.1	9.3	(22)	
	5%	DB	6.3	7.3	14.0	20.1	26.0	29.1	30.3	28.8	27.0	21.1	14.0	7.8	(23)	
		MCWB	4.5	4.6	9.8	12.8	18.2	20.7	21.9	21.2	19.5	16.2	10.5	5.6	(24)	
	10%	DB	3.3	4.1	10.9	17.4	23.3	27.4	28.7	27.4	24.7	18.6	12.0	5.3	(25)	
		MCWB	2.0	2.0	7.3	11.4	16.6	19.9	21.1	20.4	18.6	14.4	9.3	3.4	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.8	12.3	16.4	18.4	22.1	24.8	25.8	25.2	23.6	21.2	15.3	12.7	(27)	
		MCDB	12.6	13.7	22.0	24.4	28.2	31.2	31.5	31.1	28.9	25.6	17.4	14.3	(28)	
	2%	WB	8.3	8.2	13.5	16.2	20.6	23.2	24.3	23.6	22.1	19.0	13.2	9.6	(29)	
		MCDB	9.0	10.2	16.9	20.7	25.9	28.9	29.3	27.9	26.4	21.9	15.9	10.8	(30)	
	5%	WB	4.7	4.7	10.7	14.1	19.3	22.2	23.4	22.6	20.9	16.7	11.2	6.0	(31)	
		MCDB	6.2	7.0	13.6	18.8	24.1	27.4	28.1	26.7	24.5	19.9	13.4	7.6	(32)	
	10%	WB	2.2	2.3	7.1	12.0	17.8	21.1	22.4	21.7	19.8	15.0	9.0	3.6	(33)	
		MCDB	3.5	4.2	10.2	16.6	22.2	25.6	26.9	25.8	23.4	18.0	11.6	5.1	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	7.2	8.1	9.2	10.7	10.7	10.5	10.3	9.8	10.3	9.3	7.5	6.2	(35)	
		MCDBR	9.5	11.3	13.6	14.7	13.1	12.2	11.7	11.1	12.6	12.5	10.9	8.8	(36)	
	5% WB	MCWBR	8.5	9.1	9.3	8.8	6.7	5.4	5.0	4.7	5.6	7.3	8.1	7.6	(37)	
		MCWBR	9.3	10.8	12.6	13.0	11.6	10.5	10.1	9.4	10.2	10.6	10.0	8.6	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.293	0.327	0.343	0.386	0.412	0.434	0.424	0.417	0.380	0.351	0.315	0.300	(40)	
		taud	2.389	2.275	2.366	2.267	2.244	2.214	2.262	2.270	2.360	2.432	2.490	2.418	(41)	
	Ebn at Noon		847	865	899	881	863	842	846	840	848	833	819	804	(42)	
		Edh at Noon	79	104	108	129	136	140	132	127	108	89	72	71	(43)	
(44) All-Sky Solar Radiation	RadAvg		1.51	2.38	3.53	4.60	5.36	6.05	6.08	5.24	4.22	2.73	1.69	1.19	(44)	
	RadStd		0.14	0.29	0.37	0.41	0.47	0.37	0.29	0.20	0.39	0.24	0.22	0.10	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (62 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page