

ROSCOMMON COUNTY AP, MI, USA

WMO: 726380

Lat: 44.359N

Lon: 84.674W

Elev: 1151

StdP: 14.09

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 94814

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-6.3	-0.7	-11.5	3.1	-4.3	-6.4	4.1	1.1	22.8	20.6	20.4	19.8	3.8	250	0.582

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	23.0	86.7	70.7	84.0	69.2	81.3	67.6	74.0	82.9	72.0	80.3	70.3	77.7	9.3	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
71.0	119.2	79.2	69.2	111.9	76.5	67.6	105.7	75.1	38.2	82.9	36.4	80.5	34.9	77.7	83.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
20.6	18.5	16.7	-15.5	91.7	8.0	3.6	-21.3	94.3	-26.0	96.4	-30.5	98.5	-36.3	101.1		
			-14.9	76.8	7.4	1.9	-20.3	78.1	-24.6	79.2	-28.7	80.2	-34.1	81.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	44.5	19.1	20.4	29.8	42.5	54.8	64.1	67.8	66.0	59.0	47.3	35.7	25.6
	DBStd	19.40	10.87	11.04	11.32	9.15	8.56	7.10	6.11	6.04	7.75	8.40	8.59	9.23
	HDD50	4079	957	828	633	259	45	1	0	0	12	155	434	755
	HDD65	7834	1422	1248	1090	676	336	100	41	62	210	550	879	1220
	CDD50	2066	0	0	8	33	193	424	552	495	283	73	5	0
	CDD65	348	0	0	0	1	19	74	128	92	31	3	0	0
	CDH74	3462	0	0	5	17	231	801	1283	813	288	24	0	0
	CDH80	852	0	0	1	1	46	225	346	177	54	2	0	0
Wind	WSAvg	7.9	8.5	8.4	8.3	9.1	8.2	7.1	6.6	6.3	6.7	8.0	8.6	8.6
Precipitation	PrecAvg	28.3	1.5	1.2	1.9	2.4	2.8	3.0	2.5	3.2	3.2	2.4	2.3	1.8
	PrecMax	37.6	3.1	3.3	5.7	4.7	7.4	6.7	5.0	7.2	9.5	8.1	5.1	4.5
	PrecMin	20.2	0.2	0.2	0.2	0.9	0.4	0.9	0.6	0.9	0.0	0.5	0.4	0.4
	PrecStd	3.6	0.7	0.7	1.1	1.0	1.5	1.6	1.3	1.7	1.9	1.4	1.2	0.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	47.1	51.4	69.5	76.4	85.0	90.6	91.1	88.3	85.8	77.4	63.7	53.2
		MCWB	45.0	46.3	59.0	58.7	67.3	73.0	73.7	71.7	69.3	64.9	54.0	50.2
	2%	DB	41.4	44.1	58.7	69.7	80.2	85.6	87.0	84.6	80.8	71.2	57.2	45.9
		MCWB	38.7	39.8	50.1	55.1	63.5	69.1	71.5	70.3	67.2	61.0	51.2	43.1
	5%	DB	36.8	38.9	52.0	64.5	75.7	82.3	83.8	81.4	77.2	66.5	53.2	41.0
		MCWB	34.8	35.6	45.4	51.5	61.1	67.5	69.8	68.3	65.2	58.7	48.3	38.5
	10%	DB	33.8	35.3	46.1	59.3	71.3	78.6	81.1	78.6	73.6	61.9	49.0	37.3
		MCWB	32.4	32.6	39.8	47.9	58.4	65.4	68.1	66.7	63.6	55.8	44.5	35.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	46.2	47.8	59.3	62.2	69.6	75.0	77.0	75.4	72.7	68.1	56.8	51.4
		MCDB	47.0	50.1	67.7	71.4	79.7	87.2	87.0	83.4	81.2	74.4	60.7	52.8
	2%	WB	39.2	40.2	52.2	57.4	66.8	72.0	74.6	72.9	70.0	63.7	52.7	43.9
		MCDB	40.8	43.8	56.9	67.1	76.2	82.4	83.5	80.7	76.1	68.0	56.3	45.8
	5%	WB	35.0	35.8	45.7	53.4	64.0	69.9	72.6	71.0	68.0	59.9	48.9	38.8
		MCDB	36.4	38.5	50.9	62.1	72.6	78.0	80.6	78.4	74.1	66.0	53.0	40.7
	10%	WB	32.5	32.9	40.7	49.6	61.0	68.0	70.6	69.1	65.8	56.4	44.9	35.2
		MCDB	33.9	35.2	45.8	58.2	69.1	75.7	77.9	75.5	72.6	61.3	48.7	37.1
Mean Daily Temperature Range	5% DB	MDBR	13.6	16.5	19.1	21.2	22.5	23.0	23.0	22.4	22.3	17.9	13.4	11.3
		MCDBR	14.0	18.0	25.2	29.9	27.9	27.0	24.8	24.6	26.3	25.7	20.8	15.3
		MCWBR	12.4	14.3	16.7	17.1	14.1	13.1	12.1	12.4	14.3	16.4	15.7	12.9
	5% WB	MCDBR	13.1	17.0	22.6	25.9	23.2	21.6	21.0	20.1	20.1	21.5	19.3	14.1
		MCWBR	12.1	14.3	16.4	17.2	13.4	12.3	11.3	11.1	12.3	15.7	15.8	13.0
Clear-Sky Solar Irradiance	taub	0.273	0.299	0.313	0.344	0.373	0.395	0.393	0.381	0.364	0.330	0.299	0.272	
	taud	2.378	2.290	2.420	2.374	2.353	2.309	2.325	2.355	2.408	2.497	2.522	2.442	
	Ebn at Noon	272	282	294	292	285	277	277	276	272	269	262	261	
	Edh at Noon	24	31	32	36	38	40	39	37	32	26	21	21	
All-Sky Solar Radiation	RadAvg	414	704	1136	1434	1710	1889	1913	1625	1292	781	450	320	
	RadStd	36	81	134	132	159	121	96	93	123	91	62	32	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46)	Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (44 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page