

ROSCOMMON COUNTY AP, MI, USA

WMO: 726380

Lat: 44.359N

Lon: 84.674W

Elev: 351

StdP: 97.18

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 94814

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-21.3	-18.2	-24.2	0.4	-20.2	-21.3	0.6	-17.2	10.2	-6.3	9.1	-6.8	1.7	250	0.582

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.8	30.4	21.5	28.9	20.6	27.4	19.8	23.3	28.3	22.2	26.8	21.3	25.4	4.2	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
21.7	17.0	26.2	20.7	16.0	24.7	19.8	15.1	23.9	71.0	28.3	66.8	27.0	63.3	25.4	28.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
9.2	8.3	7.5	-26.4	33.2	4.5	2.0	-29.6	34.6	-32.2	35.8	-34.7	36.9	-37.9	38.4		
			-26.1	24.9	4.1	1.0	-29.0	25.6	-31.4	26.2	-33.7	26.8	-36.7	27.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	6.9	-7.2	-6.4	-1.2	5.8	12.6	17.8	19.9	18.9	15.0	8.5	2.1	-3.5
	DBStd	10.78	6.04	6.14	6.29	5.08	4.76	3.95	3.40	3.36	4.30	4.67	4.77	5.13
	HDD10.0	2266	532	460	352	144	25	1	0	0	7	86	241	419
	HDD18.3	4352	790	693	606	376	187	56	23	34	117	306	488	678
	CDD10.0	1148	0	0	4	18	107	236	307	275	157	41	3	0
	CDD18.3	193	0	0	0	1	11	41	71	51	17	2	0	0
	CDH23.3	1923	0	0	3	9	128	445	713	452	160	13	0	0
	CDH26.7	473	0	0	1	1	26	125	192	98	30	1	0	0
Wind	WSAvg	3.5	3.8	3.8	3.7	4.1	3.7	3.2	3.0	2.8	3.0	3.6	3.9	3.8
Precipitation	PrecAvg	720	37	30	49	60	72	75	63	82	81	61	59	46
	PrecMax	956	80	85	144	120	188	169	126	182	241	205	130	114
	PrecMin	514	5	4	5	22	10	22	14	22	0	12	11	9
	PrecStd	91	17	17	28	25	39	41	34	43	47	36	30	24
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	8.4	10.8	20.8	24.7	29.4	32.6	32.8	31.3	29.9	25.2	17.6	11.8
		MCWB	7.2	8.0	15.0	14.8	19.6	22.8	23.2	22.1	20.7	18.3	12.2	10.1
	2%	DB	5.2	6.7	14.8	20.9	26.8	29.8	30.6	29.2	27.1	21.8	14.0	7.7
		MCWB	3.7	4.3	10.1	12.8	17.5	20.6	21.9	21.3	19.6	16.1	10.7	6.2
	5%	DB	2.6	3.8	11.1	18.1	24.3	27.9	28.8	27.4	25.1	19.1	11.8	5.0
		MCWB	1.5	2.0	7.4	10.8	16.2	19.7	21.0	20.2	18.4	14.8	9.0	3.6
	10%	DB	1.0	1.8	7.8	15.2	21.9	25.9	27.3	25.9	23.1	16.6	9.5	2.9
		MCWB	0.2	0.3	4.4	8.8	14.7	18.5	20.0	19.3	17.6	13.2	7.0	1.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.9	8.8	15.1	16.8	20.9	23.9	25.0	24.1	22.6	20.1	13.8	10.8
		MCDB	8.3	10.1	19.9	21.9	26.5	30.7	30.6	28.6	27.3	23.6	16.0	11.6
	2%	WB	4.0	4.5	11.2	14.1	19.3	22.2	23.7	22.7	21.1	17.6	11.5	6.6
		MCDB	4.9	6.6	13.9	19.5	24.6	28.0	28.6	27.0	24.5	20.0	13.5	7.7
	5%	WB	1.7	2.1	7.6	11.9	17.8	21.1	22.6	21.7	20.0	15.5	9.4	3.8
		MCDB	2.4	3.6	10.5	16.7	22.6	25.6	27.0	25.8	23.4	18.9	11.7	4.8
	10%	WB	0.3	0.5	4.8	9.8	16.1	20.0	21.4	20.6	18.8	13.5	7.2	1.8
		MCDB	1.1	1.8	7.7	14.5	20.6	24.3	25.5	24.2	22.5	16.3	9.3	2.8
Mean Daily Temperature Range	5% DB	MDBR	7.6	9.2	10.6	11.8	12.5	12.8	12.8	12.5	12.4	9.9	7.4	6.3
		MCDBR	7.8	10.0	14.0	16.6	15.5	15.0	13.8	13.7	14.6	14.3	11.6	8.5
		MCWBR	6.9	7.9	9.3	9.5	7.8	7.3	6.7	6.9	7.9	9.1	8.7	7.1
	5% WB	MCDBR	7.3	9.4	12.6	14.4	12.9	12.0	11.7	11.2	11.2	11.9	10.7	7.8
		MCWBR	6.7	7.9	9.1	9.5	7.4	6.8	6.3	6.1	6.8	8.7	8.8	7.2
Clear-Sky Solar Irradiance	taub	0.273	0.299	0.313	0.344	0.373	0.395	0.393	0.381	0.364	0.330	0.299	0.272	
	taud	2.378	2.290	2.420	2.374	2.353	2.309	2.325	2.355	2.408	2.497	2.522	2.442	
	Ebn at Noon	856	888	926	919	897	874	872	870	859	848	825	824	
	Edh at Noon	75	99	100	114	121	127	123	116	101	81	66	65	
All-Sky Solar Radiation	RadAvg	1.31	2.22	3.58	4.52	5.39	5.96	6.03	5.12	4.07	2.46	1.42	1.01	
	RadStd	0.12	0.25	0.42	0.41	0.50	0.38	0.30	0.29	0.39	0.29	0.20	0.10	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (44 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page