

TAYLOR COUNTY AP, WI, USA

WMO: 726417

Lat: 45.101N

Lon: 90.303W

Elev: 1470

StdP: 13.93

Time Zone: -6.00 (NAC)

Period: 99-19

WBAN: 54911

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-13.4	-8.7	-20.2	1.9	-11.3	-16.8	2.3	-8.0	23.1	17.2	20.0	18.3	5.3	290	0.570

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.0	85.7	72.6	82.2	70.4	80.7	69.2	75.6	82.1	73.6	79.4	71.5	77.3	9.9	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
73.3	130.8	78.7	72.0	125.2	77.6	69.9	116.3	75.7	40.3	82.0	38.1	78.9	36.2	77.4	86.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
20.8	18.5	16.6	DB	-20.4	89.5	4.9	4.1	-23.9	92.4	-26.7	94.8	-29.5	97.1	-33.0	100.1	
			WB	-20.2	78.1	5.2	2.9	-24.0	80.2	-27.0	82.0	-30.0	83.6	-33.7	85.7	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	42.9	14.3	16.5	29.1	42.8	54.8	63.8	68.4	65.7	58.7	46.2	33.2	19.3
	DBStd	21.33	12.40	12.04	12.37	9.78	8.45	6.44	5.77	5.85	8.11	8.94	10.18	11.43
	HDD50	4669	1108	937	657	254	46	0	0	17	186	511	953	
	HDD65	8414	1573	1357	1112	666	333	97	31	62	222	588	955	1418
	CDD50	2062	0	0	10	39	194	415	571	486	276	66	5	0
	CDD65	334	0	0	0	0	16	62	137	83	32	4	0	0
	CDH74	2693	0	0	1	14	160	473	1154	625	244	22	0	0
	CDH80	607	0	0	0	2	33	91	307	127	46	1	0	0
Wind	WSAvg	7.2	7.6	7.7	7.7	8.6	8.0	6.8	5.8	5.4	6.5	7.6	7.8	7.4
Precipitation	PrecAvg	32.5	1.1	0.9	1.7	2.6	3.5	4.3	3.8	4.4	4.4	2.6	1.9	1.2
	PrecMax	45.6	3.3	3.0	3.6	5.9	7.5	10.4	9.2	9.4	10.4	6.5	6.6	3.3
	PrecMin	19.3	0.1	0.0	0.2	0.8	0.6	1.0	1.2	0.6	0.7	0.3	0.2	0.4
	PrecStd	5.9	0.8	0.7	1.0	1.2	1.7	2.2	1.8	2.1	2.1	1.4	1.2	0.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	41.2	46.4	68.2	75.1	84.1	86.4	91.1	88.1	84.4	77.2	63.6	46.2
		MCWB	36.5	41.5	60.2	58.5	67.7	73.7	74.2	74.5	71.2	65.5	55.0	44.3
	2%	DB	36.9	41.0	58.9	69.8	78.9	82.1	87.7	83.4	80.8	71.8	57.0	39.4
		MCWB	34.6	37.1	51.3	55.4	64.3	70.5	73.4	70.8	68.5	63.2	50.7	37.1
	5%	DB	34.3	36.5	51.8	63.7	73.4	79.4	82.4	80.8	76.4	65.7	52.5	36.6
		MCWB	33.1	33.7	46.1	50.2	60.8	68.1	71.4	69.5	65.5	57.5	47.4	35.1
	10%	DB	31.8	33.6	45.4	59.2	70.0	75.4	80.8	77.3	72.6	61.1	47.7	34.2
		MCWB	30.9	31.2	40.5	48.5	59.2	65.8	70.0	67.8	64.2	54.8	44.0	33.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	37.7	42.7	60.2	61.5	71.8	76.7	80.5	77.1	73.9	71.5	57.8	45.5
		MCDB	40.3	46.1	66.2	72.5	80.0	82.7	86.2	82.6	80.8	74.9	61.6	45.9
	2%	WB	35.2	37.4	53.5	57.1	67.3	74.0	76.7	74.5	70.9	63.3	52.6	38.1
		MCDB	36.8	40.3	56.6	65.6	74.9	79.9	82.6	80.2	76.8	68.7	56.4	39.2
	5%	WB	33.0	33.8	45.7	53.1	64.2	71.2	74.2	72.1	68.2	59.1	47.6	35.3
		MCDB	34.4	36.4	50.6	61.2	70.6	76.9	80.2	77.3	74.1	64.4	51.0	36.5
	10%	WB	30.5	30.8	40.7	49.3	61.3	68.3	71.9	69.8	65.9	55.1	44.0	32.9
		MCDB	31.5	32.6	45.2	58.1	66.7	74.0	78.0	75.5	71.0	60.3	47.5	34.0
Mean Daily Temperature Range	5% DB	MDBR	14.6	16.6	17.0	18.8	20.1	18.9	20.0	19.9	20.1	17.0	13.7	12.8
		MCDBR	13.6	16.0	21.2	27.0	24.3	21.3	21.9	21.9	23.3	23.5	20.6	13.8
		MCWBR	12.0	12.9	14.1	15.4	12.8	12.2	11.5	11.7	12.7	14.4	15.2	12.2
	5% WB	MCDBR	13.2	14.8	19.6	23.6	20.3	18.3	18.9	18.4	19.6	20.0	19.2	12.1
		MCWBR	11.9	12.2	14.1	15.6	12.5	12.4	12.0	11.5	12.3	14.3	15.6	11.0
Clear-Sky Solar Irradiance	taub		0.243	0.267	0.303	0.339	0.368	0.368	0.368	0.369	0.341	0.310	0.281	0.253
	taud		2.400	2.330	2.388	2.398	2.354	2.377	2.391	2.392	2.471	2.541	2.528	2.448
	Ebn at Noon		284	294	296	292	285	285	283	279	280	276	267	268
	Edh at Noon		23	30	32	35	38	37	36	35	30	24	20	20
All-Sky Solar Radiation	RadAvg		527	884	1241	1442	1699	1865	1937	1633	1282	807	498	371
	RadStd		58	79	128	146	131	148	89	112	85	92	49	43

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (40 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page