

TAYLOR COUNTY AP, WI, USA

WMO: 726417

Lat: 45.101N

Lon: 90.303W

Elev: 448

StdP: 96.06

Time Zone: -6.00 (NAC)

Period: 99-19

WBAN: 54911

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -25.2	(c) -22.6	(d) -29.0	(e) 0.3	(f) -24.1	(g) -27.1	(h) 0.3	(i) -22.2	(j) 10.3	(k) -8.2	(l) 9.0	(m) -7.6	(n) 2.4	(o) 290	(p) 0.570

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.1	29.8	22.6	27.9	21.3	27.0	20.7	24.2	27.8	23.1	26.3	21.9	25.2	4.4	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
23.0	18.7	25.9	22.2	17.9	25.4	21.1	16.6	24.3	75.9	27.8	70.9	26.1	66.4	25.2	30.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 9.3	(b) 8.3	(c) 7.4	(e) -29.1	(f) 31.9	(g) 2.7	(h) 2.3	(i) -31.0	(j) 33.6	(k) -32.6	(l) 34.9	(m) -34.1	(n) 36.2	(o) -36.1	(p) 37.8		
(a) 9.3	(b) 8.3	(c) 7.4	(e) -29.0	(f) 25.6	(g) 2.9	(h) 1.6	(i) -31.1	(j) 26.8	(k) -32.8	(l) 27.8	(m) -34.4	(n) 28.7	(o) -36.5	(p) 29.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	6.0	-9.9	-8.6	-1.6	6.0	12.6	17.7	20.2	18.7	14.8	7.9	0.6	-7.1		
	DBStd	11.85	6.89	6.69	6.87	5.43	4.69	3.58	3.20	3.25	4.50	4.96	5.66	6.35		
	HDD10.0	2594	616	521	365	141	26	0	0	0	9	103	284	529		
	HDD18.3	4674	874	754	618	370	185	54	17	34	123	327	531	788		
	CDD10.0	1146	0	0	6	22	108	231	317	270	153	37	3	0		
	CDD18.3	186	0	0	0	0	9	34	76	46	18	2	0	0		
	CDH23.3	1496	0	0	1	8	89	263	641	347	136	12	0	0		
	CDH26.7	337	0	0	0	1	18	51	171	71	26	1	0	0		
(14) Wind	WSAvg	3.2	3.4	3.4	3.4	3.8	3.6	3.0	2.6	2.4	2.9	3.4	3.5	3.3		
(15) Precipitation	PrecAvg	826	27	22	44	67	89	110	96	112	111	65	49	31		
	PrecMax	1157	84	77	92	151	190	263	234	240	263	164	167	83		
	PrecMin	490	2	1	5	21	16	26	30	14	17	7	5	9		
	PrecStd	149	20	17	25	30	42	55	46	54	54	35	31	18		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	5.1	8.0	20.1	23.9	29.0	30.2	32.8	31.2	29.1	25.1	17.5	7.9		
		MCWB	2.5	5.3	15.7	14.7	19.8	23.2	23.4	23.6	21.8	18.6	12.8	6.8		
	2%	DB	2.7	5.0	15.0	21.0	26.1	27.8	30.9	28.5	27.1	22.1	13.9	4.1		
		MCWB	1.4	2.8	10.7	13.0	17.9	21.4	23.0	21.6	20.3	17.3	10.4	2.8		
	5%	DB	1.3	2.5	11.0	17.6	23.0	26.3	28.0	27.1	24.6	18.7	11.4	2.5		
		MCWB	0.6	0.9	7.8	10.1	16.0	20.1	21.9	20.8	18.6	14.2	8.6	1.7		
	10%	DB	-0.1	0.9	7.4	15.1	21.1	24.1	27.1	25.2	22.5	16.1	8.7	1.2		
		MCWB	-0.6	-0.5	4.7	9.2	15.1	18.8	21.1	19.9	17.9	12.6	6.7	0.6		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	3.2	5.9	15.7	16.4	22.1	24.8	26.9	25.1	23.3	22.0	14.3	7.5		
		MCDB	4.6	7.8	19.0	22.5	26.7	28.2	30.1	28.1	27.1	23.8	16.5	7.7		
	2%	WB	1.8	3.0	12.0	13.9	19.6	23.3	24.8	23.6	21.6	17.4	11.5	3.4		
		MCDB	2.7	4.6	13.7	18.7	23.8	26.6	28.1	26.8	24.9	20.4	13.6	4.0		
	5%	WB	0.5	1.0	7.6	11.7	17.9	21.8	23.4	22.3	20.1	15.1	8.7	1.8		
		MCDB	1.3	2.4	10.3	16.2	21.5	25.0	26.8	25.1	23.4	18.0	10.5	2.5		
	10%	WB	-0.8	-0.7	4.8	9.6	16.3	20.2	22.2	21.0	18.9	12.8	6.7	0.5		
		MCDB	-0.3	0.3	7.3	14.5	19.3	23.3	25.5	24.2	21.7	15.7	8.6	1.1		
(35) Mean Daily Temperature Range	5% DB	MDBR	8.1	9.2	9.4	10.4	11.1	10.5	11.1	11.0	11.2	9.5	7.6	7.1		
		MCDBR	7.5	8.9	11.8	15.0	13.5	11.8	12.2	12.2	13.0	13.1	11.4	7.6		
	5% WB	MCWBR	6.6	7.2	7.9	8.5	7.1	6.8	6.4	6.5	7.0	8.0	8.4	6.8		
		MCWBR	7.3	8.2	10.9	13.1	11.3	10.2	10.5	10.2	10.9	11.1	10.7	6.7		
(40) Clear-Sky Solar Irradiance	taub		0.243	0.267	0.303	0.339	0.368	0.368	0.368	0.369	0.341	0.310	0.281	0.253		
	taud		2.400	2.330	2.388	2.398	2.354	2.377	2.391	2.392	2.471	2.541	2.528	2.448		
	Ebn at Noon		894	926	934	922	900	899	893	881	882	869	842	845		
	Edh at Noon		71	93	102	111	120	118	115	111	94	76	64	62		
(44) All-Sky Solar Radiation	RadAvg		1.66	2.79	3.91	4.55	5.36	5.88	6.11	5.15	4.04	2.54	1.57	1.17		
	RadStd		0.18	0.25	0.40	0.46	0.41	0.47	0.28	0.35	0.27	0.29	0.15	0.14		

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (40 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page