

ASHLAND JFK, WI, USA

WMO: 726419

Lat: 46.549N

Lon: 90.919W

Elev: 252

StdP: 98.34

Time Zone: -6.00 (NAC)

Period: 01-19

WBAN: 94929

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -24.8	(c) -22.2	(d) -28.9	(e) 0.3	(f) -23.9	(g) -26.7	(h) 0.3	(i) -21.7	(j) 10.4	(k) -7.8	(l) 9.2	(m) -8.0	(n) 3.8	(o) 240	(p) 0.608

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 12.9	(c) 30.3	(d) 22.0	(e) 28.7	(f) 21.0	(g) 27.3	(h) 20.0	(i) 23.5	(j) 28.5	(k) 22.3	(l) 27.0	(m) 21.2	(n) 25.6	(o) 4.7	(p) 200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.9	17.1	26.4	20.8	15.9	25.3	19.5	14.7	24.0	71.2	28.5	66.7	27.1	62.7	25.5	28.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 9.6	(b) 8.4	(c) 7.5	(e) -27.9	(f) 33.5	(g) 2.5	(h) 1.7	(i) -29.7	(j) 34.8	(k) -31.2	(l) 35.8	(m) -32.6	(n) 36.7	(o) -34.4	(p) 38.0		
(a) 9.6	(b) 8.4	(c) 7.5	(e) -28.2	(f) 25.3	(g) 2.4	(h) 1.1	(i) -29.9	(j) 26.1	(k) -31.3	(l) 26.7	(m) -32.6	(n) 27.3	(o) -34.3	(p) 28.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	5.5	-9.7	-8.4	-2.2	4.3	10.6	16.0	19.7	18.5	14.6	7.3	0.6	-6.6		
	DBStd	11.47	6.93	6.43	6.79	5.04	4.77	3.97	3.48	3.27	4.58	4.74	5.57	6.27		
	HDD10.0	2663	610	514	382	183	49	2	0	0	11	114	285	513		
	HDD18.3	4853	868	748	637	421	246	92	26	38	130	344	532	772		
	CDD10.0	1010	0	0	3	11	68	182	301	264	147	29	3	0		
	CDD18.3	159	0	0	1	0	6	21	69	44	17	2	0	0		
	CDH23.3	1721	0	0	3	12	96	264	735	427	167	16	0	0		
	CDH26.7	447	0	0	0	2	27	64	218	98	37	2	0	0		
(14) Wind	WSAvg	3.3	3.7	3.8	3.5	3.8	3.4	2.8	2.8	2.8	3.1	3.3	3.5	3.6		
(15) Precipitation	PrecAvg	773	31	22	43	65	81	87	98	101	95	63	55	32		
	PrecMax	1051	112	74	149	232	190	167	228	223	254	151	215	116		
	PrecMin	510	1	1	5	14	16	36	14	32	22	11	7	3		
	PrecStd	133	25	17	28	41	44	36	52	43	47	37	42	22		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	7.0	9.7	20.3	25.0	30.1	31.2	33.2	31.4	30.2	25.9	17.8	7.6		
		MCWB	3.0	6.8	13.5	15.0	18.6	22.5	23.7	22.7	22.3	16.9	11.4	4.2		
	2%	DB	3.8	5.5	13.9	20.2	26.1	28.4	30.8	29.1	27.5	21.8	14.5	5.0		
		MCWB	1.7	2.3	8.0	11.2	16.4	20.5	22.7	21.6	20.1	15.2	10.4	3.0		
	5%	DB	1.6	2.6	10.1	16.7	22.6	26.4	29.0	27.5	25.2	18.1	11.6	3.0		
		MCWB	0.3	0.3	6.1	9.7	14.5	18.9	21.2	20.7	19.4	13.2	7.7	1.6		
	10%	DB	-0.1	0.6	6.9	13.4	19.8	24.2	27.5	25.9	23.0	15.2	8.8	1.7		
		MCWB	-1.3	-1.0	3.4	7.8	13.5	18.0	20.5	19.6	18.1	10.9	5.7	0.7		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	3.6	5.6	15.5	15.8	20.9	23.9	25.4	24.3	23.7	18.6	13.7	5.3		
		MCDB	6.1	9.2	19.5	22.7	26.4	29.6	30.9	29.0	28.0	23.8	16.5	6.2		
	2%	WB	1.8	2.5	9.3	12.3	18.2	21.9	23.7	22.9	21.7	15.7	10.7	3.2		
		MCDB	3.5	5.0	13.5	18.2	23.3	26.9	28.9	27.7	25.9	20.0	14.1	4.6		
	5%	WB	0.4	0.6	6.1	10.1	16.0	20.1	22.5	21.7	20.1	13.7	7.9	1.9		
		MCDB	1.7	2.4	9.4	16.2	21.4	24.6	27.2	25.9	23.9	17.7	10.5	3.0		
	10%	WB	-1.3	-1.0	3.8	8.1	14.0	18.7	21.4	20.5	18.7	11.7	6.1	0.6		
		MCDB	-0.2	0.4	6.5	12.9	18.6	22.8	25.8	24.5	22.5	14.5	8.8	1.6		
(35) Mean Daily Temperature Range	MDBR		8.4	9.6	10.5	11.3	13.1	12.8	12.9	12.4	12.0	10.1	8.3	7.3		
	5% DB	MCDBR	8.7	11.0	13.8	18.3	17.8	15.4	14.4	14.3	14.4	14.8	12.8	8.4		
		MCWBR	7.0	8.2	9.0	10.7	9.7	8.5	7.3	7.6	8.3	9.0	8.8	6.8		
	5% WB	MCDBR	8.3	9.7	12.6	16.9	16.0	14.1	13.2	12.7	12.5	12.9	12.1	7.7		
		MCWBR	6.9	7.5	8.9	10.3	9.5	8.7	7.5	7.5	7.7	8.6	8.8	6.5		
(40) Clear-Sky Solar Irradiance	taub		0.250	0.281	0.308	0.345	0.374	0.373	0.375	0.376	0.359	0.315	0.290	0.266		
	taud		2.441	2.353	2.388	2.394	2.365	2.393	2.421	2.429	2.456	2.557	2.524	2.454		
	Ebn at Noon		872	898	922	912	892	891	884	870	856	854	812	805		
	Edh at Noon		66	89	101	111	118	116	111	106	94	74	62	59		
(44) All-Sky Solar Radiation	RadAvg		1.33	2.38	3.57	4.50	5.32	5.78	6.07	5.07	3.83	2.33	1.35	0.94		
	RadStd		0.14	0.23	0.32	0.47	0.39	0.40	0.23	0.33	0.22	0.28	0.17	0.10		

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (39 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page