

PRICE COUNTY AP, WI, USA

WMO: 726468

Lat: 45.709N

Lon: 90.402W

Elev: 1497

StdP: 13.92

Time Zone: -6.00 (NAC)

Period: 94-19

WBAN: 54913

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-18.9	-12.8	-27.2	1.3	-17.5	-20.1	1.9	-11.5	19.5	21.4	17.6	20.0	1.3	280	0.556

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	21.1	85.8	71.5	82.4	69.0	80.9	67.7	74.6	81.8	72.5	79.4	70.7	77.2	9.1	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
72.4	127.0	78.5	70.4	118.1	76.5	68.4	110.2	74.7	39.2	82.3	37.2	79.1	35.5	75.9	82.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
18.5	16.4	14.2	DB	-25.8	89.9	4.8	3.5	-29.3	92.5	-32.1	94.5	-34.8	96.5	-38.3	99.0	
			WB	-26.0	77.3	4.6	2.6	-29.3	79.2	-32.0	80.7	-34.6	82.2	-38.0	84.1	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	42.0	12.6	16.1	28.0	41.0	54.0	63.5	67.8	65.8	58.3	45.5	31.5	18.9
	DBStd	21.79	13.42	13.18	12.87	9.91	8.70	6.98	5.92	5.93	8.45	9.02	10.51	11.95
	HDD50	4903	1160	951	690	299	56	2	0	0	21	200	559	965
	HDD65	8705	1625	1371	1147	719	358	109	40	62	231	608	1005	1430
	CDD50	1999	0	0	9	30	179	407	550	488	272	60	4	0
	CDD65	327	0	0	0	1	16	64	125	86	32	3	0	0
	CDH74	2936	0	0	2	15	202	605	1142	685	262	23	0	0
	CDH80	652	0	0	0	2	42	133	292	135	47	1	0	0
	WSAvg	5.7	5.6	5.9	6.1	6.7	6.5	5.4	4.9	4.6	5.4	6.0	6.0	5.7
	PrecAvg	32.4	1.1	0.9	1.6	2.6	3.5	4.4	4.2	3.8	4.1	3.4	1.9	1.2
(15) Precipitation	PrecMax	42.2	2.4	2.2	3.2	5.6	6.4	8.4	9.1	10.0	9.7	7.0	6.3	2.3
	PrecMin	24.3	0.3	0.1	0.3	0.6	1.8	1.7	1.1	1.4	0.9	0.9	0.1	0.4
	PrecStd	5.8	0.6	0.6	0.9	1.3	1.3	1.6	2.0	2.0	2.2	1.8	1.3	0.6
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	43.1	48.4	68.2	75.1	84.4	88.2	90.9	88.2	84.4	77.3	63.2	48.2
		MCWB	36.9	42.9	58.8	57.5	66.8	72.6	76.0	73.1	70.2	61.6	52.6	45.7
	2%	DB	37.0	43.3	59.1	69.8	79.4	83.6	86.2	83.7	80.9	71.7	55.9	41.1
		MCWB	34.3	38.5	50.4	53.3	62.8	69.5	72.6	70.8	67.9	60.8	49.2	38.0
	5%	DB	34.2	37.4	52.1	63.8	74.8	80.9	82.4	81.0	76.9	65.6	51.8	36.8
		MCWB	32.8	33.8	45.0	49.3	60.4	67.2	69.9	68.3	65.1	57.9	46.3	34.9
	10%	DB	30.5	34.3	45.9	58.9	70.5	77.3	80.8	78.5	72.8	60.9	46.3	34.3
		MCWB	29.4	31.7	39.9	47.0	57.1	65.1	68.7	66.9	63.6	53.8	42.1	32.9
	0.4%	WB	38.1	44.6	60.3	61.7	71.5	75.3	79.2	76.4	73.4	69.8	56.7	46.3
		MCDB	41.0	46.8	66.0	71.7	79.3	83.4	86.4	82.9	80.4	71.7	60.0	47.7
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	34.9	38.8	52.1	56.1	66.8	72.3	75.4	73.6	70.2	62.3	50.9	38.3
		MCDB	36.9	42.7	56.4	66.1	74.5	80.4	82.6	79.8	76.3	67.3	55.3	40.0
	5%	WB	32.6	34.9	45.6	51.8	63.4	70.0	73.0	71.5	68.1	58.2	46.1	35.6
		MCDB	34.2	38.0	50.5	60.1	70.2	77.7	79.9	77.2	74.5	64.5	49.7	37.1
	10%	WB	29.8	31.7	40.2	48.0	60.0	67.6	70.8	69.2	65.6	54.5	42.6	32.8
		MCDB	30.9	34.2	45.7	57.9	67.6	74.3	77.3	75.6	71.2	59.8	46.7	34.3
(35) Mean Daily Temperature Range	5% DB	MDBR	17.7	20.0	20.3	21.3	22.8	21.2	21.1	20.5	20.6	17.9	14.6	14.6
		MCDBR	17.2	20.0	24.2	30.2	27.9	23.8	23.0	23.0	24.0	24.7	22.0	16.3
		MCWBR	14.5	15.3	15.5	16.4	13.7	12.0	11.2	11.4	12.5	14.7	15.2	13.5
	5% WB	MCDBR	16.4	17.1	21.1	26.3	21.8	20.3	20.2	18.8	20.3	20.6	19.4	14.1
		MCWBR	14.2	13.5	14.7	16.6	12.4	12.0	11.4	10.9	12.2	14.4	14.9	12.1
(40) Clear-Sky Solar Irradiance	taub		0.239	0.263	0.293	0.334	0.361	0.362	0.364	0.364	0.339	0.304	0.277	0.250
	taud		2.399	2.332	2.401	2.425	2.388	2.405	2.416	2.429	2.495	2.579	2.544	2.442
	Ebn at Noon		283	294	299	294	287	287	284	281	279	278	267	267
	Edh at Noon		22	29	32	34	37	36	36	34	29	23	20	19
(44) All-Sky Solar Radiation	RadAvg		494	844	1210	1443	1687	1851	1929	1617	1254	782	467	341
	RadStd		53	73	111	148	128	143	82	111	79	88	49	39

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (40 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page