

SIOUX FALLS, SD, USA

WMO: 726510

Lat: 43.578N

Lon: 96.754W

Elev: 435

StdP: 96.20

Time Zone: -6.00 (NAC)

Period: 94-19

WBAN: 14944

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-23.9	-21.3	-27.6	0.3	-23.7	-25.1	0.4	-21.0	14.6	-10.6	12.8	-9.2	3.6	310	0.630

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.3	32.9	23.5	31.3	22.8	29.8	22.0	25.3	30.4	24.3	29.4	23.3	28.3	6.2	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.8	19.7	28.9	22.7	18.4	27.8	21.7	17.2	26.7	80.2	30.5	75.7	29.4	71.8	28.3	28.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.1	10.9	9.4	DB	-28.1	35.7	3.1	2.1	-30.3	37.2	-32.1	38.5	-33.8	39.7	-36.1	41.3	(4)
(5)			WB	-28.3	27.1	3.0	0.8	-30.4	27.6	-32.2	28.1	-33.9	28.6	-36.1	29.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	8.2	-8.4	-6.0	0.9	8.1	14.5	20.5	23.2	21.7	17.4	9.6	1.4	-5.8	(6)	
	DBStd	12.36	7.24	7.15	7.24	5.74	4.82	3.88	3.38	3.16	4.74	5.33	6.10	6.54	(7)	
	HDD10.0	2253	570	448	292	101	14	0	0	0	3	73	263	489	(8)	
	HDD18.3	4134	828	681	540	311	137	22	4	7	73	275	508	748	(9)	
	CDD10.0	1584	0	0	10	43	154	315	409	362	225	60	5	0	(10)	
	CDD18.3	423	0	0	1	3	20	86	154	111	45	4	0	0	(11)	
	CDH23.3	4140	0	0	5	47	235	864	1567	948	427	46	1	0	(12)	
	CDH26.7	1379	0	0	1	12	64	292	591	289	121	9	0	0	(13)	
(14) Wind	WSAvg	4.5	4.5	4.6	5.0	5.4	4.8	4.2	3.9	3.7	4.2	4.4	4.4	4.3	(14)	
(15) Precipitation	PrecAvg	658	15	18	40	70	87	98	73	81	73	52	29	19	(15)	
	PrecMax	996	43	103	127	177	210	348	217	231	235	160	121	66	(16)	
	PrecMin	290	2	1	4	4	16	19	6	14	5	0	0	0	(17)	
	PrecStd	155	10	18	28	38	50	55	50	50	49	44	27	15	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.9	14.4	23.2	28.5	31.3	34.4	36.2	34.3	32.1	27.9	20.8	11.3	(19)	
		MCWB	5.1	8.9	12.9	16.7	19.3	23.1	24.3	24.0	21.9	17.6	12.4	7.1	(20)	
	2%	DB	5.3	9.6	18.8	24.0	28.4	31.8	33.4	31.5	29.8	24.0	16.8	7.6	(21)	
		MCWB	2.3	5.8	11.8	14.3	18.6	22.2	24.3	23.9	21.3	16.1	10.9	4.2	(22)	
	5%	DB	3.0	6.2	14.8	20.7	26.0	29.9	31.5	29.7	27.9	21.1	13.4	4.7	(23)	
		MCWB	1.2	3.3	10.0	12.5	17.5	21.3	23.8	22.8	20.1	14.5	8.6	2.0	(24)	
	10%	DB	1.3	3.6	11.4	17.9	23.5	28.1	29.9	28.0	25.8	18.4	10.4	2.7	(25)	
		MCWB	0.0	1.5	7.6	10.9	16.1	20.4	22.9	21.8	19.1	13.0	6.5	0.9	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	5.2	10.0	15.5	17.9	21.8	25.2	27.0	26.3	23.9	19.9	14.2	8.1	(27)	
		MCDB	9.5	14.5	19.4	26.0	28.2	31.2	31.8	31.3	28.9	24.3	18.7	10.7	(28)	
	2%	WB	2.7	5.8	12.7	15.5	20.0	23.8	25.7	25.0	22.7	17.5	11.4	4.2	(29)	
		MCDB	4.9	9.1	17.2	22.5	26.2	29.7	30.8	29.8	27.9	21.8	15.8	7.2	(30)	
	5%	WB	1.3	3.5	10.3	13.5	18.4	22.6	24.8	23.8	21.5	15.5	8.9	2.4	(31)	
		MCDB	2.8	6.0	14.8	19.3	24.3	28.2	30.0	28.4	26.2	19.9	12.9	4.5	(32)	
	10%	WB	0.1	1.6	7.5	11.7	17.0	21.4	23.8	22.8	20.2	13.6	6.7	1.0	(33)	
		MCDB	1.4	3.4	11.3	16.8	22.2	26.8	28.9	26.9	24.5	17.9	10.4	2.5	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	9.6	10.0	10.5	12.1	11.8	11.3	11.3	11.0	12.2	11.7	10.6	9.2	(35)	
		MCDBR	11.9	13.3	16.3	16.9	15.1	13.3	12.4	12.4	13.9	15.7	15.7	12.5	(36)	
	5% WB	MCWBR	9.4	9.7	10.1	9.2	7.8	6.3	5.8	6.2	6.8	8.8	10.1	9.3	(37)	
		MCWBR	11.2	12.6	15.3	14.7	13.0	11.5	11.2	10.9	11.4	13.2	14.7	11.8	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.272	0.285	0.319	0.370	0.388	0.397	0.402	0.405	0.356	0.327	0.294	0.274	(40)	
		taud	2.431	2.417	2.406	2.286	2.316	2.348	2.332	2.301	2.415	2.469	2.478	2.440	(41)	
	Ebn at Noon	Ebn at Noon	870	919	923	893	884	875	864	849	871	855	836	831	(42)	
		Edh at Noon	73	88	103	126	126	122	123	123	101	84	70	66	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	1.91	2.96	3.87	4.88	5.62	6.30	6.68	5.51	4.40	2.98	2.06	1.53	(44)	
	RadStd	RadStd	0.17	0.21	0.30	0.44	0.41	0.41	0.24	0.41	0.33	0.35	0.14	0.12	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (38 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page