

PIPESTONE, MN, USA

WMO: 726566

Lat: 43.983N

Lon: 96.300W

Elev: 529

StdP: 95.13

Time Zone: -6.00 (NAC)

Period: 94-19

WBAN: 04965

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-24.3	-22.2	-27.8	0.3	-23.4	-25.9	0.4	-21.7	13.0	-8.7	11.9	-7.8	3.4	300	0.596

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.6	32.1	23.2	30.1	22.5	28.7	21.6	25.4	29.3	24.4	28.3	23.3	27.0	5.7	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.1	20.2	27.9	22.9	18.8	26.9	22.2	18.1	26.3	81.6	29.5	76.6	28.4	72.3	26.7	30.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.8	10.6	9.2	DB	-28.6	34.5	3.5	1.7	-31.1	35.7	-33.2	36.7	-35.1	37.7	-37.7	38.9	(4)
(5)			WB	-29.1	27.0	3.5	1.6	-31.6	28.1	-33.6	29.1	-35.6	29.9	-38.1	31.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	7.5	-9.0	-6.7	-0.2	7.5	14.1	20.0	22.4	20.7	16.8	9.2	0.8	-6.4	(6)	
	DBStd	12.36	7.20	7.20	7.12	5.56	4.91	3.74	3.15	3.03	4.56	5.46	6.33	6.73	(7)	
	HDD10.0	2378	591	468	321	109	18	0	0	0	4	81	280	507	(8)	
	HDD18.3	4298	849	701	573	326	148	24	5	12	83	286	525	766	(9)	
	CDD10.0	1474	0	0	6	35	145	301	385	333	207	57	5	0	(10)	
	CDD18.3	353	0	0	0	2	17	75	132	87	36	4	0	0	(11)	
	CDH23.3	3032	0	0	1	28	194	671	1169	629	293	46	1	0	(12)	
	CDH26.7	872	0	0	0	6	56	206	374	151	68	11	0	0	(13)	
(14) Wind	WSAvg	4.1	4.4	4.6	4.6	4.8	4.7	3.9	3.2	3.0	3.6	4.1	4.3	4.3	(14)	
(15) Precipitation	PrecAvg	653	14	15	38	66	85	100	82	77	78	51	33	16	(15)	
	PrecMax	981	43	63	105	194	219	250	197	210	260	160	112	50	(16)	
	PrecMin	232	0	0	2	9	6	32	25	16	10	1	1	0	(17)	
	PrecStd	145	12	13	26	42	53	55	47	44	51	41	29	13	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	7.6	12.8	21.2	27.3	32.1	33.0	33.7	32.4	31.2	27.9	20.2	10.8	(19)	
		MCWB	3.5	7.3	12.6	14.9	18.5	22.7	24.9	24.8	21.0	16.9	12.0	7.2	(20)	
	2%	DB	3.6	7.9	16.7	22.6	27.8	31.1	32.2	29.9	28.6	23.7	16.2	7.0	(21)	
		MCWB	1.6	4.7	11.2	12.8	17.2	21.6	24.5	24.2	21.2	15.3	10.1	3.9	(22)	
	5%	DB	2.2	4.9	12.7	19.1	25.5	28.9	30.8	27.9	27.1	21.0	12.5	3.6	(23)	
		MCWB	1.1	3.0	8.9	11.1	16.4	20.6	23.9	22.4	19.5	14.3	8.1	1.6	(24)	
	10%	DB	1.0	2.6	9.2	17.1	22.7	27.4	28.7	27.2	24.7	17.7	9.1	2.3	(25)	
		MCWB	0.0	1.1	6.5	10.2	15.0	19.7	22.6	21.5	18.4	12.6	5.9	0.9	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	4.1	9.3	14.5	16.5	21.6	25.3	27.4	27.0	23.8	19.9	13.8	7.5	(27)	
		MCDB	7.1	12.4	17.9	23.6	27.6	30.4	30.9	30.2	28.1	24.5	17.9	8.9	(28)	
	2%	WB	2.2	5.1	11.6	14.3	19.3	23.9	25.9	25.0	22.4	17.4	10.8	3.8	(29)	
		MCDB	3.4	7.6	15.2	20.0	25.0	28.3	29.6	28.4	26.6	20.2	15.0	6.1	(30)	
	5%	WB	0.9	2.9	9.3	12.6	17.8	22.6	24.9	23.9	21.1	15.2	8.4	2.1	(31)	
		MCDB	1.9	4.6	13.2	17.5	22.5	26.6	28.9	27.2	25.0	19.4	12.1	3.4	(32)	
	10%	WB	-0.2	1.3	6.5	11.2	16.4	21.1	23.8	22.6	19.8	13.1	6.2	0.8	(33)	
		MCDB	0.8	2.6	9.5	15.8	21.3	25.8	27.7	25.6	23.6	17.2	9.3	2.0	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	8.9	9.5	9.2	11.0	11.0	10.5	10.6	10.3	11.6	10.9	9.7	8.4	(35)	
		MCDBR	10.5	11.8	14.2	16.2	14.7	12.6	11.7	11.3	13.4	15.0	14.2	10.9	(36)	
	5% WB	MCWBR	8.6	8.8	9.2	8.5	7.2	6.0	6.0	6.6	6.8	8.2	8.9	8.5	(37)	
		MCWBR	9.5	10.9	13.6	13.5	12.2	10.8	10.5	10.3	11.1	12.4	13.3	10.1	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.260	0.278	0.310	0.363	0.380	0.391	0.399	0.402	0.356	0.319	0.285	0.267	(40)	
		taud	2.449	2.417	2.424	2.304	2.333	2.359	2.328	2.292	2.401	2.487	2.502	2.445	(41)	
	Ebn at Noon	Ebn at Noon	885	924	932	900	891	879	867	850	868	864	846	837	(42)	
		Edh at Noon	71	88	100	123	123	121	123	123	102	82	67	65	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	1.88	2.94	3.83	4.81	5.55	6.20	6.64	5.48	4.34	2.91	1.97	1.46	(44)	
	RadStd	RadStd	0.19	0.27	0.34	0.45	0.41	0.41	0.24	0.43	0.32	0.36	0.15	0.13	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (45 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page