

WORLAND, WY, USA

WMO: 726665

Lat: 43.966N

Lon: 107.951W

Elev: 4172

StdP: 12.61

Time Zone: -7.00 (NAM)

Period: 00-19

WBAN: 24062

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-12.7	-6.7	-17.5	2.5	-12.1	-11.3	3.5	-5.9	24.7	29.7	19.9	32.3	3.1	190	0.583

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	32.8	95.8	61.2	93.0	60.9	90.1	60.3	65.0	85.7	63.5	84.6	62.1	83.9	8.0	10

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
58.6	85.8	70.1	56.2	78.5	69.0	54.1	72.7	68.6	32.1	85.2	30.8	84.7	29.7	83.6	75.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 23.6	18.9	15.9	DB	-24.4	101.3	5.5	2.4	-28.4	103.0	-31.6	104.4	-34.7	105.8	-38.7	107.5	(4)
(5)			WB	-24.6	68.1	5.4	2.4	-28.5	69.8	-31.7	71.2	-34.7	72.5	-38.6	74.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	45.6	17.7	22.2	37.5	46.1	55.1	65.8	74.0	70.4	60.5	46.0	31.9	18.4	(6)	
	DBStd	21.27	10.57	11.95	10.05	8.01	8.10	7.18	4.78	5.42	7.63	9.05	11.30	10.63	(7)	
	HDD50	4100	1000	779	398	165	43	2	0	0	10	178	546	979	(8)	
	HDD65	7704	1465	1199	853	569	320	75	4	18	173	590	994	1444	(9)	
	CDD50	2488	0	0	9	47	199	476	745	632	324	54	2	0	(10)	
	CDD65	617	0	0	0	0	11	99	284	185	37	1	0	0	(11)	
	CDH74	9767	0	0	5	47	355	1690	3975	2707	922	66	0	0	(12)	
	CDH80	4612	0	0	0	5	95	754	2088	1299	357	14	0	0	(13)	
(14) Wind	WSAvg	5.7	4.0	4.8	6.8	7.7	7.0	6.4	5.9	5.6	5.5	5.3	4.8	4.3	(14)	
(15) Precipitation	PrecAvg	7.2	0.3	0.2	0.4	0.9	1.3	1.1	0.5	0.6	0.7	0.6	0.4	0.3	(15)	
	PrecMax	11.3	1.0	1.0	1.2	2.0	4.1	3.5	2.0	2.8	2.6	2.5	0.9	0.9	(16)	
	PrecMin	3.7	0.0	0.0	0.0	0.0	0.1	0.1	0.0	0.0	0.0	0.1	0.0	0.0	(17)	
	PrecStd	1.9	0.2	0.2	0.3	0.5	1.0	0.8	0.5	0.6	0.6	0.6	0.3	0.2	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	48.8	55.7	72.3	79.4	87.5	97.3	100.3	97.6	92.4	81.8	66.0	49.8	(19)	
		MCWB	38.2	41.5	48.7	51.7	57.2	59.9	62.9	60.9	60.1	55.4	47.5	39.4	(20)	
	2%	DB	41.8	48.4	66.2	73.8	82.5	92.9	97.0	94.1	88.4	74.2	59.3	42.8	(21)	
		MCWB	34.4	37.3	46.3	49.4	56.2	60.2	62.6	60.0	58.1	51.9	44.0	35.1	(22)	
	5%	DB	37.2	43.1	60.5	68.8	77.8	88.5	94.0	91.2	84.3	68.5	53.5	37.7	(23)	
		MCWB	31.6	35.0	43.8	48.1	55.0	59.3	61.9	59.7	56.7	50.5	41.3	31.7	(24)	
	10%	DB	33.0	38.8	54.7	63.6	72.8	83.9	91.0	88.0	79.6	62.8	48.1	33.3	(25)	
		MCWB	29.0	32.7	41.3	46.2	53.0	58.3	61.4	59.7	55.8	47.6	38.3	29.4	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	38.8	42.5	49.9	53.1	60.3	64.5	68.3	64.8	62.6	56.4	48.1	39.9	(27)	
		MCDB	47.2	52.8	69.4	76.5	80.3	85.1	89.1	85.3	85.3	76.5	63.7	49.4	(28)	
	2%	WB	34.9	38.3	46.8	50.7	58.1	62.5	66.2	63.2	60.2	53.5	44.6	35.4	(29)	
		MCDB	41.1	46.7	64.4	70.0	76.7	84.6	87.1	84.6	81.6	71.6	58.3	41.7	(30)	
	5%	WB	32.1	35.4	44.4	48.7	56.2	61.0	64.6	61.9	58.5	51.0	41.8	32.3	(31)	
		MCDB	36.7	42.2	59.0	66.5	74.0	83.1	85.3	83.8	79.3	66.3	52.4	37.1	(32)	
	10%	WB	29.1	32.8	41.9	46.8	54.3	59.5	63.3	60.6	56.5	48.5	38.9	29.6	(33)	
		MCDB	33.0	38.4	53.8	62.5	70.0	80.5	84.2	82.4	76.2	61.4	47.4	33.6	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	24.0	23.6	26.0	26.3	26.2	30.2	32.8	32.7	31.0	27.0	25.4	22.9	(35)	
		MCDBR	26.3	27.0	34.7	36.2	35.2	38.1	37.1	37.8	39.6	37.0	34.0	26.9	(36)	
	5% WB	MCWBR	19.5	17.5	17.7	16.1	13.5	13.6	12.8	13.8	16.5	18.2	20.2	19.9	(37)	
		MCWBR	25.8	26.1	32.4	33.3	31.5	34.3	33.1	33.0	34.9	33.8	32.1	25.7	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.247	0.253	0.277	0.313	0.332	0.339	0.363	0.355	0.320	0.281	0.256	0.244	(40)	
		taud	2.547	2.552	2.507	2.403	2.410	2.411	2.374	2.376	2.468	2.561	2.555	2.546	(41)	
	Ebn at Noon		290	306	308	302	297	294	286	285	288	290	283	280	(42)	
		Edh at Noon	20	24	29	35	36	36	37	36	30	24	20	18	(43)	
(44) All-Sky Solar Radiation	RadAvg		603	912	1321	1661	1953	2320	2321	1991	1574	1030	675	489	(44)	
	RadStd		42	59	86	91	180	147	84	73	109	82	53	29	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (10 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page