

CALDWELL, ID, USA

WMO: 726813

Lat: 43.650N

Lon: 116.633W

Elev: 2429

StdP: 13.45

Time Zone: -7.00 (NAM)

Period: 94-19

WBAN: 94195

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 9.5	(c) 15.6	(d) 1.1	(e) 6.3	(f) 11.6	(g) 7.0	(h) 8.6	(i) 16.7	(j) 25.4	(k) 37.9	(l) 22.3	(m) 37.8	(n) 2.9	(o) 120	(p) 0.548

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 32.5	(c) 97.3	(d) 66.2	(e) 93.4	(f) 64.9	(g) 91.0	(h) 64.0	(i) 68.3	(j) 92.7	(k) 66.7	(l) 90.5	(m) 65.3	(n) 88.6	(o) 5.7	(p) 350

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
59.3	82.5	77.8	56.9	75.6	77.1	55.0	70.4	75.8	33.9	92.6	32.5	91.0	31.3	88.4	77.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
22.1	19.2	17.0	DB	5.7	101.8	8.3	3.1	-0.3	104.1	-5.2	105.9	-9.9	107.7	-16.0	110.0	
			WB	4.8	72.3	7.9	2.1	-0.9	73.8	-5.6	75.0	-10.0	76.2	-15.8	77.8	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	51.7	31.0	36.6	44.4	50.0	58.6	66.5	75.3	72.7	63.3	50.3	39.4	31.0	(6)
	DBStd	16.46	7.93	6.83	6.25	6.26	7.07	6.90	5.06	5.23	6.49	6.73	7.42	8.05	(7)
	HDD50	2236	589	377	193	77	11	0	0	0	1	75	323	590	(8)
	HDD65	5621	1054	795	638	452	222	64	3	7	107	457	767	1055	(9)
	CDD50	2849	0	1	20	76	276	495	784	705	401	85	6	0	(10)
	CDD65	759	0	0	0	0	22	109	322	247	57	2	0	0	(11)
	CDH74	11390	0	0	1	55	468	1659	4543	3526	1084	54	0	0	(12)
	CDH80	5563	0	0	0	6	139	697	2507	1806	400	8	0	0	(13)
(14) Wind	WSAvg	6.6	5.8	7.3	8.2	8.2	7.4	6.9	5.9	5.5	5.5	5.7	6.3	6.4	(14)
(15) Precipitation	PrecAvg	11.0	1.5	1.0	1.1	1.0	0.9	0.8	0.3	0.4	0.6	0.7	1.3	1.4	(15)
	PrecMax	17.4	5.0	3.4	3.4	3.3	2.6	2.6	1.2	2.3	2.5	1.6	2.6	4.0	(16)
	PrecMin	5.8	0.3	0.0	0.1	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.2	0.1	(17)
	PrecStd	2.7	1.0	0.7	0.8	0.7	0.6	0.6	0.4	0.6	0.7	0.5	0.7	0.9	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	51.8	60.7	71.3	80.9	89.9	97.3	101.5	99.3	93.0	81.0	64.0	54.1	(19)
		MCWB	44.4	48.4	51.8	57.7	62.8	66.8	68.4	65.9	64.2	58.0	50.2	46.0	(20)
	2%	DB	46.3	54.8	64.7	73.5	83.8	91.3	98.8	95.9	88.9	73.2	58.9	48.5	(21)
		MCWB	40.7	44.7	49.0	54.2	60.1	64.1	66.9	65.4	62.4	54.9	48.0	42.7	(22)
	5%	DB	44.1	51.6	61.4	69.8	79.4	88.0	95.6	92.8	84.2	69.0	54.8	45.6	(23)
		MCWB	38.8	43.2	47.4	52.1	58.0	62.9	66.3	64.1	60.5	52.9	45.8	40.3	(24)
	10%	DB	41.1	47.6	57.1	64.0	74.6	83.6	92.4	90.3	81.0	64.0	51.8	42.4	(25)
		MCWB	36.4	41.1	45.2	49.3	56.3	61.0	65.0	63.2	59.0	50.1	43.8	37.7	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	45.1	49.1	53.2	58.5	64.3	69.2	71.5	68.4	66.8	59.2	52.4	46.9	(27)
		MCDB	49.3	58.9	66.3	77.8	85.4	93.9	95.7	93.4	87.0	77.9	59.8	52.9	(28)
	2%	WB	41.7	45.8	50.5	55.3	61.3	66.1	69.2	66.8	64.3	56.1	49.4	43.7	(29)
		MCDB	45.9	53.7	62.4	71.0	80.4	88.1	94.0	91.7	83.7	71.2	57.7	48.2	(30)
	5%	WB	39.3	43.4	48.6	52.8	59.2	63.9	67.7	65.5	62.2	53.5	46.4	40.8	(31)
		MCDB	43.4	50.0	59.7	66.6	77.0	84.8	92.0	90.2	81.0	66.3	54.0	45.2	(32)
	10%	WB	37.1	41.1	46.3	50.6	57.2	61.8	66.1	64.1	59.8	51.2	44.1	37.9	(33)
		MCDB	41.0	46.8	56.7	63.1	73.1	81.6	90.1	87.6	78.5	63.0	50.5	41.7	(34)
(35) Mean Daily Temperature Range	MDBR		12.5	17.1	22.1	23.9	25.2	28.0	32.5	32.9	30.4	25.5	18.4	12.8	(35)
	5% DB	MCDBR	14.9	21.6	28.4	33.7	33.1	35.7	37.0	36.8	36.4	31.9	22.8	15.1	(36)
		MCWBR	11.1	14.0	16.5	17.8	15.2	15.3	14.8	14.2	15.6	17.3	14.5	11.0	(37)
	5% WB	MCDBR	14.0	19.7	25.7	30.2	30.5	33.6	34.7	34.5	32.2	28.7	21.0	13.8	(38)
		MCWBR	10.9	13.2	15.4	16.4	14.2	14.8	14.7	13.6	13.7	15.8	13.8	10.3	(39)
(40) Clear-Sky Solar Irradiance	taub		0.265	0.273	0.288	0.311	0.331	0.329	0.336	0.339	0.316	0.290	0.273	0.266	(40)
	taud		2.574	2.592	2.563	2.485	2.446	2.484	2.470	2.442	2.508	2.578	2.579	2.564	(41)
	Ebn at Noon		283	299	305	303	298	298	294	290	291	287	277	272	(42)
	Edh at Noon		20	24	28	33	35	34	34	34	29	24	20	19	(43)
(44) All-Sky Solar Radiation	RadAvg		495	818	1234	1731	2104	2390	2456	2120	1643	1076	626	409	(44)
	RadStd		72	107	121	136	144	123	85	89	88	79	53	60	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (11 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page