

MULLAN PASS, ID, USA

WMO: 726817

Lat: 47.457N

Lon: 115.645W

Elev: 6028

StdP: 11.76

Time Zone: -7.00 (NAM)

Period: 99-19

WBAN: 24154

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-2.0	3.5	-8.8	4.3	-0.4	-3.2	5.8	6.8	18.2	21.3	16.3	22.5	5.8	120	0.624

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.2	77.4	54.8	74.5	53.9	71.9	53.0	57.3	72.1	55.7	70.5	54.2	68.9	3.7	310

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
51.5	70.8	62.0	48.9	64.3	60.5	47.1	59.9	58.6	27.1	72.1	25.9	70.7	24.9	68.9	64.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
15.1	12.6	11.1	DB	-6.2	83.0	7.3	3.2	-11.5	85.3	-15.7	87.1	-19.8	88.9	-25.1	91.2	
			WB	-6.9	60.5	7.1	2.0	-12.0	61.9	-16.2	63.1	-20.2	64.2	-25.3	65.6	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	38.2	23.4	22.6	27.7	33.3	42.5	49.6	60.8	60.0	50.5	37.8	27.8	21.7		
	DBStd	16.10	7.69	8.55	7.23	7.82	9.01	9.20	8.02	7.84	9.79	8.94	8.38	7.88		
	HDD50	5256	824	768	691	504	271	119	14	16	115	390	667	877		
	HDD65	9859	1289	1188	1156	950	698	468	175	190	444	842	1117	1342		
	CDD50	965	0	0	0	3	38	107	349	326	129	13	0	0		
	CDD65	92	0	0	0	0	0	6	45	34	7	0	0	0		
	CDH74	301	0	0	0	0	0	25	155	108	13	0	0	0		
	CDH80	27	0	0	0	0	0	3	13	11	0	0	0	0		
	WSAvg	5.5	5.7	6.0	6.2	5.6	5.2	5.2	4.8	4.7	5.1	5.8	6.2	5.6		
	PrecAvg	37.8	4.6	3.5	4.5	3.2	3.0	3.0	0.8	1.0	1.7	3.7	5.2	4.9		
(15) Precipitation	PrecMax	50.8	8.8	6.8	10.6	8.1	5.5	6.5	2.1	4.6	5.8	10.2	12.8	10.0		
	PrecMin	30.2	1.2	0.8	2.2	1.3	0.8	1.3	0.1	0.0	0.4	0.3	2.3	0.4		
	PrecStd	5.4	2.0	1.5	2.0	1.6	1.2	1.3	0.6	1.2	1.3	2.1	2.5	2.5		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	44.8	43.0	49.5	60.9	69.5	77.3	81.9	81.1	75.7	64.0	52.1	39.4		
		MCWB	32.3	34.7	38.0	44.0	49.7	55.8	57.9	54.6	52.2	47.4	40.4	32.0		
	2%	DB	38.7	38.7	45.0	54.4	64.1	71.7	78.4	76.8	71.7	58.7	46.3	36.0		
		MCWB	32.4	32.2	35.5	41.4	47.8	54.3	56.0	53.9	51.1	44.9	39.2	32.4		
	5%	DB	34.8	35.3	40.7	49.7	60.2	66.7	75.0	73.9	67.9	54.2	42.8	33.5		
		MCWB	31.1	31.2	34.0	39.2	45.9	51.8	54.8	53.3	49.4	43.1	37.2	31.2		
	10%	DB	32.2	32.6	37.0	45.5	55.7	63.2	72.3	71.3	64.1	50.3	38.7	31.0		
		MCWB	30.1	30.4	32.5	37.1	44.0	50.0	53.8	52.1	48.2	41.1	34.3	29.3		
	0.4%	WB	37.0	36.2	39.9	45.5	51.6	57.8	60.7	58.0	55.4	50.0	44.3	36.3		
		MCDB	39.7	39.5	44.7	58.4	63.3	73.4	77.1	72.0	68.3	59.9	47.4	37.0		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	33.8	33.9	37.2	42.2	49.0	54.9	58.3	56.2	52.8	46.7	40.8	33.6		
		MCDB	36.2	36.1	41.7	52.0	61.1	68.5	73.6	71.4	67.3	55.5	44.8	34.4		
	5%	WB	31.8	32.3	35.3	40.1	47.2	52.9	56.5	54.8	50.9	44.2	37.5	31.0		
		MCDB	34.0	34.4	39.5	48.6	57.9	65.4	71.5	70.2	65.0	51.9	40.7	32.3		
	10%	WB	30.1	30.4	33.1	37.5	45.2	50.7	54.9	53.4	49.3	42.1	35.2	29.2		
		MCDB	31.9	32.5	36.7	43.6	54.2	61.7	69.7	68.5	62.3	48.7	38.2	30.8		
(35) Mean Daily Temperature Range	5% DB	MDBR	7.4	8.6	9.8	11.5	12.9	13.8	15.2	15.0	13.2	10.4	7.7	7.1		
		MCDBR	9.0	10.2	14.0	17.4	16.3	17.6	16.1	16.8	16.2	14.5	11.1	9.0		
		MCWBR	6.0	6.9	8.2	8.9	8.0	9.1	8.8	8.4	8.0	8.1	7.0	6.8		
		MCDBR	7.9	8.9	12.5	16.0	15.4	16.9	16.0	15.7	15.3	13.2	9.7	7.9		
	5% WB	MCWBR	6.5	6.9	8.4	8.7	8.0	9.2	9.2	8.3	7.8	7.9	6.9	6.8		
(40) Clear-Sky Solar Irradiance	taub		0.225	0.230	0.256	0.292	0.303	0.307	0.305	0.321	0.298	0.262	0.251	0.222		
	taud		2.501	2.495	2.496	2.479	2.516	2.535	2.544	2.493	2.546	2.668	2.600	2.558		
	Ebn at Noon		288	308	312	306	305	303	302	293	292	292	274	278		
	Edh at Noon		19	24	28	32	32	32	31	31	27	20	17	16		
(44) All-Sky Solar Radiation	RadAvg		346	619	984	1432	1754	1935	2299	1909	1342	795	390	273		
	RadStd		42	77	103	126	138	175	152	123	142	91	40	33		

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (15 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+149	N/A

Nomenclature: See separate page