

STANLEY RANGER STATION, ID, USA

WMO: 726824

Lat: 44.171N

Lon: 114.927W

Elev: 1980

StdP: 79.70

Time Zone: -7.00 (NAM)

Period: 01-19

WBAN: 04112

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-26.9	-23.8	-29.6	0.3	-26.6	-26.6	0.4	-23.7	7.5	-1.9	6.6	-1.6	0.4	100	0.667

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	22.2	29.6	12.6	28.1	12.1	26.6	11.6	14.0	25.0	13.2	24.8	12.5	24.1	3.2	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10.8	10.3	15.0	9.0	9.1	14.3	7.5	8.2	13.9	45.3	24.8	42.9	24.9	40.8	24.0	17.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
6.2	5.4	4.7	-31.9	32.1	2.6	1.2	-33.8	33.0	-35.3	33.7	-36.8	34.3	-38.7	35.2		
			DB	WB	-32.0	15.8	2.5	0.9	-33.8	16.5	-35.3	17.0	-36.7	17.5	-38.6	18.2

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	2.6	-9.0	-6.8	-2.6	1.1	6.3	10.8	15.2	13.9	9.6	3.7	-3.0	-8.2
	DBStd	9.51	6.54	5.48	4.68	4.03	3.63	3.55	2.64	2.63	3.45	4.06	5.93	7.35
	HDD10.0	3074	588	472	391	266	122	32	1	4	48	196	389	565
	HDD18.3	5733	846	705	649	516	372	227	102	138	263	453	639	821
	CDD10.0	390	1	0	0	0	8	56	161	126	34	2	1	2
	CDD18.3	6	0	0	0	0	0	1	4	1	0	0	0	0
	CDH23.3	1291	0	0	0	0	7	120	645	433	84	2	0	0
	CDH26.7	313	0	0	0	0	1	24	181	96	12	0	0	0
Wind	WSAvg	1.5	1.1	1.4	1.7	1.7	1.8	1.9	1.8	1.7	1.5	1.4	1.2	1.2
Precipitation	PrecAvg	317	34	23	29	30	39	29	13	13	17	25	25	37
	PrecMax	514	79	90	77	56	83	85	29	75	51	125	45	120
	PrecMin	128	3	2	4	2	6	3	1	1	2	4	5	2
	PrecStd	87	22	20	18	12	22	24	8	14	13	23	13	28
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.3	8.1	13.1	18.6	24.3	29.7	32.0	30.7	28.4	21.5	15.8	17.4
		MCWB	2.2	1.5	3.8	6.8	10.0	13.5	13.9	12.9	11.6	9.2	4.5	4.1
	2%	DB	3.5	5.0	10.0	15.4	21.6	26.5	30.1	29.0	25.7	17.9	11.5	9.9
		MCWB	0.6	0.7	2.7	5.4	9.1	12.1	13.0	12.1	10.6	7.3	3.7	1.3
	5%	DB	2.0	3.0	7.4	12.7	19.2	24.2	28.8	27.7	23.7	15.4	8.0	3.7
		MCWB	0.2	-0.1	1.5	4.3	8.3	10.9	12.4	11.6	9.8	6.3	2.5	0.8
	10%	DB	0.3	1.4	5.1	9.6	16.9	22.2	27.3	26.1	21.5	12.3	5.1	1.8
		MCWB	-1.1	-0.8	0.7	3.0	7.5	10.1	12.1	11.2	9.1	5.1	1.5	0.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	3.0	2.7	5.0	7.5	11.5	14.6	15.4	14.4	13.0	10.0	7.0	4.1
		MCDB	7.1	5.3	10.5	17.4	20.6	26.7	25.5	24.2	23.5	19.3	11.2	16.2
	2%	WB	1.4	1.6	3.3	5.8	10.0	12.9	14.4	13.3	11.9	8.4	4.6	2.2
		MCDB	3.6	4.0	8.0	13.9	19.7	24.0	25.5	24.5	22.7	15.8	9.1	6.8
	5%	WB	0.2	0.5	2.4	4.6	8.9	11.8	13.6	12.6	10.7	7.0	3.1	1.2
		MCDB	1.9	2.5	6.4	11.5	17.8	22.2	25.3	24.4	21.4	13.8	7.3	4.2
	10%	WB	-1.1	-0.8	1.4	3.4	7.8	10.7	12.9	11.9	9.6	5.8	1.8	0.1
		MCDB	0.3	1.5	4.5	8.7	15.7	20.5	24.8	23.9	19.5	11.6	5.0	2.3
Mean Daily Temperature Range	5% DB	MDBR	12.5	13.6	14.0	13.9	15.8	18.2	22.2	22.4	20.4	15.8	12.9	11.1
		MCDBR	11.3	13.5	17.0	20.0	22.1	23.4	25.5	25.6	25.8	21.6	15.6	9.4
		MCWBR	8.8	9.9	10.5	11.0	10.9	10.7	10.8	11.2	12.5	12.0	9.4	5.8
	5% WB	MCDBR	10.1	10.7	13.8	17.7	19.7	20.7	21.6	22.0	22.3	19.5	14.1	8.2
		MCWBR	8.1	8.1	8.6	9.9	9.9	9.6	9.4	10.0	11.0	11.0	9.0	5.8
Clear-Sky Solar Irradiance	taub	0.234	0.244	0.261	0.320	0.313	0.308	0.314	0.320	0.299	0.275	0.250	0.239	
	taud	2.393	2.350	2.362	2.297	2.457	2.511	2.519	2.478	2.554	2.593	2.559	2.435	
	Ebn at Noon	917	965	987	943	956	959	949	933	934	922	898	877	
	Edh at Noon	73	92	105	123	109	103	102	102	87	73	62	64	
All-Sky Solar Radiation	RadAvg	1.74	2.69	3.94	5.26	6.11	7.11	7.46	6.40	4.96	3.22	1.91	1.36	
	RadStd	0.21	0.33	0.38	0.41	0.59	0.55	0.44	0.36	0.37	0.27	0.17	0.18	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (13 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page