

BURNS, OR, USA

WMO: 726830

Lat: 43.595N

Lon: 118.956W

Elev: 1262

StdP: 87.06

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 94185

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-19.2	-15.5	-21.8	0.6	-18.1	-18.4	0.9	-14.1	10.9	4.0	9.4	1.7	1.1	260	0.626

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	21.2	34.2	15.5	32.7	15.2	31.0	14.7	17.3	29.6	16.1	29.4	15.3	28.7	3.5	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
13.1	11.0	21.0	11.3	9.7	19.0	9.8	8.8	18.1	53.3	29.4	49.2	29.3	46.7	28.7	31.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.7	8.4	7.4	-24.2	37.2	3.9	1.7	-27.0	38.4	-29.2	39.4	-31.4	40.4	-34.2	41.6		
(5)			-24.4	19.8	3.8	3.6	-27.2	22.3	-29.4	24.4	-31.5	26.4	-34.3	29.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	7.4	-3.3	-1.2	3.2	6.2	10.9	15.0	20.2	18.8	13.8	7.0	1.1	-3.8		
	DBStd	9.08	5.14	4.37	3.68	3.80	4.17	4.09	3.23	3.19	4.09	4.05	4.73	5.17		
	HDD10.0	1929	413	314	210	126	40	8	0	1	13	110	267	428		
	HDD18.3	4149	672	548	468	365	233	114	19	33	143	352	517	686		
	CDD10.0	966	0	0	1	10	67	157	315	272	126	17	1	0		
	CDD18.3	143	0	0	0	0	2	13	76	47	6	0	0	0		
	CDH23.3	4113	0	0	0	7	107	473	1715	1336	449	27	0	0		
	CDH26.7	1800	0	0	0	0	22	160	852	609	152	4	0	0		
(14) Wind	WSAvg	2.9	2.2	2.7	3.3	3.7	3.5	3.4	3.1	3.0	2.8	2.7	2.4	2.3		
(15) Precipitation	PrecAvg	297	47	27	29	17	22	17	8	14	12	19	39	46		
	PrecMax	407	146	54	62	53	59	49	29	50	30	94	81	139		
	PrecMin	189	18	6	3	2	1	0	0	0	0	3	0	0		
	PrecStd	56	29	16	20	15	17	15	8	17	10	20	20	29		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.2	13.5	19.4	24.3	29.2	33.7	37.2	35.6	32.7	26.5	17.5	9.9		
		MCWB	5.2	7.1	8.4	11.0	13.9	16.0	17.0	16.0	14.1	12.0	8.6	6.3		
	2%	DB	6.5	9.5	16.2	21.5	26.3	30.6	34.7	33.7	30.4	22.9	14.1	7.0		
		MCWB	3.4	5.0	7.2	10.1	13.1	14.8	15.7	15.5	13.4	10.7	7.6	4.3		
	5%	DB	4.6	7.0	13.5	18.2	23.6	28.3	33.3	32.2	28.4	19.9	11.2	5.1		
		MCWB	2.2	3.5	6.2	8.6	11.9	14.0	15.5	14.9	12.9	9.3	6.4	2.8		
	10%	DB	3.0	5.0	10.9	15.3	21.0	26.1	31.6	30.4	26.0	16.9	8.8	3.4		
		MCWB	1.4	2.3	5.2	7.5	10.8	13.0	15.1	14.2	12.3	8.1	5.0	1.6		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.1	7.6	9.7	11.9	15.3	17.8	21.0	20.8	17.4	13.0	10.2	6.6		
		MCDB	8.0	12.6	17.1	22.0	25.8	30.5	30.9	32.2	25.2	23.3	15.3	8.8		
	2%	WB	3.8	5.5	8.0	10.5	13.9	15.8	17.7	16.5	14.9	11.5	8.4	4.8		
		MCDB	5.8	8.8	14.2	19.6	23.7	28.2	30.4	30.1	26.5	21.0	12.6	6.8		
	5%	WB	2.6	3.9	6.9	9.2	12.7	14.7	16.4	15.5	13.8	10.1	6.9	3.1		
		MCDB	4.2	6.5	12.5	17.1	21.9	26.3	30.2	29.7	26.5	18.3	10.9	4.5		
	10%	WB	1.5	2.5	5.7	7.8	11.5	13.6	15.6	14.6	12.6	8.8	5.4	1.8		
		MCDB	2.9	4.7	10.5	14.4	19.5	24.4	29.4	28.6	25.1	15.8	8.5	3.1		
(35) Mean Daily Temperature Range	5% DB	MDBR	10.3	10.7	12.9	14.7	15.9	17.9	21.2	21.7	21.2	18.2	13.1	10.5		
		MCDBR	11.1	12.3	18.0	20.8	20.9	21.8	23.3	23.9	24.7	23.4	16.9	10.8		
		MCWBR	8.3	8.4	10.3	10.9	9.6	9.4	9.1	10.1	11.4	12.9	10.9	8.3		
	5% WB	MCDBR	9.8	11.4	16.1	18.7	18.6	20.1	21.4	22.1	22.3	20.4	15.3	9.4		
		MCWBR	7.6	8.0	9.6	10.1	8.7	9.0	9.4	9.9	10.8	11.6	10.2	7.5		
(40) Clear-Sky Solar Irradiance	taub	0.260	0.267	0.275	0.295	0.308	0.308	0.315	0.311	0.294	0.285	0.264	0.259			
	taud	2.560	2.595	2.601	2.534	2.516	2.542	2.532	2.528	2.562	2.590	2.596	2.562			
	Ebn at Noon	900	950	979	975	963	960	949	945	942	913	887	866			
	Edh at Noon	65	74	84	98	103	101	100	97	87	74	62	59			
(44) All-Sky Solar Radiation	RadAvg	1.64	2.59	3.85	5.37	6.43	7.48	7.77	6.72	5.19	3.40	1.97	1.32			
	RadStd	0.26	0.32	0.36	0.43	0.48	0.39	0.29	0.32	0.29	0.27	0.18	0.22			

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	-1.83	-1.73	N/A	-0.42	N/A	N/A	N/A	N/A	N/A	
(47) Regional (13 neighbors)		N/A	N/A	-1.42	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page